



Division of Finance and Business Operations

Procurement & Strategic Sourcing  
5700 Cass Avenue, suite 4200  
Detroit, Michigan 48202  
(313) 577-3734

April 10, 2024

**Addendum #3 To  
Request for Proposal**

**For Wayne State University Detroit Campus Wide Elevator Modernization - REBID  
Projects:**

005-352965 Science Hall  
034-357608 Student Center  
036-406207 Reuther Library  
042-357625 Alumni House  
045-401743 Parking Structure 5  
051-344289 Parking Structure 1  
071-400578 5057 Woodward  
088-402566 Parking Structure 6  
089-406148 Biological Sciences Building  
130-400577 Faculty/Administration Building  
629-409520 Elliman Clinical Research

**Dated March 28, 2024**

**Points of Clarifications since the Pre-proposal Meeting:**

The information on page 2 of this Addendum is being issued as a clarification to the Campus Wide Elevator Modernization project. See below clarifying which facilities have the backup power.

The Addendum must be acknowledged on your lump sum bid.

A copy of this Addendum will be posted to the Purchasing web site at <http://go.wayne.edu/bids>.

All questions concerning this project must be emailed to: **Kenneth Doherty**, Procurement & Strategic Sourcing. Email: **ken-doherty@wayne.edu**.

Bids are due **by electronic submission on** no later than 2:00 p.m., **April 22, 2024**. The link for bid submission was posted with the bid details at <http://go.wayne.edu/bids> beginning **March 28, 2024**.

Thank you,

**Kenneth Doherty,  
Associate Vice President**



**Design and Construction Services**  
Facilities Planning & Management

**ADDENDUM**

---

Project Name: Wayne State University  
Campus

Addendum Number: 3

WSU Project No: Multiple

Date: April 10, 2024

Prepared by: S. Vrubel

*This Addendum is issued pursuant to the Wayne State University Campus Wide Elevator Modernization Project. This Addendum serves to clarify, revise, and supersede information in the Pre-Bid Meeting, Specifications, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the CONTRACT FOR CONSTRUCTION MANAGEMENT SERVICES. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.*

**PART 1 – SUPPLEMENTAL INFORMATION**

- A. The following information is being issued as a clarification to the Campus Wide Elevator Modernization project. See below clarifying which facilities have the backup power.
- a. Science Hall Building has full building generator, including elevators.
  - b. Student Center Building has full building generator, including elevators.
  - c. Reuther Library does not have the generator.
  - d. Faculty Administration Building has a generator for life safety systems only.
  - e. Alumni House does not have the generator.
  - f. Elliman Clinical Research Building has full building generator, including elevators.
  - g. Parking Structure 5 does not have the generator.
  - h. Parking Structure 1 does not have the generator.
  - i. 5057 Woodward Ave. does not have the generator.
  - j. Parking Structure #6 does not have the generator.
  - k. Biological Sciences Building has full building generator, including elevators.

**END OF DOCUMENT**