



November 20, 2019

**Addendum #3 To
Request for Proposal
For Cohn Building Student Commons: Project 048-291367 and
For Cohn Building Student Commons FFE: Project 048-291367
Dated November 1, 2019**

The Addendum must be acknowledged on your lump sum bid.

NOTE: You must have attended a pre-bid conference in order to be eligible to bid on a particular project. Receipt of minutes or addenda without being at a pre-bid conference does not qualify your company to bid.

Please find the following questions and clarifications with regards to the above bid opportunity.

Question 1: The specs call for this laminate to be fire rated class A the drawings call for a K28 laminate finish, but the fire rated laminate is only available in a 60, K01 & K07 finish

Answer: The laminate should be Class A fire rated with a 60 finish.

IMPORTANT- This is an addendum which MUST be acknowledged on your bid form

We will require your lump sum proposals, vendor qualification questionnaire and your bid bond documents as a single PDF in your electronic submission.

All questions concerning this project must be emailed to: Robert Kuhn, Sr Buyer, Procurement & Strategic Sourcing. Email: ac6243@wayne.edu, and copy Kim Toby-Tomszewski, Sr. Buyer, at ac9934@wayne.edu.

Do not contact either FP&M or the Design Firm directly as this may result in disqualification of your proposal.

Thank you for interest shown in working with Wayne State University.

Robert Kuhn
Sr. Buyer

CC: Kidest Albaari – Project Manager
Vincent Mattina – Fishbeck
Kim Toby-Tomszewski, Sr. – Buyer
Attendee List