

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

**SECTION 260101
ELECTRICAL DEMOLITION**

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. This Section includes the following:
 - 1. Demolition and removal of selected portions of electrical items.
 - 2. Salvage of existing items to be reused or recycled.

1.03 DEFINITIONS

- A. Remove: Detach items from existing construction and legally dispose of them off-site, unless indicated to be removed and salvaged or removed and reinstalled.
- B. Remove and Reinstall: Detach items from existing construction, prepare them for reuse, and reinstall them where indicated. Extend wiring and conduit as required.
- C. Existing to Remain: Existing items of construction that are not to be removed and that are not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.

1.04 MATERIALS OWNERSHIP

- 1. Coordinate with Owner's Representative, who will establish special procedures for removal and salvage.

1.05 INFORMATIONAL SUBMITTALS

- A. Schedule of Electrical Demolition Activities: Indicate the following:
 - 1. Detailed sequence of selective demolition and removal work, with starting and ending dates for each activity. Ensure Owner's on-site operations are uninterrupted.
 - 2. Locations of proposed dust- and noise-control temporary partitions and means of egress.
 - 3. Coordination of Owner's continuing occupancy of portions of existing building and of Owner's partial occupancy of completed Work.
 - 4. Means of protection for items to remain and items in path of waste removal from building.
- B. Inventory: After electrical demolition is complete, submit a list of items that have been removed and salvaged.

1.06 QUALITY ASSURANCE

- A. Demolition Firm Qualifications: An experienced firm that has specialized in demolition work similar in material and extent to that indicated for this Project.
- B. Regulatory Requirements: Comply with governing EPA notification regulations before beginning electrical demolition. Comply with hauling and disposal regulations of authorities having jurisdiction.
- C. Standards: Comply with ANSI A10.6 and NFPA 241.
- D. Pre-demolition Conference: Conduct conference at Project site to comply with:
 - 1. Inspect and discuss condition of construction to be selectively demolished.
 - 2. Review structural load limitations of existing structure.
 - 3. Review and finalize electrical demolition schedule and verify availability of materials, demolition personnel, equipment, and facilities needed to make progress and avoid delays.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

4. Review requirements of work performed by other trades that rely on substrates exposed by selective demolition operations.
5. Review areas where existing construction is to remain and requires protection.

1.07 PROJECT CONDITIONS

- A. Owner will occupy portions of building immediately adjacent to electrical demolition area. Conduct electrical demolition so Owner's operations will not be disrupted.
- B. Conditions existing at time of inspection for bidding purpose will be maintained by Owner as far as practical.
- C. Hazardous Materials: It is not expected that hazardous materials will be encountered in the Work.
 1. If materials suspected of containing hazardous materials are encountered, do not disturb; immediately notify Owner's Representative. Owner's Representative will have hazardous materials removed under a separate contract.
- D. Storage or sale of removed items or materials on-site is not permitted.
- E. Utility Service: Maintain existing utilities indicated to remain in service and protect them against damage during demolition operations.
 1. Maintain fire-protection facilities in service during demolition operations.

1.08 WARRANTY

- A. Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during demolition, by methods and with materials so as not to void existing warranties.

PART 2 PRODUCTS (Not Used)

PART 3 EXECUTION

3.01 EXAMINATION

- A. Survey existing conditions and correlate with requirements indicated to determine extent of demolition required.
- B. Inventory and record the condition of items to be removed and reinstalled and items to be removed and salvaged.
- C. When unanticipated electrical elements that conflict with intended function or design are encountered, investigate and measure the nature and extent of conflict. Promptly submit a written report to Owner's Representative. Contractor is responsible for all items, demolition and reinstallation whether shown on the drawings or not shown on the drawings.

3.02 ELECTRICAL SYSTEMS

- A. Existing Electrical Systems: Maintain electrical systems indicated to remain and protect them against damage during selective demolition operations.

3.03 ELECTRICAL DEMOLITION, GENERAL

- A. Removed and Reinstalled Items:
 1. Clean and repair items to functional condition adequate for intended reuse. Paint equipment to match new equipment.
 2. Pack or crate items after cleaning and repairing. Identify contents of containers.
 3. Protect items from damage during transport and storage.
 4. Reinstall items in locations indicated. Comply with installation requirements for new materials and equipment. Provide connections, supports, and miscellaneous materials necessary to make item functional for use indicated.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.04 DISPOSAL OF DEMOLISHED MATERIALS

- A. General: Except for items or materials indicated to be reused, salvaged, reinstalled, or otherwise indicated to remain Owner's property, remove demolished materials from Project site and legally dispose of them in an EPA-approved landfill.
 - 1. Do not allow demolished materials to accumulate on-site.
 - 2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
- B. Burning: Do not burn demolished materials.
- C. Disposal: Transport demolished materials off Owner's property and legally dispose of them.

3.05 CLEANING

- A. Clean adjacent structures and improvements of dust, dirt, and debris caused by electrical demolition operations. Return adjacent areas to condition existing before electrical demolition operations began.

END OF SECTION 260101

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

This page intentionally left blank

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 260519
LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
1. Copper building wire rated 600 V or less.
 2. Metal-clad cable, Type MC, rated 600 V or less.
 3. Armored cable, Type AC, rated 600 V or less.
 4. Fire-alarm wire and cable.
 5. Connectors, splices, and terminations rated 600 V and less.

1.03 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.

1.04 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Member company of NETA.
1. Testing Agency's Field Supervisor: Certified by NETA to supervise on-site testing.

PART 2 PRODUCTS

2.01 CONDUCTORS AND CABLES

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Triangle.
 2. Rome.
 3. Southwire Company.
 4. Cablec.

2.02 COPPER BUILDING WIRE

- A. Description: Flexible, insulated and uninsulated, drawn copper current-carrying conductor with an overall insulation layer or jacket, or both, rated 600 V or less.
- B. Standards:
1. Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and use.
- C. Conductor Insulation:
1. Type THHN and Type THWN-2: Comply with UL 83.
 2. Type XHHW-2: Comply with UL 44.

2.03 METAL-CLAD CABLE, TYPE MC

- A. Description: A factory assembly of one or more current-carrying insulated conductors in an overall metallic sheath.
- B. Standards:
1. Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and use.
 2. Comply with UL 1569.
- C. Circuits:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Single circuit.
 2. Power-Limited Fire-Alarm Circuits: Comply with UL 1424.
- D. Conductors: Copper, complying with ASTM B3 for bare annealed copper and with ASTM B8 for stranded conductors.
- E. Ground Conductor: Insulated.
- F. Conductor Insulation:
1. Type TFN/THHN/THWN-2: Comply with UL 83.
 2. Type XHHW-2: Comply with UL 44.
- G. Armor: Steel, interlocked.

2.04 ARMORED CABLE, TYPE AC

- A. Description: A factory assembly of insulated current-carrying conductors with or without an equipment grounding conductor in an overall metallic sheath.
- B. Standards:
1. Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and use.
 2. Comply with UL 4.
- C. Circuits:
1. Single circuit.
 2. Power-Limited Fire-Alarm Circuits: Comply with UL 1424.
- D. Conductors: Copper, complying with ASTM B3 for bare annealed copper and with ASTM B8 for stranded conductors.
- E. Ground Conductor: Insulated.
- F. Conductor Insulation: Type THHN/THWN-2. Comply with UL 83.
- G. Armor: Aluminum, interlocked.

2.05 FIRE-ALARM WIRE AND CABLE

- A. General Wire and Cable Requirements: NRTL listed and labeled as complying with NFPA 70, Article 760.
- B. Signaling Line Circuits: Twisted, shielded pair, size as recommended by system manufacturer.
- C. Non-Power-Limited Circuits: Solid-copper conductors with 600-V rated, 75 deg C, color-coded insulation, and complying with requirements in UL 2196 for a two-hour rating.
1. Low-Voltage Circuits: No. 16 AWG, minimum, in pathway.
 2. Line-Voltage Circuits: No. 12 AWG, minimum, in pathway.
 3. Multiconductor Armored Cable: NFPA 70, Type MC, copper conductors, Type TFN/THHN conductor insulation, copper drain wire, copper armor with outer jacket with red identifier stripe, NRTL listed for fire-alarm and cable tray installation, plenum rated.

2.06 CONNECTORS AND SPLICES

- A. Description: Factory-fabricated connectors, splices, and lugs of size, ampacity rating, material, type, and class for application and service indicated; listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and use.
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Burndy, Thomas & Betts.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. IlSCO.
3. GB Electric
- C. Description: Factory-fabricated connectors and splices of size, ampacity rating, material, type, and class for application and service indicated.
 1. Aboveground Circuits (No. 10 AWG and smaller):
 - a. Connectors: Solderless, screw-on, reusable pressure cable type, rated 600 V, 90° C, with integral insulation, approved for copper conductors.
 - b. The integral insulator shall have a skirt to completely cover the stripped wires.
 - c. The number, size, and combination of conductors, as listed on the manufacturer's packaging, shall be strictly followed.
 2. Aboveground Circuits (No. 8 AWG and larger):
 - a. Cable termination lugs shall be made of high conductivity and corrosion-resistant material, electro-tin plated, listed for use with copper conductors only, rated for 600 V. Lugs shall be color coded by size.
 - b. Cable termination lugs shall be indent type, long barrel with chamfered entry, 2 – hole, compression type for 250 kcmil and above, 1 – hole for less than 250 kcmil.

PART 3 EXECUTION

3.01 CONDUCTOR MATERIAL APPLICATIONS

- A. Feeders: Copper; solid for No. 12 AWG and smaller; stranded for No. 10 AWG and larger.
- B. Branch Circuits: Copper. Solid for No. 12 AWG and smaller; stranded for No. 10 AWG and larger.
- C. Power-Limited Fire Alarm and Control: Solid for No. 12 AWG and smaller.

3.02 CONDUCTOR INSULATION AND MULTICONDUCTOR CABLE APPLICATIONS AND WIRING METHODS

- A. Service Entrance: Type XHHW-2, single conductors in raceway.
- B. Exposed Feeders: Type THHN/THWN-2, single conductors in raceway.
- C. Feeders Concealed in Ceilings, Walls, Partitions, and Crawlspace: Type THHN/THWN-2, single conductors in raceway.
- D. Feeders Concealed in Concrete, below Slabs-on-Grade, and Underground: Type XHHW-2, single conductors in raceway.
- E. Exposed Branch Circuits, Including in Crawlspace: Type THHN/THWN-2, single conductors in raceway.
- F. Branch Circuits Concealed in Ceilings, Walls, and Partitions: Type THHN/THWN-2, single conductors in raceway, AC or MC cable from junction box above accessible ceiling to devices. Homeruns shall be single conductors in raceway.
- G. Branch Circuits Concealed in Concrete, below Slabs-on-Grade, and Underground: Type THHN/THWN-2, single conductors in raceway.
- H. Cord Drops and Portable Appliance Connections: Type SO, hard service cord with stainless-steel, wire-mesh, strain relief device at terminations to suit application.

3.03 INSTALLATION OF CONDUCTORS AND CABLES

- A. Conceal cables in finished walls, ceilings, and floors unless otherwise indicated.
- B. Complete raceway installation between conductor and cable termination points according to Section 260533 "Raceways and Boxes for Electrical Systems" prior to pulling conductors and cables.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Use manufacturer-approved pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation. Do not exceed manufacturer's recommended maximum pulling tensions and sidewall pressure values.
- D. Use pulling means, including fish tape, cable, rope, and basket-weave wire/cable grips, that will not damage cables or raceway.
- E. Install exposed cables parallel and perpendicular to surfaces of exposed structural members, and follow surface contours where possible.
- F. Support cables according to Section 260529 "Hangers and Supports for Electrical Systems."

3.04 INSTALLATION OF FIRE-ALARM WIRING

- A. Comply with NECA 1 and NFPA 72.
- B. Wiring Method: Install wiring in metal pathway according to Section 270528.29 "Hangers and Supports for Communications Systems."
 - 1. Install plenum cable in environmental airspaces, including plenum ceilings.
 - 2. Fire-alarm circuits and equipment control wiring associated with fire-alarm system shall be installed in a dedicated pathway system. This system shall not be used for any other wire or cable.
- C. Wiring within Enclosures: Separate power-limited and non-power-limited conductors as recommended by manufacturer. Install conductors parallel with or at right angles to sides and back of the enclosure. Bundle, lace, and train conductors to terminal points with no excess. Connect conductors that are terminated, spliced, or interrupted in any enclosure associated with fire-alarm system to terminal blocks. Mark each terminal according to system's wiring diagrams. Make all connections with approved crimp-on terminal spade lugs, pressure-type terminal blocks, or plug connectors.
- D. Cable Taps: Use numbered terminal strips in junction, pull, and outlet boxes; cabinets; or equipment enclosures where circuit connections are made.
- E. Color-Coding: Color-code fire-alarm conductors differently from the normal building power wiring. Use one color-code for alarm circuit wiring and another for supervisory circuits. Color-code audible alarm-indicating circuits differently from alarm-initiating circuits. Use different colors for visible alarm-indicating devices. Paint fire-alarm system junction boxes and covers red.

3.05 CONNECTIONS

- A. Tighten electrical connectors and terminals according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A-486B.
- B. Make splices, terminations, and taps that are compatible with conductor material and that possess equivalent or better mechanical strength and insulation ratings than unspliced conductors.
- C. Wiring at Outlets: Install conductor at each outlet, with at least 6 inches of slack.

3.06 IDENTIFICATION

- A. Identify and color-code conductors and cables according to Section 260553 "Identification for Electrical Systems."
- B. Identify each spare conductor at each end with identity number and location of other end of conductor, and identify as spare conductor.

3.07 SLEEVE AND SLEEVE-SEAL INSTALLATION FOR ELECTRICAL PENETRATIONS

- A. Install sleeves and sleeve seals at penetrations of exterior floor and wall assemblies. Comply with requirements in Section 260544 "Sleeves and Sleeve Seals for Electrical Raceways and Cabling."

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.08 FIRESTOPPING

- A. Apply firestopping to electrical penetrations of fire-rated floor and wall assemblies to restore original fire-resistance rating of assembly.

3.09 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
 - 1. After installing conductors and cables and before electrical circuitry has been energized, test service entrance and feeder conductors for compliance with requirements.
 - 2. Perform each of the following visual and electrical tests:
 - a. Inspect exposed sections of conductor and cable for physical damage and correct connection according to the single-line diagram.
 - b. Test bolted connections for high resistance using one of the following:
 - 1) A low-resistance ohmmeter.
 - 2) Calibrated torque wrench.
 - 3) Thermographic survey.
 - c. Inspect compression-applied connectors for correct cable match and indentation.
 - d. Inspect for correct identification.
 - e. Inspect cable jacket and condition.
 - f. Insulation-resistance test on each conductor for ground and adjacent conductors. Apply a potential of 500-V dc for 300-V rated cable and 1000-V dc for 600-V rated cable for a one-minute duration.
 - g. Continuity test on each conductor and cable.
 - h. Uniform resistance of parallel conductors.
- B. Cables will be considered defective if they do not pass tests and inspections.
- C. Prepare test and inspection reports to record the following:
 - 1. Procedures used.
 - 2. Results that comply with requirements.
 - 3. Results that do not comply with requirements, and corrective action taken to achieve compliance with requirements.

END OF SECTION 260519

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

This page intentionally left blank

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 260526
GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section includes grounding and bonding systems and equipment.

1.03 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.

1.04 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Certified by NETA.

PART 2 PRODUCTS

2.01 SYSTEM DESCRIPTION

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with UL 467 for grounding and bonding materials and equipment.

2.02 CONDUCTORS

- A. Insulated Conductors: Copper wire or cable insulated for 600 V unless otherwise required by applicable Code or authorities having jurisdiction.
- B. Bare Copper Conductors:
 - 1. Solid Conductors: ASTM B3.
 - 2. Stranded Conductors: ASTM B8.
 - 3. Tinned Conductors: ASTM B33.
 - 4. Bonding Cable: 28 kcmil, 14 strands of No. 17 AWG conductor, 1/4 inch in diameter.
 - 5. Bonding Conductor: No. 4 or No. 6 AWG, stranded conductor.
 - 6. Bonding Jumper: Copper tape, braided conductors terminated with copper ferrules; 1-5/8 inches wide and 1/16 inch thick.
 - 7. Tinned Bonding Jumper: Tinned-copper tape, braided conductors terminated with copper ferrules; 1-5/8 inches wide and 1/16 inch thick.
- C. Grounding Bus: Predrilled rectangular bars of annealed copper, 1/4 by 4 inches in cross section, with 9/32-inch holes spaced 1-1/8 inches apart. Stand-off insulators for mounting shall comply with UL 891 for use in switchboards, 600 V and shall be Lexan or PVC, impulse tested at 5000 V.

2.03 CONNECTORS

- A. Listed and labeled by an NRTL acceptable to authorities having jurisdiction for applications in which used and for specific types, sizes, and combinations of conductors and other items connected.
- B. Welded Connectors: Exothermic-welding kits of types recommended by kit manufacturer for materials being joined and installation conditions.
- C. Bus-Bar Connectors: Mechanical type, cast silicon bronze, solderless compression-type wire terminals, and long-barrel, two-bolt connection to ground bus bar.
- D. Beam Clamps: Mechanical type, terminal, ground wire access from four directions, with dual, tin-plated or silicon bronze bolts.
- E. Cable-to-Cable Connectors: Compression type, copper or copper alloy.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- F. Conduit Hubs: Mechanical type, terminal with threaded hub.

PART 3 EXECUTION

3.01 APPLICATIONS

- A. Conductors: Install solid conductor for No. 12 AWG and smaller, and stranded conductors for No. 10 AWG and larger unless otherwise indicated.
- B. Grounding Conductors: Green-colored insulation with continuous yellow stripe.
- C. Conductor Terminations and Connections:
 - 1. Pipe and Equipment Grounding Conductor Terminations: Bolted connectors.
 - 2. Connections to Structural Steel: Welded connectors.

3.02 GROUNDING AT THE SERVICE

- A. Equipment grounding conductors and grounding electrode conductors shall be connected to the ground bus. Install a main bonding jumper between the neutral and ground buses.

3.03 EQUIPMENT GROUNDING

- A. Install insulated equipment grounding conductors with all feeders and branch circuits. Conduit shall not be used as the grounding conductor.
- B. Air-Duct Equipment Circuits: Install insulated equipment grounding conductor to duct-mounted electrical devices operating at 120 V and more, including air cleaners, heaters, dampers, humidifiers, and other duct electrical equipment. Bond conductor to each unit and to air duct and connected metallic piping.
- C. Water Heater, Heat-Tracing, and Antifrost Heating Cables: Install a separate insulated equipment grounding conductor to each electric water heater and heat-tracing cable. Bond conductor to heater units, piping, connected equipment, and components.

3.04 INSTALLATION

- A. Grounding Conductors: Route along shortest and straightest paths possible unless otherwise indicated or required by Code. Avoid obstructing access or placing conductors where they may be subjected to strain, impact, or damage.
- B. Bonding Straps and Jumpers: Install in locations accessible for inspection and maintenance except where routed through short lengths of conduit.
 - 1. Bonding to Structure: Bond straps directly to basic structure, taking care not to penetrate any adjacent parts.
 - 2. Bonding to Equipment Mounted on Vibration Isolation Hangers and Supports: Install bonding so vibration is not transmitted to rigidly mounted equipment.
 - 3. Use exothermic-welded connectors for outdoor locations; if a disconnect-type connection is required, use a bolted clamp.
- C. Bonding Interior Metal Ducts: Bond metal air ducts to equipment grounding conductors of associated fans, blowers, electric heaters, and air cleaners. Install tinned bonding jumper to bond across flexible duct connections to achieve continuity.
- D. Connections: Make connections so possibility of galvanic action or electrolysis is minimized. Select connectors, connection hardware, conductors, and connection methods so metals in direct contact are galvanically compatible.
 - 1. Use electroplated or hot-tin-coated materials to ensure high conductivity and to make contact points closer in order of galvanic series.
 - 2. Make connections with clean, bare metal at points of contact.
 - 3. Make aluminum-to-steel connections with stainless-steel separators and mechanical clamps.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

4. Make aluminum-to-galvanized-steel connections with tin-plated copper jumpers and mechanical clamps.
5. Coat and seal connections having dissimilar metals with inert material to prevent future penetration of moisture to contact surfaces.

3.05 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Tests and Inspections:
 1. After installing grounding system but before permanent electrical circuits have been energized, test for compliance with requirements.
 2. Inspect physical and mechanical condition. Verify tightness of accessible, bolted, electrical connections with a calibrated torque wrench according to manufacturer's written instructions.
 3. Test completed grounding system at each location where a maximum ground-resistance level is specified, at service disconnect enclosure grounding terminal. Make tests at ground rods before any conductors are connected.
 - a. Measure ground resistance no fewer than two full days after last trace of precipitation and without soil being moistened by any means other than natural drainage or seepage and without chemical treatment or other artificial means of reducing natural ground resistance.
 - b. Perform tests by fall-of-potential method according to IEEE 81.
 4. Prepare dimensioned Drawings locating each ground rod and ground-rod assembly, and other grounding electrodes. Identify each by letter in alphabetical order, and key to the record of tests and observations. Include the number of rods driven and their depth at each location, and include observations of weather and other phenomena that may affect test results. Describe measures taken to improve test results.
- C. Grounding system will be considered defective if it does not pass tests and inspections.
- D. Prepare test and inspection reports, submit to Engineer.
- E. Report measured ground resistances that exceed the following values:
 1. Power and Lighting Equipment or System with Capacity of 500 kVA and less: 10 ohms.
 2. Power and Lighting Equipment or System with Capacity of 500 to 1000 kVA: 5 ohms.
 3. Power and Lighting Equipment or System with Capacity More Than 1000 kVA: 3 ohms.
 4. Power Distribution Units or Panelboards Serving Electronic Equipment: 1 ohm(s).
 5. Substations and Pad-Mounted Equipment: 5 ohms.
- F. Excessive Ground Resistance: If resistance to ground exceeds specified values, notify Architect promptly and include recommendations to reduce ground resistance.

END OF SECTION 260526

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 260529
HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. This Section includes the following:
 - 1. Hangers and supports for electrical equipment and systems.
 - 2. Construction requirements for concrete bases.

1.03 QUALITY ASSURANCE

- A. Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M.
- B. All products shall be UL Labeled for their intended use.
- C. Comply with NFPA 70.

1.04 COORDINATION

- A. Coordinate size and location of concrete bases. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified in Division 03.
- B. Coordinate installation of roof curbs, equipment supports, and roof penetrations. These items are specified in Division 07 Sections.

PART 2 PRODUCTS

2.01 SUPPORT, ANCHORAGE, AND ATTACHMENT COMPONENTS

- A. Steel Slotted Support Systems: Preformed steel channels and angles with minimum 13/32-inch-diameter holes at a maximum of 8 inches o.c. in at least one surface.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Allied Tube & Conduit.
 - b. Cooper B-Line, Inc.; a division of Cooper Industries.
 - c. ERICO International Corporation.
 - d. GS Metals Corp.
 - e. Thomas & Betts Corporation.
 - f. Unistrut; Tyco International, Ltd.
 - 2. Metallic Coatings: Hot-dip galvanized after fabrication and applied according to MFMA-4.
 - 3. Nonmetallic Coatings: Manufacturer's standard PVC, polyurethane, or polyester coating applied according to MFMA-4.
 - 4. Painted Coatings: Manufacturer's standard painted coating applied according to MFMA-4.
 - 5. Channel Dimensions: Selected for applicable load criteria.
- B. Nonmetallic Slotted Support Systems: Structural-grade, factory-formed, glass-fiber-resin channels and angles with minimum 13/32-inch-diameter holes at a maximum of 8 inches o.c., in at least one surface.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Allied Tube & Conduit.
 - b. Cooper B-Line, Inc.; a division of Cooper Industries.
 - 2. Fittings and Accessories: Products of channel and angle manufacturer and designed for use with those items.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3. Fitting and Accessory Materials: Same as channels and angles, except metal items may be stainless steel.
4. Rated Strength: Selected to suit applicable load criteria.
- C. Raceway and Cable Supports: As described in NECA 1 and NECA 101.
- D. Conduit and Cable Support Devices: Steel and malleable-iron hangers, clamps, and associated fittings, designed for types and sizes of raceway or cable to be supported.
- E. Support for Conductors in Vertical Conduit: Factory-fabricated assembly consisting of threaded body and insulating wedging plug or plugs for nonarmored electrical conductors or cables in riser conduits. Plugs shall have number, size, and shape of conductor gripping pieces as required to suit individual conductors or cables supported. Body shall be made of malleable iron.
- F. Structural Steel for Fabricated Supports and Restraints: ASTM A36/A36M steel plates, shapes, and bars; black and galvanized.
- G. Mounting, Anchoring, and Attachment Components: Items for fastening electrical items or their supports to building surfaces include the following:
 1. Powder-Actuated Fasteners: Threaded-steel stud, for use in hardened portland cement concrete, steel, or wood, with tension, shear, and pullout capacities appropriate for supported loads and building materials where used.
 - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1) Hilti Inc.
 - 2) ITW Ramset/Red Head; a division of Illinois Tool Works, Inc.
 - 3) MKT Fastening, LLC.
 - 4) Simpson Strong-Tie Co., Inc.; Masterset Fastening Systems Unit.
 2. Mechanical-Expansion Anchors: Insert-wedge-type, stainless steel, for use in hardened portland cement concrete, with tension, shear, and pullout capacities appropriate for supported loads and building materials where used.
 - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1) Cooper B-Line, Inc.; a division of Cooper Industries.
 - 2) Empire Tool and Manufacturing Co., Inc.
 - 3) Hilti Inc.
 - 4) ITW Ramset/Red Head; a division of Illinois Tool Works, Inc.
 - 5) MKT Fastening, LLC.
 3. Concrete Inserts: Steel or malleable-iron, slotted support system units are similar to MSS Type 18 units and comply with MFMA-4 or MSS SP-58.
 4. Clamps for Attachment to Steel Structural Elements: MSS SP-58 units are suitable for attached structural element.
 5. Through Bolts: Structural type, hex head, and high strength. Comply with ASTM F3125/F3125M,
 6. Toggle Bolts: All-steel springhead type.
 7. Hanger Rods: Threaded steel.

2.02 FABRICATED METAL EQUIPMENT SUPPORT ASSEMBLIES

- A. Description: Welded or bolted structural-steel shapes, shop or field fabricated to fit dimensions of supported equipment.
- B. Materials: Comply with requirements in Section 055000 "Metal Fabrications" for steel shapes and plates.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

PART 3 EXECUTION

3.01 APPLICATION

- A. Comply with the following standards for application and installation requirements of hangers and supports, except where requirements on Drawings or in this Section are stricter:
 - 1. NECA 1.
 - 2. NECA 101
 - 3. NECA 102.
 - 4. NECA 105.
 - 5. NECA 111.
- B. Comply with requirements in Section 078413 "Penetration Firestopping" for firestopping materials and installation for penetrations through fire-rated walls, ceilings, and assemblies.
- C. Comply with requirements for raceways and boxes specified in Section 260533 "Raceways and Boxes for Electrical Systems."
- D. Maximum Support Spacing and Minimum Hanger Rod Size for Raceways: Space supports for EMT, IMC, and RMC as required by NFPA 70. Minimum rod size shall be 1/4 inch in diameter.
- E. Multiple Raceways or Cables: Install trapeze-type supports fabricated with steel support system, sized so capacity can be increased by at least 25 percent in future without exceeding specified design load limits.
 - 1. Secure raceways and cables to these supports with single-bolt conduit clamps or single-bolt conduit clamps using spring friction action for retention in support channel.
- F. Spring-steel clamps designed for supporting single conduits without bolts may be used for 1-1/2-inch and smaller raceways serving branch circuits and communication systems above suspended ceilings, and for fastening raceways to trapeze supports.

3.02 SUPPORT INSTALLATION

- A. Comply with NECA 1 and NECA 101 for installation requirements except as specified in this article.
- B. Raceway Support Methods: In addition to methods described in NECA 1, EMT, IMC and RMC may be supported by openings through structure members, according to NFPA 70.
- C. Strength of Support Assemblies: Where not indicated, select sizes of components so strength will be adequate to carry present and future static loads within specified loading limits. Minimum static design load used for strength determination shall be weight of supported components plus 200 lb.
- D. Mounting and Anchorage of Surface-Mounted Equipment and Components: Anchor and fasten electrical items and their supports to building structural elements by the following methods unless otherwise indicated by code:
 - 1. To Wood: Fasten with lag screws or through bolts.
 - 2. To New Concrete: Bolt to concrete inserts.
 - 3. To Masonry: Approved toggle-type bolts on hollow masonry units and expansion anchor fasteners on solid masonry units.
 - 4. To Existing Concrete: Expansion anchor fasteners.
 - 5. Instead of expansion anchors, powder-actuated driven threaded studs provided with lock washers and nuts may be used in existing standard-weight concrete 4 inches thick or greater. Do not use for anchorage to lightweight-aggregate concrete or for slabs less than 4 inches thick.
 - 6. To Steel: Beam clamps (MSS SP-58, Type 19, 21, 23, 25, or 27), complying with MSS SP-69.
 - 7. To Light Steel: Sheet metal screws.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- 8. Items Mounted on Hollow Walls and Nonstructural Building Surfaces: Mount cabinets, panelboards, disconnect switches, control enclosures, pull and junction boxes, transformers, and other devices on slotted-channel racks attached to substrate.
- E. Drill holes for expansion anchors in concrete at locations and to depths that avoid the need for reinforcing bars.

3.03 INSTALLATION OF FABRICATED METAL SUPPORTS

- A. Comply with installation requirements in Section 055000 "Metal Fabrications" for site-fabricated metal supports.
- B. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor electrical materials and equipment.
- C. Field Welding: Comply with AWS D1.1/D1.1M.

3.04 CONCRETE BASES

- A. Construct concrete bases of dimensions indicated, but not less than 4 inches larger in both directions than supported unit, and so anchors will be a minimum of 10 bolt diameters from edge of the base.
- B. Use 3000-psi, 28-day compressive-strength concrete. Concrete materials, reinforcement, and placement requirements are specified in Section 033000 "Cast-in-Place Concrete."
- C. Anchor equipment to concrete base as follows:
 - 1. Place and secure anchorage devices. Use supported equipment manufacturer's setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
 - 2. Install anchor bolts to elevations required for proper attachment to supported equipment.
 - 3. Install anchor bolts according to anchor-bolt manufacturer's written instructions.

3.05 PAINTING

- A. Touchup: Clean field welds and abraded areas of shop paint. Paint exposed areas immediately after erecting hangers and supports. Use same materials as used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
 - 1. Apply paint by brush or spray to provide minimum dry film thickness of 2.0 mils.
- B. Touchup: Comply with requirements in Division 09 Painting Sections for cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint on miscellaneous metal.
- C. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas and apply galvanizing-repair paint to comply with ASTM A-780.

END OF SECTION 260529

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 260533
RACEWAYS AND BOXES FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
 - 1. Metal conduits and fittings.
 - 2. Metal wireways and auxiliary gutters.
 - 3. Boxes, enclosures, and cabinets.

1.03 DEFINITIONS

- A. GRC: Galvanized rigid steel conduit.
- B. IMC: Intermediate metal conduit.

1.04 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Conduit routing plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of items involved:
 - 1. Structural members in paths of conduit groups with common supports.
 - 2. HVAC and plumbing items and architectural features in paths of conduit groups with common supports.

1.05 QUALITY ASSURANCE

- A. All products shall be UL labeled for their intended use.
- B. Comply with NFPA 70.

PART 2 PRODUCTS

2.01 METAL CONDUITS AND FITTINGS

- A. Manufacturers: Subject to compliance with requirements, products of the following manufacturers are acceptable provided they have a smooth interior, are UL listed and labeled as defined in NFPA 70 for the intended location and application and are electro-galvanized steel (EMT) or hot dipped galvanized steel inside and out (GRC). Conduit and fittings shall be obtained from the same manufacturer:
 - 1. Triangle PWC
 - 2. Wheatland
 - 3. Allied Steel Conduits
 - 4. LFMC only: AFC, Electri-FlexCo, O.Z. Gedney
- B. Metal Conduit:
 - 1. Listing and Labeling: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
 - 2. GRC: Comply with ANSI C80.1 and UL 6.
 - 3. IMC: Comply with ANSI C80.6 and UL 1242.
 - 4. EMT: Comply with ANSI C80.3 and UL 797.
 - 5. FMC: Comply with UL 1; zinc-coated steel.
 - 6. LFMC: Flexible steel conduit with PVC jacket and complying with UL 360.
- C. Metal Fittings:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Comply with NEMA FB 1 and UL 514B.
 2. Listing and Labeling: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
 3. Fittings, General: Listed and labeled for type of conduit, location, and use.
 4. Fittings for EMT:
 - a. Material: Steel.
 - b. Type: Setscrew-indoors; Compression-exterior.
 5. Expansion Fittings: PVC or steel to match conduit type, complying with UL 651, rated for environmental conditions where installed, and including flexible external bonding jumper.
- D. Joint Compound for IMC or GRC: Approved, as defined in NFPA 70, by authorities having jurisdiction for use in conduit assemblies, and compounded for use to lubricate and protect threaded conduit joints from corrosion and to enhance their conductivity.

2.02 METAL WIREWAYS AND AUXILIARY GUTTERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Cooper B-Line, Inc.
 2. Hoffman; a Pentair company.
 3. Square D; a brand of Schneider Electric.
- B. Description: Sheet metal, complying with UL 870 and NEMA 250, Type 1 unless otherwise indicated, and sized according to NFPA 70.
1. Metal wireways installed outdoors shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- C. Fittings and Accessories: Include covers, couplings, offsets, elbows, expansion joints, adapters, hold-down straps, end caps, and other fittings to match and mate with wireways as required for complete system.
- D. Wireway Covers: Screw-cover type unless otherwise indicated.
- E. Finish: Manufacturer's standard enamel finish.

2.03 BOXES, ENCLOSURES, AND CABINETS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Adalet.
 2. Cooper Crouse-Hinds.
 3. EGS/Appleton Electric.
 4. FSR Inc.
 5. Hoffman; a Pentair company.
 6. Hubbell Incorporated; Killark Division.
 7. O-Z/Gedney; a brand of EGS Electrical Group.
 8. RACO; a Hubbell Company.
 9. Spring City Electrical Manufacturing Company.
 10. Thomas & Betts Corporation.
 11. Wiremold / Legrand.
- B. General Requirements for Boxes, Enclosures, and Cabinets: Boxes, enclosures, and cabinets installed in wet locations shall be listed for use in wet locations.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Sheet Metal Outlet and Device Boxes: Comply with NEMA OS 1 and UL 514A.
- D. Cast-Metal Outlet and Device Boxes: Comply with NEMA FB 1, ferrous alloy, Type FD, with gasketed cover.
- E. Metal Floor Boxes:
 - 1. Material: Sheet metal, 11 gauge.
 - 2. Type: Flush. Cover with 0.25" square aluminum flange rated for carpet/tile installations. Provide pour pan accessory for on grade installations.
 - 3. Shape: Rectangular.
 - 4. Listing and Labeling: Metal floor boxes shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- F. Luminaire Outlet Boxes: Nonadjustable, designed for attachment of luminaire weighing 50 lb. Outlet boxes designed for attachment of luminaires weighing more than 50 lb shall be listed and marked for the maximum allowable weight.
- G. Small Sheet Metal Pull and Junction Boxes: NEMA OS 1.
- H. Cast-Metal Access, Pull, and Junction Boxes: Comply with NEMA FB 1 and UL 1773, galvanized, cast iron with gasketed cover.
- I. Box extensions used to accommodate new building finishes shall be of same material as recessed box.
- J. Hinged-Cover Enclosures: Comply with UL 50 and NEMA 250, Type 1 with continuous-hinge cover with flush latch unless otherwise indicated.
 - 1. Metal Enclosures: Steel, finished inside and out with manufacturer's standard enamel.
 - 2. Nonmetallic Enclosures: Plastic.
 - 3. Interior Panels: Steel; all sides finished with manufacturer's standard enamel.
- K. Cabinets:
 - 1. NEMA 250, Type 1 galvanized-steel box with removable interior panel and removable front, finished inside and out with manufacturer's standard enamel.
 - 2. Hinged door in front cover with flush latch and concealed hinge.
 - 3. Key latch to match panelboards.
 - 4. Metal barriers to separate wiring of different systems and voltage.
 - 5. Accessory feet where required for freestanding equipment.
 - 6. Nonmetallic cabinets shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

PART 3 EXECUTION

3.01 RACEWAY APPLICATION

- A. Outdoors: Apply raceway products as specified below unless otherwise indicated:
 - 1. Exposed Conduit: GRC, IMC.
 - 2. Concealed Conduit, Aboveground: IMC, EMT.
 - 3. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): LFMC.
 - 4. Boxes and Enclosures, Aboveground: NEMA 250, Type 3R.
- B. Indoors: Apply raceway products as specified below unless otherwise indicated:
 - 1. Exposed, Not Subject to Physical Damage: EMT.
 - 2. Exposed, Not Subject to Severe Physical Damage: EMT.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3. Exposed and Subject to Severe Physical Damage: GRC.
 4. Concealed in Ceilings and Interior Walls and Partitions: EMT.
 5. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): FMC, except use LFMC in damp or wet locations.
 6. Feeders over 600 V: GRC.
 7. Damp or Wet Locations: GRC or IMC.
 8. Tunnels: GRC.
 9. Boxes and Enclosures: NEMA 250, Type 1, except use NEMA 250, Type 4 stainless steel in institutional and commercial kitchens and damp or wet locations.
- C. Minimum Raceway Size: 3/4-inch trade size.
- D. Raceway Fittings: Compatible with raceways and suitable for use and location.
1. Rigid and Intermediate Steel Conduit: Use threaded rigid steel conduit fittings unless otherwise indicated. Comply with NEMA FB 2.10.
 2. PVC Externally Coated, Rigid Steel Conduits: Use only fittings listed for use with this type of conduit. Patch and seal all joints, nicks, and scrapes in PVC coating after installing conduits and fittings. Use sealant recommended by fitting manufacturer and apply in thickness and number of coats recommended by manufacturer.
 3. EMT: Use setscrew (indoors) or compression (outdoors), steel fittings. Comply with NEMA FB 2.10.
 4. Flexible Conduit: Use only fittings listed for use with flexible conduit. Comply with NEMA FB 2.20.
- E. Install nonferrous conduit or tubing for circuits operating above 60 Hz. Where aluminum raceways are installed for such circuits and pass through concrete, install in nonmetallic sleeve.
- F. Do not install aluminum conduits, boxes, or fittings in contact with concrete or earth.
- G. Install surface raceways only where indicated on Drawings.

3.02 INSTALLATION

- A. Comply with requirements in Section 260529 "Hangers and Supports for Electrical Systems" for hangers and supports.
- B. Comply with NECA 1 and NECA 101 for installation requirements except where requirements on Drawings or in this article are stricter. Comply with NECA 102 for aluminum conduits. Comply with NFPA 70 limitations for types of raceways allowed in specific occupancies and number of floors.
- C. Do not fasten conduits onto the bottom side of a metal deck roof.
- D. Keep raceways at least 6 inches away from parallel runs of flues and steam or hot-water pipes. Install horizontal raceway runs above water and steam piping.
- E. Complete raceway installation before starting conductor installation.
- F. Arrange stub-ups so curved portions of bends are not visible above finished slab.
- G. Install no more than the equivalent of three 90-degree bends in any conduit run except for control wiring conduits, for which fewer bends are allowed. Support within 12 inches of changes in direction.
- H. Make bends in raceway using large-radius preformed ells. Field bending shall be according to NFPA 70 minimum radii requirements. Use only equipment specifically designed for material and size involved.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- I. Conceal conduit within finished walls, ceilings, and floors unless otherwise indicated. Install conduits parallel or perpendicular to building lines.
- J. Support conduit within 12 inches of enclosures to which attached.
- K. Stub-Ups to Above Recessed Ceilings:
 - 1. Use EMT for raceways.
 - 2. Use a conduit bushing or insulated fitting to terminate stub-ups not terminated in hubs or in an enclosure.
- L. Threaded Conduit Joints, Exposed to Wet, Damp, Corrosive, or Outdoor Conditions: Apply listed compound to threads of raceway and fittings before making up joints. Follow compound manufacturer's written instructions.
- M. Raceway Terminations at Locations Subject to Moisture or Vibration: Use insulating bushings to protect conductors including conductors smaller than No. 4 AWG.
- N. Terminate threaded conduits into threaded hubs or with locknuts on inside and outside of boxes or cabinets. Install bushings on conduits up to 1-1/4-inch trade size and insulated throat metal bushings on 1-1/2-inch trade size and larger conduits terminated with locknuts. Install insulated throat metal grounding bushings on service conduits.
- O. Install raceways square to the enclosure and terminate at enclosures with locknuts. Install locknuts hand tight plus 1/4 turn more.
- P. Do not rely on locknuts to penetrate nonconductive coatings on enclosures. Remove coatings in the locknut area prior to assembling conduit to enclosure to assure a continuous ground path.
- Q. Cut conduit perpendicular to the length. For conduits 2-inch trade size and larger, use roll cutter or a guide to make cut straight and perpendicular to the length.
- R. Install pull wires in empty raceways. Use polypropylene or monofilament plastic line with not less than 200-lb tensile strength. Leave at least 12 inches of slack at each end of pull wire. Cap underground raceways designated as spare above grade alongside raceways in use.
- S. Install raceway sealing fittings at accessible locations according to NFPA 70 and fill them with listed sealing compound. For concealed raceways, install each fitting in a flush steel box with a blank cover plate having a finish similar to that of adjacent plates or surfaces. Install raceway sealing fittings according to NFPA 70.
- T. Install devices to seal raceway interiors at accessible locations. Locate seals so no fittings or boxes are between the seal and the following changes of environments. Seal the interior of all raceways at the following points:
 - 1. Where conduits pass from warm to cold locations, such as boundaries of refrigerated spaces.
 - 2. Where an underground service raceway enters a building or structure.
 - 3. Conduit extending from interior to exterior of building.
 - 4. Conduit extending into pressurized duct and equipment.
 - 5. Conduit extending into pressurized zones that are automatically controlled to maintain different pressure set points.
 - 6. Where otherwise required by NFPA 70.
- U. Comply with manufacturer's written instructions for solvent welding RNC and fittings.
- V. Expansion-Joint Fittings:
 - 1. Install in each run of aboveground RMC and EMT conduit that is located where environmental temperature change may exceed 100 deg F and that has straight-run length that exceeds 100 feet.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Install type and quantity of fittings that accommodate temperature change listed for each of the following locations:
 - a. Outdoor Locations Not Exposed to Direct Sunlight: 125 deg F temperature change.
 - b. Outdoor Locations Exposed to Direct Sunlight: 155 deg F temperature change.
 - c. Indoor Spaces Connected with Outdoors without Physical Separation: 125 deg F temperature change.
 - d. Attics: 135 deg F temperature change.
 3. Install fitting(s) that provide expansion and contraction for at least 0.000078 inch per foot of length of straight run per deg F of temperature change for metal conduits.
 4. Install expansion fittings at all locations where conduits cross building or structure expansion joints.
 5. Install each expansion-joint fitting with position, mounting, and piston setting selected according to manufacturer's written instructions for conditions at specific location at time of installation. Install conduit supports to allow for expansion movement.
- W. Flexible Conduit Connections: Comply with NEMA RV 3. Use a maximum of 72 inches of flexible conduit for recessed and semirecessed luminaires, equipment subject to vibration, noise transmission, or movement; and for transformers and motors.
1. Use LFMC in damp or wet locations subject to severe physical damage.
 2. Use LFMC in damp or wet locations not subject to severe physical damage.
- X. Mount boxes at heights indicated on Drawings. If mounting heights of boxes are not individually indicated, give priority to ADA requirements. Install boxes with height measured to center of box unless otherwise indicated.
- Y. Recessed Boxes in Masonry Walls: Saw-cut opening for box in center of cell of masonry block, and install box flush with surface of wall. Prepare block surfaces to provide a flat surface for a raintight connection between box and cover plate or supported equipment and box.
- Z. Horizontally separate boxes mounted on opposite sides of walls so they are not in the same vertical channel. Provide minimum 6-inch separation in non-fire-rated walls. Provide minimum 24-inch horizontal separation in acoustic-rated walls.
- AA. Locate boxes so that cover or plate will not span different building finishes.
- BB. Support boxes of three gangs or more from more than one side by spanning two framing members or mounting on brackets specifically designed for the purpose.
- CC. Fasten junction and pull boxes to or support from building structure. Do not support boxes by conduits.
- DD. Set metal floor boxes level and flush with finished floor surface.
- EE. Set nonmetallic floor boxes level. Trim after installation to fit flush with finished floor surface.

3.03 SLEEVE AND SLEEVE-SEAL INSTALLATION FOR ELECTRICAL PENETRATIONS

- A. Install sleeves and sleeve seals at penetrations of exterior floor and wall assemblies. Comply with requirements in Section 260544 "Sleeves and Sleeve Seals for Electrical Raceways and Cabling."

3.04 FIRESTOPPING

- A. Install firestopping at penetrations of fire-rated floor and wall assemblies.

3.05 PROTECTION

- A. Protect coatings, finishes, and cabinets from damage and deterioration.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Repair damage to galvanized finishes with zinc-rich paint recommended by manufacturer.
2. Repair damage to PVC coatings or paint finishes with matching touchup coating recommended by manufacturer.

END OF SECTION 260533

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

This page intentionally left blank

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 260544
SLEEVES AND SLEEVE SEALS FOR ELECTRICAL RACEWAYS AND CABLING

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
 - 1. Sleeves for raceway and cable penetration of non-fire-rated construction walls and floors.
 - 2. Sleeve-seal systems.
 - 3. Sleeve-seal fittings.
 - 4. Grout.
 - 5. Silicone sealants.

PART 2 PRODUCTS

2.01 SLEEVES

- A. Wall Sleeves:
 - 1. Steel Pipe Sleeves: ASTM A53/A53M, Type E, Grade B, Schedule 40, zinc coated, plain ends.
- B. Sleeves for Conduits Penetrating Non-Fire-Rated Gypsum Board Assemblies: Galvanized-steel sheet; 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint, with tabs for screw-fastening the sleeve to the board.
- C. Sleeves for Rectangular Openings:
 - 1. Material: Galvanized sheet steel.
 - 2. Minimum Metal Thickness:
 - a. For sleeve cross-section rectangle perimeter less than 50 inches and with no side larger than 16 inches, thickness shall be 0.052 inch.
 - b. For sleeve cross-section rectangle perimeter 50 inches or more and one or more sides larger than 16 inches, thickness shall be 0.138 inch.

2.02 SLEEVE-SEAL SYSTEMS

- A. Description: Modular sealing device, designed for field assembly, to fill annular space between sleeve and raceway or cable.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - a. Pipeline Seal & Insulator, Inc. (Link Seal).
 - 2. Sealing Elements: EPDM rubber interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
 - 3. Pressure Plates: Carbon steel.
 - 4. Connecting Bolts and Nuts: Carbon steel, with corrosion-resistant coating of length required to secure pressure plates to sealing elements.

2.03 SLEEVE-SEAL FITTINGS

- A. Description: Manufactured plastic, sleeve-type, waterstop assembly made for embedding in concrete slab or wall. Unit shall have plastic or rubber waterstop collar with center opening to match piping OD.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - a. Pipeline Seal & Insulator, Inc. (Link Seal).

2.04 GROUT

- A. Description: Nonshrink; recommended for interior and exterior sealing openings in non-fire-rated walls or floors.
- B. Standard: ASTM C1107/C1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- C. Design Mix: 5000-psi, 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

2.05 SILICONE SEALANTS

- A. Silicone Sealants: Single-component, silicone-based, neutral-curing elastomeric sealants of grade indicated below.
 1. Grade: Pourable (self-leveling) formulation for openings in floors and other horizontal surfaces that are not fire rated.

PART 3 EXECUTION

3.01 SLEEVE INSTALLATION FOR NON-FIRE-RATED ELECTRICAL PENETRATIONS

- A. Comply with NECA 1.
- B. Comply with NEMA VE 2 for cable tray and cable penetrations.
- C. Sleeves for Conduits Penetrating Above-Grade Non-Fire-Rated Concrete and Masonry-Unit Floors and Walls:
 1. Interior Penetrations of Non-Fire-Rated Walls and Floors:
 - a. Seal annular space between sleeve and raceway or cable, using joint sealant appropriate for size, depth, and location of joint. Comply with requirements in Section 079200 "Joint Sealants."
 - b. Seal space outside of sleeves with mortar or grout. Pack sealing material solidly between sleeve and wall so no voids remain. Tool exposed surfaces smooth; protect material while curing.
 2. Use pipe sleeves unless penetration arrangement requires rectangular sleeved opening.
 3. Size pipe sleeves to provide 1/4-inch annular clear space between sleeve and raceway or cable unless sleeve seal is to be installed.
 4. Install sleeves for wall penetrations unless core-drilled holes or formed openings are used. Install sleeves during erection of walls. Cut sleeves to length for mounting flush with both surfaces of walls. De-burr after cutting.
 5. Install sleeves for floor penetrations. Extend sleeves installed in floors 3 inches above finished floor level. Install sleeves during erection of floors.
- D. Sleeves for Conduits Penetrating Non-Fire-Rated Gypsum Board Assemblies:
 1. Use circular metal sleeves unless penetration arrangement requires rectangular sleeved opening.
 2. Seal space outside of sleeves with approved joint compound for gypsum board assemblies.
- E. Roof-Penetration Sleeves: Seal penetration of individual raceways and cables with flexible boot-type flashing units applied in coordination with roofing work.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- F. Aboveground, Exterior-Wall Penetrations: Seal penetrations using steel pipe sleeves and mechanical sleeve seals. Select sleeve size to allow for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
- G. Underground, Exterior-Wall and Floor Penetrations: Install cast-iron pipe sleeves. Size sleeves to allow for 1-inch annular clear space between raceway or cable and sleeve for installing sleeve-seal system.

3.02 SLEEVE-SEAL-SYSTEM INSTALLATION

- A. Install sleeve-seal systems in sleeves in exterior concrete walls and slabs-on-grade at raceway entries into building.
- B. Install type and number of sealing elements recommended by manufacturer for raceway or cable material and size. Position raceway or cable in center of sleeve. Assemble mechanical sleeve seals and install in annular space between raceway or cable and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.

3.03 SLEEVE-SEAL-FITTING INSTALLATION

- A. Install sleeve-seal fittings in new walls and slabs as they are constructed.
- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange to be centered in concrete slab or wall.
- C. Secure nailing flanges to concrete forms.
- D. Using grout, seal the space around outside of sleeve-seal fittings.

END OF SECTION 260544

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

This page intentionally left blank

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 260553
IDENTIFICATION FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
 - 1. Color and legend requirements for raceways, conductors, and warning labels and signs.
 - 2. Labels.
 - 3. Tapes and stencils.
 - 4. Tags.
 - 5. Signs.
 - 6. Cable ties.
 - 7. Paint for identification.
 - 8. Fasteners for labels and signs.

1.03 ACTION SUBMITTALS

- A. Identification Schedule: For each piece of electrical equipment and electrical system components to be an index of nomenclature for electrical equipment and system components used in identification signs and labels. Use same designations indicated on Drawings.
- B. Delegated-Design Submittal: For arc-flash hazard study.

PART 2 PRODUCTS

2.01 PERFORMANCE REQUIREMENTS

- A. Comply with ASME A13.1.
- B. Comply with NFPA 70.
- C. Comply with 29 CFR 1910.144 and 29 CFR 1910.145.
- D. Comply with NFPA 70E requirements for arc-flash warning labels.

2.02 COLOR AND LEGEND REQUIREMENTS

- A. Color-Coding for Phase- and Voltage-Level Identification, 600 V or Less: Use colors listed below for ungrounded service, feeder and branch-circuit conductors.
 - 1. Color shall be factory applied or field applied for sizes larger than No. 8 AWG if authorities having jurisdiction permit.
 - 2. Colors for 208/120-V Circuits:
 - a. Phase A: Black.
 - b. Phase B: Red.
 - c. Phase C: Blue.
 - 3. Color for Neutral: White.
 - 4. Color for Equipment Grounds: Green.
- B. Warning labels and signs shall include, but are not limited to, the following legends:
 - 1. Multiple Power Source Warning: "DANGER - ELECTRICAL SHOCK HAZARD - EQUIPMENT HAS MULTIPLE POWER SOURCES."

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Workspace Clearance Warning: "WARNING - OSHA REGULATION - AREA IN FRONT OF ELECTRICAL EQUIPMENT MUST BE KEPT CLEAR FOR 36 INCHES."
 3. Flash Protection Field Marking: All panelboards, switchgear, switchboards, panelboards motor control centers, motor control panels and electrical control panels shall be provided with a black on yellow warning sign per ANSI Z535.4 and ISO 3864. The sign shall read: "DANGER! ARC FLASH and SHOCK HAZARD. FOLLOW ALL REQUIREMENTS IN NFPA70E FOR SAFE WORK PRACTICES and PERSONAL PROTECTIVE EQUIPMENT." The sign shall be prominently mounted on the front of the equipment and readily visible. If the equipment has multiple removable front covers, a sign shall be mounted on each cover. For flush mounted panelboards in finished spaces, the sign shall be mounted on the inside of the door or inside cover. Manufacturers' standard labels are not acceptable.
- C. Equipment Identification Labels:
1. Black letters on a white field.

2.03 LABELS

- A. Self-Adhesive Wraparound Labels: Preprinted, 3-mil-thick, vinyl flexible label with acrylic pressure-sensitive adhesive.
1. Self-Lamination: Clear; UV-, weather- and chemical-resistant; self-laminating, protective shield over the legend. Labels sized such that the clear shield overlaps the entire printed legend.
 2. Marker for Labels: Permanent, waterproof, black ink marker recommended by tag manufacturer.
 3. Marker for Labels: Machine-printed, permanent, waterproof, black ink recommended by printer manufacturer.
- B. Self-Adhesive Labels: Vinyl, thermal, transfer-printed, 3-mil-thick, multicolor, weather- and UV-resistant, pressure-sensitive adhesive labels, configured for intended use and location.
1. Minimum Nominal Size:
 - a. 1-1/2 by 6 inches for raceway and conductors.
 - b. 3-1/2 by 5 inches for equipment.
 - c. As required by authorities having jurisdiction.

2.04 TAPES AND STENCILS

- A. Marker Tapes: Vinyl or vinyl-cloth, self-adhesive wraparound type, with circuit identification legend machine printed by thermal transfer or equivalent process.
- B. Self-Adhesive Vinyl Tape: Colored, heavy duty, waterproof, fade resistant; not less than 3 mils thick by 1 to 2 inches wide; compounded for outdoor use.
- C. Floor Marking Tape: 2-inch-wide, 5-mil pressure-sensitive vinyl tape, with yellow and black stripes and clear vinyl overlay.

2.05 TAGS

- A. Write-on Tags:
1. Polyester Tags: 0.015 inch thick, with corrosion-resistant grommet and cable tie for attachment.
 2. Marker for Tags: Machine-printed, permanent, waterproof, black ink marker recommended by printer manufacturer.

2.06 SIGNS

- A. Baked-Enamel Signs:
1. Preprinted aluminum signs, punched or drilled for fasteners, with colors, legend, and size required for application.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. 1/4-inch grommets in corners for mounting.
 3. Nominal size, 7 by 10 inches.
- B. Metal-Backed Butyrate Signs:
1. Weather-resistant, non-fading, preprinted, cellulose-acetate butyrate signs with 0.0396-inch galvanized-steel backing; and with colors, legend, and size required for application.
 2. 1/4-inch grommets in corners for mounting.
 3. Nominal size, 10 by 14 inches.
- C. Laminated Acrylic or Melamine Plastic Signs:
1. Engraved legend.
 2. Thickness:
 - a. For signs up to 20 sq. in., minimum 1/16 inch thick.
 - b. For signs larger than 20 sq. in., 1/8 inch thick.
 - c. Engraved legend with black letters on white face.
 - d. Punched or drilled for mechanical fasteners with 1/4-inch grommets in corners for mounting.
 - e. Framed with mitered acrylic molding and arranged for attachment at applicable equipment.

2.07 CABLE TIES

- A. General-Purpose Cable Ties: Fungus inert, self-extinguishing, one piece, self-locking, and Type 6/6 nylon.
1. Minimum Width: 3/16 inch.
 2. Tensile Strength at 73 Deg F according to ASTM D638: 12,000 psi.
 3. Temperature Range: Minus 40 to plus 185 deg F.
 4. Color: Black, except where used for color-coding.
- B. Plenum-Rated Cable Ties: Self-extinguishing, UV stabilized, one piece, and self-locking.
1. Minimum Width: 3/16 inch.
 2. Tensile Strength at 73 Deg F according to ASTM D638: 7000 psi.
 3. UL 94 Flame Rating: 94V-0.
 4. Temperature Range: Minus 50 to plus 284 deg F.
 5. Color: Black.

2.08 MISCELLANEOUS IDENTIFICATION PRODUCTS

- A. Paint: Comply with requirements in painting Sections for paint materials and application requirements. Retain paint system applicable for surface material and location (exterior or interior).
- B. Fasteners for Labels and Signs: Self-tapping, stainless-steel screws or stainless-steel machine screws with nuts and flat and lock washers.

PART 3 EXECUTION

3.01 PREPARATION

- A. Self-Adhesive Identification Products: Before applying electrical identification products, clean substrates of substances that could impair bond, using materials and methods recommended by manufacturer of identification product.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.02 INSTALLATION

- A. Verify and coordinate identification names, abbreviations, colors, and other features with requirements in other Sections requiring identification applications, Drawings, Shop Drawings, manufacturer's wiring diagrams, and operation and maintenance manual. Use consistent designations throughout Project.
- B. Install identifying devices before installing acoustical ceilings and similar concealment.
- C. Verify identity of each item before installing identification products.
- D. Coordinate identification with Project Drawings, manufacturer's wiring diagrams, and operation and maintenance manual.
- E. Apply identification devices to surfaces that require finish after completing finish work.
- F. Install signs with approved legend to facilitate proper identification, operation, and maintenance of electrical systems and connected items.
- G. System Identification for Raceways and Cables under 600 V: Identification shall completely encircle cable or conduit. Place identification of two-color markings in contact, side by side.
 - 1. Secure tight to surface of conductor, cable, or raceway.
- H. Auxiliary Electrical Systems Conductor Identification: Identify field-installed alarm, control, and signal connections.
- I. Elevated Components: Increase sizes of labels, signs, and letters to those appropriate for viewing from the floor.
- J. Accessible Fittings for Raceways: Identify the covers of each junction and pull box of the following systems with the wiring system legend and system voltage. System legends shall be as follows:
 - 1. "POWER."
 - 2. "FIRE ALARM."
- K. Self-Adhesive Wraparound Labels: Secure tight to surface at a location with high visibility and accessibility.
- L. Self-Adhesive Labels:
 - 1. On each item, install unique designation label that is consistent with wiring diagrams, schedules, and operation and maintenance manual.
 - 2. Unless otherwise indicated, provide a single line of text with 1/2-inch-high letters on 1-1/2-inch-high label; where two lines of text are required, use labels 2 inches high.
- M. Marker Tapes: Secure tight to surface at a location with high visibility and accessibility.
- N. Self-Adhesive Vinyl Tape: Secure tight to surface at a location with high visibility and accessibility.
 - 1. Field-Applied, Color-Coding Conductor Tape: Apply in half-lapped turns for a minimum distance of 6 inches where splices or taps are made. Apply last two turns of tape with no tension to prevent possible unwinding.
- O. Floor Marking Tape: Apply stripes to finished surfaces following manufacturer's written instructions.
- P. Underground Line Warning Tape:
 - 1. During backfilling of trenches, install continuous underground-line warning tape directly above cable or raceway at 6 to 8 inches below finished grade. Use multiple tapes where width of multiple lines installed in a common trench exceeds 16 inches overall.
 - 2. Install underground-line warning tape for direct-buried cables and cables in raceways.
- Q. Write-on Tags:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Place in a location with high visibility and accessibility.
 2. Secure using general-purpose cable ties.
- R. Baked-Enamel Signs:
1. Attach signs that are not self-adhesive type with mechanical fasteners appropriate to the location and substrate.
 2. Unless otherwise indicated, provide a single line of text with 1/2-inch-high letters on minimum 1-1/2-inch-high sign; where two lines of text are required, use signs minimum 2 inches high.
- S. Metal-Backed Butyrate Signs:
1. Attach signs that are not self-adhesive type with mechanical fasteners appropriate to the location and substrate.
 2. Unless otherwise indicated, provide a single line of text with 1/2-inch-high letters on 1-1/2-inch-high sign; where two lines of text are required, use labels 2 inches high.
- T. Laminated Acrylic or Melamine Plastic Signs:
1. Attach signs that are not self-adhesive type with mechanical fasteners appropriate to the location and substrate.
 2. Unless otherwise indicated, provide a single line of text with 1/2-inch-high letters on 1-1/2-inch-high sign; where two lines of text are required, use labels 2 inches high.
- U. Cable Ties: General purpose, for attaching tags, except as listed below:
1. In Spaces Handling Environmental Air: Plenum rated.

3.03 IDENTIFICATION SCHEDULE

- A. Install identification materials and devices at locations for most convenient viewing without interference with operation and maintenance of equipment. Install access doors or panels to provide view of identifying devices.
- B. Identify conductors, cables, and terminals in enclosures and at junctions, terminals, pull points, and locations of high visibility. Identify by system and circuit designation.
- C. Accessible Raceways, Armored and Metal-Clad Cables, More Than 600 V: Self-adhesive labels.
1. Locate identification at changes in direction, at penetrations of walls and floors, at 50-foot maximum intervals in straight runs, and at 25-foot maximum intervals in congested areas.
- D. Accessible Fittings for Raceways and Cables within Buildings: Identify the covers of each junction and pull box of the following systems with self-adhesive labels containing the wiring system legend and system voltage. System legends shall be as follows:
1. "POWER."
 2. "FIRE ALARM."
- E. Power-Circuit Conductor Identification, 600 V or Less: For conductors in vaults, pull and junction boxes, manholes, and handholes, use self-adhesive vinyl tape to identify the phase.
1. Locate identification in pull/junction boxes.
- F. Control-Circuit Conductor Identification: For conductors and cables in pull and junction boxes, manholes, and handholes, use self-adhesive labels with the conductor or cable designation, origin, and destination.
- G. Control-Circuit Conductor Termination Identification: For identification at terminations, provide self-adhesive labels with the conductor designation.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- H. Auxiliary Electrical Systems Conductor Identification: Marker tape or Self-adhesive vinyl tape that is uniform and consistent with system used by manufacturer for factory-installed connections.
 - 1. Identify conductors, cables, and terminals in enclosures and at junctions, terminals, and pull points. Identify by system and circuit designation.
- I. Locations of Underground Lines: Underground-line warning tape for power, lighting, communication, and control wiring and optical-fiber cable.
- J. Workspace Indication: Apply floor marking tape to finished surfaces. Show working clearances in the direction of access to live parts. Workspace shall comply with NFPA 70 and 29 CFR 1926.403 unless otherwise indicated. Do not install at flush-mounted panelboards and similar equipment in finished spaces.
- K. Instructional Signs: Self-adhesive labels, including the color code for grounded and ungrounded conductors.
- L. Warning Labels for Indoor Cabinets, Boxes, and Enclosures for Power and Lighting: Baked-enamel warning signs.
 - 1. Apply to exterior of door, cover, or other access.
 - 2. For equipment with multiple power or control sources, apply to door or cover of equipment, including, but not limited to, the following:
 - a. Controls with external control power connections.
 - b. Other equipment as indicated on the Drawings.
- M. Arc Flash Warning Labeling: Self-adhesive labels.
- N. Operating Instruction Signs: Laminated acrylic or melamine plastic signs.
- O. Equipment Identification Labels:
 - 1. Indoor Equipment: Laminated acrylic or melamine plastic sign.
 - 2. Outdoor Equipment: Laminated acrylic or melamine sign
 - 3. Equipment to Be Labeled:
 - a. Panelboards: Typewritten directory of circuits in the location provided by panelboard manufacturer. Panelboard identification shall be in the form of a engraved, laminated acrylic or melamine label.
 - b. Enclosures and electrical cabinets.
 - c. Switchboards.
 - d. Transformers: Label that includes tag designation indicated on Drawings for the transformer, feeder, and panelboards or equipment supplied by the secondary.
 - e. Enclosed switches.
 - f. Enclosed circuit breakers.
 - g. Enclosed controllers.
 - h. Variable-speed controllers.
 - i. Push-button stations.
 - j. Contactors.

END OF SECTION 260553

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 260574
OVERCURRENT PROTECTIVE DEVICE ARC-FLASH STUDY

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section includes a computer-based, arc-flash study to determine the arc-flash hazard distance and the incident energy to which personnel could be exposed during work on or near electrical equipment.

1.03 DEFINITIONS

- A. Existing to Remain: Existing items of construction that are not to be removed and that are not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.
- B. One-Line Diagram: A diagram which shows, by means of single lines and graphic symbols, the course of an electric circuit or system of circuits and the component devices or parts used therein.
- C. Protective Device: A device that senses when an abnormal current flow exists and then removes the affected portion from the system.
- D. SCCR: Short-circuit current rating.
- E. Service: The conductors and equipment for delivering electric energy from the serving utility to the wiring system of the premises served.

1.04 ACTION SUBMITTALS

- A. Study Submittals: Submit the following submittals after the approval of system protective devices submittals. Submittals shall be in digital form.
 - 1. Arc-flash study input data, including completed computer program input data sheets.
 - 2. Arc-flash study report; signed, dated, and sealed by a qualified professional engineer.
 - a. Submit study report for action prior to receiving final approval of the distribution equipment submittals. If formal completion of studies will cause delay in equipment manufacturing, obtain approval from Architect for preliminary submittal of sufficient study data to ensure that the selection of devices and associated characteristics is satisfactory.

1.05 QUALITY ASSURANCE

- A. Studies shall use computer programs that are distributed nationally and are in wide use. Software algorithms shall comply with requirements of standards and guides specified in this Section. Manual calculations are unacceptable.
- B. Arc-Flash Study Software Developer Qualifications: An entity that owns and markets computer software used for studies, having performed successful studies of similar magnitude on electrical distribution systems using similar devices.
 - 1. The computer program shall be developed under the charge of a licensed professional engineer who holds IEEE Computer Society's Certified Software Development Professional certification.
- C. Arc-Flash Study Specialist Qualifications: Professional engineer in charge of performing the study, analyzing the arc flash, and documenting recommendations, licensed in the state where Project is located. All elements of the study shall be performed under the direct supervision and control of this professional engineer.
- D. Field Adjusting Agency Qualifications: An independent agency, with the experience and capability to adjust overcurrent devices and to conduct the testing indicated, that is a

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

member company of the InterNational Electrical Testing Association or is a nationally recognized testing laboratory (NRTL) as defined by OSHA in 29 CFR 1910.7, and that is acceptable to authorities having jurisdiction.

PART 2 PRODUCTS

2.01 COMPUTER SOFTWARE DEVELOPERS

- A. Computer Software Developers: Subject to compliance with requirements, provide products by one of the following:
 - 1. EDSA Micro Corporation.
 - 2. ESA Inc.
 - 3. EZ Power.
 - 4. SKM Systems Analysis, Inc.
- B. Comply with IEEE 1584 and NFPA 70E.
- C. Analytical features of device coordination study computer software program shall have the capability to calculate "mandatory," "very desirable," and "desirable" features as listed in IEEE 399.

2.02 ARC-FLASH STUDY REPORT CONTENT

- A. Executive summary.
- B. Study descriptions, purpose, basis and scope.
- C. One-line diagram, showing the following:
 - 1. Protective device designations and ampere ratings.
 - 2. Cable size and lengths.
 - 3. Transformer kilovolt ampere (kVA) and voltage ratings.
 - 4. Motor and generator designations and kVA ratings.
 - 5. Switchgear, switchboard, motor-control center and panelboard designations.
- D. Study Input Data: As described in "Power System Data" Article.
- E. Short-Circuit Study Output:
 - 1. Low-Voltage Fault Report: Three-phase and unbalanced fault calculations, showing the following for each overcurrent device location:
 - a. Voltage.
 - b. Calculated fault-current magnitude and angle.
 - c. Fault-point X/R ratio.
 - d. Equivalent impedance.
- F. Protective Device Coordination Study:
 - 1. Report recommended settings of protective devices, ready to be applied in the field. Use manufacturer's data sheets for recording the recommended setting of overcurrent protective devices when available.
 - a. Phase and Ground Relays:
 - 1) Device tag.
 - 2) Relay current transformer ratio and tap, time dial, and instantaneous pickup value.
 - 3) Recommendations on improved relaying systems, if applicable.
 - b. Circuit Breakers:
 - 1) Adjustable pickups and time delays (long time, short time, ground).

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- 2) Adjustable time-current characteristic.
 - 3) Adjustable instantaneous pickup.
 - 4) Recommendations on improved trip systems, if applicable.
 - c. Fuses: Show current rating, voltage, and class.
 2. Time-Current Coordination Curves: Determine settings of overcurrent protective devices to achieve selective coordination. Graphically illustrate that adequate time separation exists between devices installed in series, including power utility company's upstream devices. Prepare separate sets of curves for the switching schemes and for emergency periods where the power source is local generation. Show the following information:
 - a. Device tag and title, one-line diagram with legend identifying the portion of the system covered.
 - b. Terminate device characteristic curves at a point reflecting maximum symmetrical or asymmetrical fault current to which the device is exposed.
 - c. Identify the device associated with each curve by manufacturer type, function, and, if applicable, tap, time delay, and instantaneous settings recommended.
 - d. Plot the following listed characteristic curves, as applicable:
 - 1) Power utility's overcurrent protective device.
 - 2) Medium-voltage equipment overcurrent relays.
 - 3) Medium- and low-voltage fuses including manufacturer's minimum melt, total clearing, tolerance, and damage bands.
 - 4) Low-voltage equipment circuit-breaker trip devices, including manufacturer's tolerance bands.
 - 5) Transformer full-load current, magnetizing inrush current, and ANSI through-fault protection curves.
 - 6) Cables and conductors damage curves.
 - 7) Ground-fault protective devices.
 - 8) Motor-starting characteristics and motor damage points.
 - 9) The largest feeder circuit breaker in each motor-control center and panelboard.
- G. Arc-Flash Study Output:
1. Interrupting Duty Report: Three-phase and unbalanced fault calculations, showing the following for each overcurrent device location:
 - a. Voltage.
 - b. Calculated symmetrical fault-current magnitude and angle.
 - c. Fault-point X/R ratio.
 - d. No AC Decrement (NACD) ratio.
 - e. Equivalent impedance.
- H. Incident Energy and Flash Protection Boundary Calculations:
1. Arcing fault magnitude.
 2. Protective device clearing time.
 3. Duration of arc.
 4. Arc-flash boundary.
 5. Working distance.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

6. Incident energy.
 7. Hazard risk category.
 8. Recommendations for arc-flash energy reduction.
- I. Fault study input data, case descriptions, and fault-current calculations including a definition of terms and guide for interpretation of the computer printout.

2.03 ARC-FLASH WARNING LABELS

- A. Comply with requirements in Section 260553 "Identification for Electrical Systems" for self-adhesive equipment labels. Produce a 3.5-by-5-inch self-adhesive equipment label for each work location included in the analysis.
- B. The label shall have an orange header with the wording, "WARNING, ARC-FLASH HAZARD," and shall include the following information taken directly from the arc-flash hazard analysis:
1. Location designation.
 2. Nominal voltage.
 3. Flash protection boundary.
 4. Hazard risk category.
 5. Incident energy.
 6. Working distance.
 7. Engineering report number, revision number, and issue date.
- C. Labels shall be machine printed, with no field-applied markings.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine Project overcurrent protective device submittals. Proceed with arc-flash study only after relevant equipment submittals have been assembled. Overcurrent protective devices that have not been submitted and approved prior to arc-flash study may not be used in study.

3.02 ARC-FLASH HAZARD ANALYSIS

- A. Comply with NFPA 70E and its Annex D for hazard analysis study.
- B. Preparatory Studies:
1. Short-Circuit Study Output: As specified in above.
 2. Protective Device Coordination Study Report Contents: As specified above.
- C. Calculate maximum and minimum contributions of fault-current size.
1. The minimum calculation shall assume that the utility contribution is at a minimum and shall assume no motor load.
 2. The maximum calculation shall assume a maximum contribution from the utility and shall assume motors to be operating under full-load conditions.
- D. Calculate the arc-flash protection boundary and incident energy at locations in the electrical distribution system where personnel could perform work on energized parts.
- E. Include medium- and low-voltage equipment locations, except equipment rated 240-V ac or less fed from transformers less than 125 kVA.
- F. Safe working distances shall be specified for calculated fault locations based on the calculated arc-flash boundary, considering incident energy of 1.2 cal/sq.cm.
- G. Incident energy calculations shall consider the accumulation of energy over time when performing arc-flash calculations on buses with multiple sources. Iterative calculations shall take into account the changing current contributions, as the sources are interrupted or

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

decremented with time. Fault contribution from motors and generators shall be decremented as follows:

1. Fault contribution from induction motors should not be considered beyond three to five cycles.
 2. Fault contribution from synchronous motors and generators should be decayed to match the actual decrement of each as closely as possible (e.g., contributions from permanent magnet generators will typically decay from 10 per unit to three per unit after 10 cycles).
- H. Arc-flash computation shall include both line and load side of a circuit breaker as follows:
1. When the circuit breaker is in a separate enclosure.
 2. When the line terminals of the circuit breaker are separate from the work location.
- I. Base arc-flash calculations on actual overcurrent protective device clearing time. Cap maximum clearing time at two seconds based on IEEE 1584, Section B.1.2.

3.03 POWER SYSTEM DATA

- A. Obtain all data necessary for the conduct of the arc-flash hazard analysis.
1. Verify completeness of data supplied on the one-line diagram on Drawings. Call discrepancies to the attention of Architect.
 2. For new equipment, use characteristics submitted under the provisions of action submittals and information submittals for this Project.
 3. For existing equipment, whether or not relocated, obtain required electrical distribution system data by field investigation and surveys, conducted by qualified technicians and engineers.
- B. Electrical Survey Data: Gather and tabulate the following input data to support study. Comply with recommendations in IEEE 1584 and NFPA 70E as to the amount of detail that is required to be acquired in the field. Field data gathering shall be under the direct supervision and control of the engineer in charge of performing the study, and shall be by the engineer or its representative who holds NETA ETT Level III certification or NICET Electrical Power Testing Level III certification.
1. Product Data for overcurrent protective devices specified in other Sections and involved in overcurrent protective device coordination studies. Use equipment designation tags that are consistent with electrical distribution system diagrams, overcurrent protective device submittals, input and output data, and recommended device settings.
 2. Obtain electrical power utility impedance at the service.
 3. Power sources and ties.
 4. Short-circuit current at each system bus, three phase and line-to-ground.
 5. Full-load current of all loads.
 6. Voltage level at each bus.
 7. For transformers, include kVA, primary and secondary voltages, connection type, impedance, X/R ratio, taps measured in per cent, and phase shift.
 8. For reactors, provide manufacturer and model designation, voltage rating and impedance.
 9. For circuit breakers and fuses, provide manufacturer and model designation. List type of breaker, type of trip and available range of settings, SCCR, current rating, and breaker settings.
 10. Generator short-circuit current contribution data, including short-circuit reactance, rated kVA, rated voltage, and X/R ratio.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

11. For relays, provide manufacturer and model designation, current transformer ratios, potential transformer ratios, and relay settings.
12. Busway manufacturer and model designation, current rating, impedance, lengths, and conductor material.
13. Motor horsepower and NEMA MG 1 code letter designation.
14. Low-voltage cable sizes, lengths, number, conductor material and conduit material (magnetic or nonmagnetic).
15. Medium-voltage cable sizes, lengths, conductor material, and cable construction and metallic shield performance parameters.

3.04 LABELING

- A. Apply one arc-flash label for 600-V ac, 480-V ac, and applicable 208-V ac panelboards and disconnects and for each of the following locations:
 1. Low-voltage switchboard.
 2. Panelboards

3.05 APPLICATION OF WARNING LABELS

- A. Install the arc-fault warning labels under the direct supervision and control of the Arc-Flash Study Specialist.

3.06 DEMONSTRATION

- A. Engage the Arc-Flash Study Specialist to train Owner's maintenance personnel in the potential arc-flash hazards associated with working on energized equipment and the significance of the arc-flash warning labels.
 1. Acquaint personnel in the fundamentals of operating the power system in normal and emergency modes.
 2. Hand-out and explain the objectives of the coordination study, study descriptions, purpose, basis, and scope. Include case descriptions, definition of terms, and guide for interpreting the time-current coordination curves.
 3. Adjust, operate, and maintain overcurrent protective device settings.

END OF SECTION 260574

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 262213

LOW-VOLTAGE DISTRIBUTION TRANSFORMERS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Distribution, dry-type transformers with nominal primary and secondary rating of 600 V and less, with capacities up to 1500 kVA.

1.2 ACTION SUBMITTALS

A. Product Data:

1. For each type of product.
 - a. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each type and size of transformer.
 - b. Include rated nameplate data, capacities, weights, dimensions, minimum clearances, installed devices and features, and performance for each type and size of transformer.

B. Shop Drawings:

1. Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of field connections.

1.3 INFORMATIONAL SUBMITTALS

1.4 DELIVERY, STORAGE, AND HANDLING

A. Inspection: On receipt, inspect for and note shipping damage to packaging and transformer.

1. If manufacturer packaging is removed for inspection, and transformer will be stored after inspection, re-package transformer using original or new packaging materials that provide protection equivalent to manufacturer's packaging.

B. Storage: Store in warm, dry, and temperature-stable location in original shipping packaging.

C. Temporary Heating: Apply temporary heat in accordance with manufacturer's published instructions within enclosure of ventilated-type units, throughout periods during which equipment is not energized and when transformer is not in space that is continuously under normal control of temperature and humidity.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Handling: Follow manufacturer's instructions for lifting and transporting transformers.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
1. Eaton Corp. Electrical Group.
 2. Schneider Electric; Square D
 3. General Electric
 4. Siemens
- B. Source Limitations: Obtain each type of transformer from single source from single manufacturer.

2.2 GENERAL TRANSFORMER REQUIREMENTS

- A. Description: Factory-assembled and -tested, air-cooled units for 60 Hz service.
- B. Electrical Components, Devices, and Accessories: Listed and labeled in accordance with NFPA 70, by qualified electrical testing laboratory recognized by authorities having jurisdiction, and marked for intended location and application.
- C. Transformers Rated 15 kVA and Larger:
1. Comply with 10 CFR 431 (DOE 2016) efficiency levels.
 2. Marked as compliant with DOE 2016 efficiency levels by qualified electrical testing laboratory recognized by authorities having jurisdiction.

2.3 DISTRIBUTION TRANSFORMERS

- A. Cores: Electrical grade, non-aging silicon steel with high permeability and low hysteresis losses.
1. One leg per phase.
- B. Coils: Continuous windings except for taps.
1. Coil Material: Copper.
 2. Internal Coil Connections: Brazed or pressure type.
- C. Enclosure: Ventilated, NEMA 250, Type 2.
1. Finish Color: ANSI 61 gray weather-resistant enamel.
- D. Taps for Transformers 7.5 to 24 kVA: One 5 percent tap above and one 5 percent tap below normal full capacity.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- E. Taps for Transformers 25 kVA and Larger: Two 2.5 percent taps above and two 2.5 percent taps below normal full capacity.
- F. Insulation Class, 30 kVA and Larger: 220 deg C, UL-component-recognized insulation system with maximum of 150 deg C rise above 40 deg C ambient temperature.
- G. Grounding: Provide ground-bar kit or ground bar installed on inside of transformer enclosure.
- H. Wall Brackets: Manufacturer's standard brackets.

2.4 IDENTIFICATION

- A. Nameplates: Engraved, laminated-acrylic or melamine plastic signs for distribution transformers, mounted with corrosion-resistant screws. Nameplates and label products are specified in Section 260553 "Identification for Electrical Systems."

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine conditions for compliance with enclosure- and ambient-temperature requirements for transformers.
- B. Verify that field measurements are as needed to maintain working clearances required by NFPA 70 and manufacturer's published instructions.
- C. Examine walls, floors, roofs, and concrete bases for suitable mounting conditions where transformers will be installed.

3.2 INSTALLATION

- A. Install wall-mounted transformers level and plumb with wall brackets.
 - 1. Coordinate installation of wall-mounted and structure-hanging supports with actual transformer provided.
- B. Construct concrete bases and anchor floor-mounted transformers in accordance with manufacturer's published instructions, and requirements in Section 260529 "Hangers and Supports for Electrical Systems."
 - 1. Coordinate size and location of concrete bases with actual transformer provided. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified with concrete.
- C. Secure transformer to concrete base in accordance with manufacturer's published instructions.
- D. Secure covers to enclosure and tighten bolts to manufacturer-recommended torques to reduce noise generation.
- E. Remove shipping bolts, blocking, and wedges.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.3 CONNECTIONS

- A. Ground equipment in accordance with Section 260526 "Grounding and Bonding for Electrical Systems."
- B. Connect wiring in accordance with Section 260519 "Low-Voltage Electrical Power Conductors and Cables."
- C. Tighten electrical connectors and terminals in accordance with manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A-486B.
- D. Provide flexible connections at conduit and conductor terminations and supports to eliminate sound and vibration transmission to building structure.

3.4 FIELD QUALITY CONTROL

- A. Tests and Inspections:
 - 1. Perform each visual and mechanical inspection and electrical test stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
- B. Remove and replace units that do not pass tests or inspections and retest as specified above.
- C. Test Labeling: On completion of satisfactory testing of each unit, attach a dated and signed "Satisfactory Test" label to tested component.

3.5 ADJUSTING

- A. Record transformer secondary voltage at unit for at least 48 hours of typical occupancy period. Adjust transformer taps to provide optimum voltage conditions at secondary terminals. Optimum is defined as not exceeding nameplate voltage plus 5 percent and not being lower than nameplate voltage minus 3 percent at maximum load conditions. Submit recording and tap settings as test results.
- B. Output Settings Report: Prepare written report recording output voltages and tap settings.

3.6 CLEANING

- A. Vacuum dirt and debris; do not use compressed air to assist in cleaning.

END OF SECTION 262213

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 262413

SWITCHBOARDS

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
 - 1. Service and distribution switchboards rated 600 V and less.
 - 2. Surge protection devices.
 - 3. Disconnecting and overcurrent protective devices.
 - 4. Control power.
 - 5. Accessory components and features.
 - 6. Identification.

1.03 ACTION SUBMITTALS

- A. Product Data: For each switchboard, overcurrent protective device, surge protection device, ground-fault protector, accessory, and component.
 - 1. Include dimensions and manufacturers' technical data on features, performance, electrical characteristics, ratings, accessories, and finishes.
- B. Shop Drawings: For each switchboard and related equipment.
 - 1. Include dimensioned plans, elevations, sections, and details, including required clearances and service space around equipment. Show tabulations of installed devices, equipment features, and ratings.
 - 2. Detail enclosure types for types other than NEMA 250, Type 1.
 - 3. Detail bus configuration, current, and voltage ratings.
 - 4. Detail short-circuit current rating of switchboards and overcurrent protective devices.
 - 5. Detail features, characteristics, ratings, and factory settings of individual overcurrent protective devices and auxiliary components.
 - 6. Include schematic and wiring diagrams for power, signal, and control wiring.
- C. Delegated Design Submittal:
 - 1. For arc-flash hazard analysis.
 - 2. For arc-flash labels.

1.04 INFORMATIONAL SUBMITTALS

- A. Field Quality-Control Reports:
 - 1. Test procedures used.
 - 2. Test results that comply with requirements.
 - 3. Results of failed tests and corrective action taken to achieve test results that comply with requirements.

1.05 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For switchboards and components to include in emergency, operation, and maintenance manuals.
 - 1. In addition to items specified in Section 017823 "Operation and Maintenance Data," include the following:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Routine maintenance requirements for switchboards and all installed components.
- b. Manufacturer's written instructions for testing and adjusting overcurrent protective devices.
- c. Time-current coordination curves for each type and rating of overcurrent protective device included in switchboards. Submit on translucent log-log graph paper; include selectable ranges for each type of overcurrent protective device.

1.06 QUALITY ASSURANCE

- A. Installer Qualifications: An employer of workers qualified as defined in NEMA PB 2.1 and trained in electrical safety as required by NFPA 70E.
- B. Testing Agency Qualifications: Accredited by NETA.
 - 1. Testing Agency's Field Supervisor: Certified by NETA to supervise on-site testing.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver switchboards in sections or lengths that can be moved past obstructions in delivery path.
- B. Remove loose packing and flammable materials from inside switchboards.
- C. Handle and prepare switchboards for installation according to NEMA PB 2.1.

1.08 FIELD CONDITIONS

- A. Environmental Limitations:
 - 1. Do not deliver or install switchboards until spaces are enclosed and weathertight, wet work in spaces is complete and dry, work above switchboards is complete, and temporary HVAC system is operating and maintaining ambient temperature and humidity conditions at occupancy levels during the remainder of the construction period.
 - 2. Rate equipment for continuous operation under the following conditions unless otherwise indicated:
 - a. Ambient Temperature: Not exceeding 104 deg F.
 - b. Altitude: Not exceeding 6600 feet.
- B. Interruption of Existing Electric Service: Do not interrupt electric service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary electric service according to requirements indicated:
 - 1. Notify Owner no fewer than ten days in advance of proposed interruption of electric service.
 - 2. Indicate method of providing temporary electric service.
 - 3. Do not proceed with interruption of electric service without Owner's written permission.
 - 4. Comply with NFPA 70E.

1.09 COORDINATION

- A. Coordinate layout and installation of switchboards and components with other construction that penetrates walls or is supported by them, including electrical and other types of equipment, raceways, piping, encumbrances to workspace clearance requirements, and adjacent surfaces. Maintain required workspace clearances and required clearances for equipment access doors and panels.
- B. Coordinate sizes and locations of concrete bases with actual equipment provided. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified with concrete.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.10 WARRANTY

- A. Manufacturer's Warranty: Manufacturer agrees to repair or replace switchboard enclosures, buswork, overcurrent protective devices, accessories, and factory installed interconnection wiring that fail in materials or workmanship within specified warranty period.
 - 1. Warranty Period: Three years from date of Substantial Completion.
- B. Manufacturer's Warranty: Manufacturer's agrees to repair or replace surge protection devices that fail in materials or workmanship within specified warranty period.
 - 1. Warranty Period: Five years from date of Substantial Completion.

PART 2 PRODUCTS

2.01 SWITCHBOARDS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Eaton Corp. Electrical Group.
 - 2. Schneider Electric; Square D
 - 3. General Electric
 - 4. Siemens
- B. Source Limitations: Obtain switchboards, overcurrent protective devices, components, and accessories from single source from single manufacturer.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- D. Comply with NEMA PB 2.
- E. Comply with NFPA 70.
- F. Comply with UL 891.
- G. Front-Connected, Front-Accessible Switchboards:
 - 1. Main Devices: Fixed, individually mounted.
 - 2. Branch Devices: Panel mounted.
 - 3. Sections front and rear aligned.
- H. Nominal System Voltage: 208Y/120 V.
- I. Main-Bus Continuous: 3000 A.
- J. Indoor Enclosures: Steel, NEMA 250, Type 1.
- K. Enclosure Finish for Indoor Units: Factory-applied finish in manufacturer's standard gray finish over a rust-inhibiting primer on treated metal surface.
- L. Barriers: Between adjacent switchboard sections.
- M. Service Entrance Rating: Switchboards intended for use as service entrance equipment shall contain from one to six service disconnecting means with overcurrent protection, a neutral bus with disconnecting link, a grounding electrode conductor terminal, and a main bonding jumper.
- N. Bus Transition and Incoming Pull Sections: Matched and aligned with basic switchboard.
- O. Hinged Front Panels: Allow access to circuit breaker, metering, accessory, and blank compartments.
- P. Buses and Connections: Three phase, four wire unless otherwise indicated.
 - 1. Provide phase bus arrangement A, B, C from front to back, top to bottom, and left to right when viewed from the front of the switchboard.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Phase- and Neutral-Bus Material: Hard-drawn copper of 98 percent conductivity, silver-plated.
 3. Phase- and Neutral-Bus Material: Tin-plated, high-strength, electrical-grade aluminum alloy with tin-plated aluminum circuit-breaker line connections.
 4. Copper feeder circuit-breaker line connections.
 5. Load Terminals: Insulated, rigidly braced, runback bus extensions, of same material as through buses, equipped with mechanical connectors for outgoing circuit conductors. Provide load terminals for future circuit-breaker positions at full-ampere rating of circuit-breaker position.
 6. Ground Bus: 1/4-by-2-inch-hard-drawn copper of 98 percent conductivity, equipped with mechanical connectors for feeder and branch-circuit ground conductors.
 7. Main-Phase Buses and Equipment-Ground Buses: Uniform capacity for entire length of switchboard's main and distribution sections. Provide for future extensions from both ends.
 8. Disconnect Links:
 - a. Isolate neutral bus from incoming neutral conductors.
 - b. Bond neutral bus to equipment-ground bus for switchboards utilized as service equipment or separately derived systems.
 9. Neutral Buses: 100 percent of the ampacity of phase buses unless otherwise indicated, equipped with mechanical connectors for outgoing circuit neutral cables. Brace bus extensions for busway feeder neutral bus.
 10. Isolation Barrier Access Provisions: Permit checking of bus-bolt tightness.
- Q. Future Devices: Equip compartments with mounting brackets, supports, bus connections, and appurtenances at full rating of circuit-breaker compartment.
- R. Bus-Bar Insulation: Factory-applied, flame-retardant, tape wrapping of individual bus bars or flame-retardant, spray-applied insulation. Minimum insulation temperature rating of 105 deg C.

2.02 SURGE PROTECTION DEVICES

- A. SPDs: Comply with UL 1449, Type 2.
- B. SPDs: Listed and labeled by an NRTL acceptable to authorities having jurisdiction as complying with UL 1449, Type 2.
- C. Features and Accessories:
 1. Integral disconnect switch.
 2. Internal thermal protection that disconnects the SPD before damaging internal suppressor components.
 3. Indicator light display for protection status.
 4. Form-C contacts rated at 5 Amp and 250-VAC, one normally open and one normally closed. Contacts shall reverse on failure of any surge diversion module or on opening of any current-limiting device.
 5. Surge counter.
- D. Peak Surge Current Rating: The minimum single-pulse surge current withstand rating per phase shall not be less than 200 kA. The peak surge current rating shall be the arithmetic sum of the ratings of the individual MOVs in a given mode.
- E. Protection modes and UL 1449 VPR for grounded wye circuits with 480Y2770 V, three-phase, four-wire circuits shall not exceed the following:
 1. Line to Neutral: 1200 V for 480Y/277 V.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- 2. Line to Ground: 1200 V for 480Y/277 V.
- 3. Line to Line: 2000 V for 480Y/277 V.
- F. SCCR: Equal or exceed 300 kA.
- G. Nominal Rating: 20 kA.

2.03 DISCONNECTING AND OVERCURRENT PROTECTIVE DEVICES

- A. Molded-Case Circuit Breaker (MCCB): Comply with UL 489, with interrupting capacity to meet available fault currents.
 - 1. Electronic trip circuit breakers. 225A and larger with rms sensing; field-replaceable rating plug or field-replicable electronic trip; and the following field-adjustable settings:
 - a. Instantaneous trip.
 - b. Long- and short-time pickup levels.
 - c. Long and short time adjustments.
 - d. Ground-fault pickup level, time delay, and I squared t response.
 - 2. MCCB Features and Accessories:
 - a. Standard frame sizes, trip ratings, and number of poles.
 - b. Lugs: Mechanical style, suitable for number, size, trip ratings, and conductor material.
 - c. Application Listing: Appropriate for application; Type SWD for switching fluorescent lighting loads; Type HID for feeding fluorescent and high-intensity discharge (HID) lighting circuits.
 - d. Ground-Fault Protection: Integrally mounted relay and trip unit with adjustable pickup and time-delay settings, push-to-test feature, and ground-fault indicator.
 - e. Zone-Selective Interlocking: Integral with electronic trip unit; for interlocking ground-fault protection function.
 - f. Shunt Trip: 120-V trip coil energized from separate circuit, set to trip at 75 percent of rated voltage.
 - g. Undervoltage Trip: Set to operate at 35 to 75 percent of rated voltage without intentional time delay.
 - h. Auxiliary Contacts: One SPDT switch with "a" and "b" contacts; "a" contacts mimic circuit-breaker contacts, "b" contacts operate in reverse of circuit-breaker contacts.
 - i. Energy Reducing Maintenance Switch with local status indicator for main circuit breaker.
- B. Fused Switch: NEMA KS 1, Type HD; clips to accommodate specified fuses; lockable handle.

2.04 CONTROL POWER

- A. Control Circuits: 120-V ac, supplied through secondary disconnecting devices from control-power transformer.
- B. Control Wiring: Factory installed, with bundling, lacing, and protection included. Provide flexible conductors for No. 8 AWG and smaller, for conductors across hinges, and for conductors for interconnections between shipping units.

2.05 ACCESSORY COMPONENTS AND FEATURES

- A. Mounting Accessories: For anchors, mounting channels, bolts, washers, and other mounting accessories, comply manufacturer's instructions.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

PART 3 EXECUTION

3.01 EXAMINATION

- A. Receive, inspect, handle, and store switchboards according to NEMA PB 2.1.
 - 1. Lift or move panelboards with spreader bars and manufacturer-supplied lifting straps following manufacturer's instructions.
 - 2. Use rollers, slings, or other manufacturer-approved methods if lifting straps are not furnished.
 - 3. Protect from moisture, dust, dirt, and debris during storage and installation.
 - 4. Install temporary heating during storage per manufacturer's instructions.
- B. Examine switchboards before installation. Reject switchboards that are moisture damaged or physically damaged.
- C. Examine elements and surfaces to receive switchboards for compliance with installation tolerances and other conditions affecting performance of the Work or that affect the performance of the equipment.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 INSTALLATION

- A. Install switchboards and accessories according to NEMA PB 2.1.
- B. Equipment Mounting: Install switchboards on concrete base, 4-inch nominal thickness. Comply with requirements for concrete base specified in Section 033000 "Cast-in-Place Concrete."
 - 1. Install conduits entering underneath the switchboard, entering under the vertical section where the conductors will terminate. Install with couplings flush with the concrete base. Extend 2 inches above concrete base after switchboard is anchored in place.
 - 2. Install dowel rods to connect concrete base to concrete floor. Unless otherwise indicated, install dowel rods on 18-inch centers around the full perimeter of concrete base.
 - 3. For supported equipment, install epoxy-coated anchor bolts that extend through concrete base and anchor into structural concrete floor.
 - 4. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
 - 5. Install anchor bolts to elevations required for proper attachment to switchboards.
 - 6. Anchor switchboard to building structure at the top of the switchboard if required or recommended by the manufacturer.
- C. Temporary Lifting Provisions: Remove temporary lifting eyes, channels, straps and brackets, and temporary blocking of moving parts from switchboard units and components.
- D. Operating Instructions: Frame and mount the printed basic operating instructions for switchboards, including control and key interlocking sequences and emergency procedures. Fabricate frame of finished wood or metal and cover instructions with clear acrylic plastic. Mount on front of switchboards.
- E. Install filler plates in unused spaces of panel-mounted sections.
- F. Install overcurrent protective devices, surge protection devices, and instrumentation.
 - 1. Set field-adjustable switches and circuit-breaker trip ranges.
- G. Comply with NECA 1.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.03 CONNECTIONS

- A. Bond conduits entering underneath the switchboard to the equipment ground bus with a bonding conductor sized per NFPA 70.
- B. Support and secure conductors within the switchboard according to NFPA 70.
- C. Extend insulated equipment grounding cable to busway ground connection and support cable at intervals in vertical run.

3.04 IDENTIFICATION

- A. Identify field-installed conductors, interconnecting wiring, and components; provide warning signs complying with requirements for identification specified in Section 260553 "Identification for Electrical Systems."
- B. Switchboard Nameplates: Label each switchboard compartment with a nameplate complying with requirements for identification specified in Section 260553 "Identification for Electrical Systems."
- C. Device Nameplates: Label each disconnecting and overcurrent protective device and each meter and control device mounted in compartment doors with a nameplate complying with requirements for identification specified in Section 260553 "Identification for Electrical Systems."

3.05 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Tests and Inspections:
 - 1. Acceptance Testing:
 - a. Test insulation resistance for each switchboard bus, component, connecting supply, feeder, and control circuit. Open control and metering circuits within the switchboard, and remove neutral connection to surge protection and other electronic devices prior to insulation test. Reconnect after test.
 - b. Test continuity of each circuit.
 - 2. Test ground-fault protection of equipment for service equipment per NFPA 70.
 - 3. Perform each visual and mechanical inspection and electrical test stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
 - 4. Correct malfunctioning units on-site where possible, and retest to demonstrate compliance; otherwise, replace with new units and retest.
 - 5. Test and adjust controls, remote monitoring, and safeties. Replace damaged and malfunctioning controls and equipment.
- C. Switchboard will be considered defective if it does not pass tests and inspections.
- D. Prepare test and inspection reports, including a certified report that identifies switchboards included and that describes scanning results. Include notation of deficiencies detected, remedial action taken, and observations after remedial action.

3.06 ADJUSTING

- A. Adjust moving parts and operable components to function smoothly, and lubricate as recommended by manufacturer.
- B. Set field-adjustable circuit-breaker trip ranges as specified in Section 260574 Overcurrent Protective Device Arc-Flash Study.

3.07 PROTECTION

- A. Temporary Heating: Apply temporary heat, to maintain temperature according to manufacturer's written instructions, until switchboard is ready to be energized and placed into service.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.08 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain switchboards, overcurrent protective devices, instrumentation, and accessories.

END OF SECTION 262413

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

**SECTION 262416
PANELBOARDS**

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
 - 1. Distribution panelboards.
 - 2. Lighting and appliance branch-circuit panelboards.

1.03 DEFINITIONS

- A. ATS: Acceptance testing specification.
- B. GFCI: Ground-fault circuit interrupter.
- C. GFEP: Ground-fault equipment protection.
- D. MCCB: Molded-case circuit breaker.
- E. SPD: Surge protective device.
- F. VPR: Voltage protection rating.

1.04 ACTION SUBMITTALS

- A. Product Data: For each type of panelboard.
 - 1. Include materials, switching and overcurrent protective devices, SPDs, accessories, and components indicated.
 - 2. Include dimensions and manufacturers' technical data on features, performance, electrical characteristics, ratings, and finishes.
- B. Shop Drawings: For each panelboard and related equipment.
 - 1. Include dimensioned plans, elevations, sections, and details.
 - 2. Detail enclosure types including mounting and anchorage, environmental protection, knockouts, corner treatments, covers and doors, gaskets, hinges, and locks.
 - 3. Detail bus configuration, current, and voltage ratings.
 - 4. Short-circuit current rating of panelboards and overcurrent protective devices.
 - 5. Detail features, characteristics, ratings, and factory settings of individual overcurrent protective devices and auxiliary components.
 - 6. Include wiring diagrams for power, signal, and control wiring.

1.05 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For panelboards and components to include in emergency, operation, and maintenance manuals. In addition to items specified in Section 017823 "Operation and Maintenance Data," include the following:
 - 1. Manufacturer's written instructions for testing and adjusting overcurrent protective devices.
 - 2. Time-current curves, including selectable ranges for each type of overcurrent protective device that allows adjustments.

1.06 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Keys: Two spares for each type of panelboard cabinet lock.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.07 QUALITY ASSURANCE

- A. Source Limitations: Obtain panelboards, overcurrent protective devices, components, and accessories from single source from single manufacturer.
- B. Series rated equipment shall not be used.
- C. Use of "Load-center" type equipment is not acceptable.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Remove loose packing and flammable materials from inside panelboard.

1.09 FIELD CONDITIONS

- A. Environmental Limitations:
 - 1. Do not deliver or install panelboards until spaces are enclosed and weathertight, wet work in spaces is complete and dry, work above panelboards is complete, and temporary HVAC system is operating and maintaining ambient temperature and humidity conditions at occupancy levels during the remainder of the construction period.
 - 2. Rate equipment for continuous operation under the following conditions unless otherwise indicated:
 - a. Ambient Temperature: Not exceeding minus 22 deg F to plus 104 deg F.
 - b. Altitude: Not exceeding 6600 feet.
- B. Service Conditions: NEMA PB 1, usual service conditions, as follows:
 - 1. Ambient temperatures within limits specified.
 - 2. Altitude not exceeding 6600 feet.
- C. Interruption of Existing Electric Service: Do not interrupt electric service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary electric service according to requirements indicated:
 - 1. Notify Construction Manager and Owner no fewer than ten days in advance of proposed interruption of electric service.
 - 2. Do not proceed with interruption of electric service without Owner's written permission.
 - 3. Comply with NFPA 70E.

1.10 WARRANTY

- A. Manufacturer's Warranty: Manufacturer agrees to repair or replace panelboards that fail in materials or workmanship within specified warranty period.
 - 1. Panelboard Warranty Period: **18** months from date of Substantial Completion.

PART 2 PRODUCTS

2.01 PANELBOARDS COMMON REQUIREMENTS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Eaton Corp. Electrical Group.
 - 2. Schneider Electric; Square D
 - 3. General Electric
 - 4. Siemens
- B. Product Selection for Restricted Space: Drawings indicate maximum dimensions for panelboards including clearances between panelboards and adjacent surfaces and other items. Comply with indicated maximum dimensions.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Comply with NEMA PB 1.
- E. Comply with NFPA 70.
- F. Enclosures: Flush or Surface-mounted, dead-front cabinets as indicated on drawings.
 - 1. Rated for environmental conditions at installed location.
 - a. Indoor Dry and Clean Locations: NEMA 250, Type 1.
 - b. Outdoor Locations: NEMA 250, Type 3R.
 - c. Kitchen Areas: NEMA 250, Type 4X, stainless steel.
 - 2. Height: 84 inches maximum.
 - 3. Front: Secured to box with concealed trim clamps. For surface-mounted fronts, match box dimensions; for flush-mounted fronts, overlap box. Trims shall cover all live parts and shall have no exposed hardware.
 - 4. Hinged Front Cover: Entire front trim hinged to box and with standard door within hinged trim cover. Trims shall cover all live parts and shall have no exposed hardware.
 - 5. Skirt for Surface-Mounted Panelboards: Same gage and finish as panelboard front with flanges for attachment to panelboard, wall, and ceiling or floor.
 - 6. Gutter Extension and Barrier: Same gage and finish as panelboard enclosure; integral with enclosure body. Arrange to isolate individual panel sections.
 - 7. Finishes:
 - a. Panels and Trim: Steel, factory finished immediately after cleaning and pretreating with manufacturer's standard two-coat, baked-on finish consisting of prime coat and thermosetting topcoat.
 - b. Back Boxes: Galvanized steel.
- G. Incoming Mains:
 - 1. Location: Top or Bottom.
 - 2. Main Breaker: Main lug interiors up to 400 amperes shall be field convertible to main breaker.
- H. Phase, Neutral, and Ground Buses:
 - 1. Material: Hard-drawn copper, 98 percent conductivity.
 - a. Plating shall run entire length of bus.
 - b. Bus shall be fully rated the entire length.
 - 2. Interiors shall be factory assembled into a unit. Replacing switching and protective devices shall not disturb adjacent units or require removing the main bus connectors.
 - 3. Equipment Ground Bus: Adequate for feeder and branch-circuit equipment grounding conductors; bonded to box.
 - 4. Full-Sized Neutral: Equipped with full-capacity bonding strap for service entrance applications. Mount electrically isolated from enclosure. Do not mount neutral bus in gutter.
- I. Conductor Connectors: Suitable for use with conductor material and sizes.
 - 1. Material: Hard-drawn copper, 98 percent conductivity.
 - 2. Terminations shall allow use of 75 deg C rated conductors without derating.
 - 3. Size: Lugs suitable for indicated conductor sizes, with additional gutter space, if required, for larger conductors.
 - 4. Main and Neutral Lugs: Mechanical type, with a lug on the neutral bar for each pole in the panelboard.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

5. Ground Lugs and Bus-Configured Terminators: Mechanical type, with a lug on the bar for each pole in the panelboard.
6. Feed-Through Lugs: Mechanical type, suitable for use with conductor material. Locate at opposite end of bus from incoming lugs or main device.
7. Subfeed (Double) Lugs: Mechanical type suitable for use with conductor material. Locate at same end of bus as incoming lugs or main device.
- J. Future Devices: Panelboards shall have mounting brackets, bus connections, filler plates, and necessary appurtenances required for future installation of devices.
- K. Panelboard Short-Circuit Current Rating: Fully rated to interrupt symmetrical short-circuit current available at terminals. Assembly listed by an NRTL for 100 percent interrupting capacity.
 1. Panelboards and overcurrent protective devices rated 240 V or less shall have short-circuit ratings as shown on Drawings, but not less than 10,000 A rms symmetrical.

2.02 LIGHTING AND APPLIANCE BRANCH-CIRCUIT PANELBOARDS

- A. Panelboards: NEMA PB 1, lighting and appliance branch-circuit type.
- B. Branch Overcurrent Protective Devices: Bolt-on circuit breakers, replaceable without disturbing adjacent units.
- C. Doors: Concealed hinges; secured with flush latch with tumbler lock; keyed alike.

2.03 DISCONNECTING AND OVERCURRENT PROTECTIVE DEVICES

- A. MCCB: Comply with UL 489, with interrupting capacity to meet available fault currents.
 1. Thermal-Magnetic Circuit Breakers:
 - a. Inverse time-current element for low-level overloads.
 - b. Instantaneous magnetic trip element for short circuits.
 - c. Adjustable magnetic trip setting for circuit-breaker frame sizes 100A up to 400A.
 2. Adjustable Instantaneous-Trip Circuit Breakers: Magnetic trip element with front-mounted, field-adjustable trip setting.
 3. Electronic Trip Circuit Breakers 400A and larger:
 - a. RMS sensing.
 - b. Field-replaceable rating plug or electronic trip.
 - c. Digital display of settings, trip targets, and indicated metering displays.
 - d. Multi-button keypad to access programmable functions and monitored data.
 - e. Ten-event, trip-history log. Each trip event shall be recorded with type, phase, and magnitude of fault that caused the trip.
 - f. Integral test jack for connection to portable test set or laptop computer.
 - g. Field-Adjustable Settings:
 - 1) Instantaneous trip.
 - 2) Long- and short-time pickup levels.
 - 3) Long and short time adjustments.
 - 4) Ground-fault pickup level, time delay, and I squared T response.
 4. GFCI Circuit Breakers: Single- and double-pole configurations with Class A ground-fault protection (6-mA trip).
 5. GFEP Circuit Breakers: Class B ground-fault protection (30-mA trip).
 6. MCCB Features and Accessories:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Standard frame sizes, trip ratings, and number of poles.
 - b. Breaker handle indicates tripped status.
 - c. UL listed for reverse connection without restrictive line or load ratings.
 - d. Lugs: Mechanical style, suitable for number, size, trip ratings, and conductor materials.
 - e. Application Listing: Appropriate for application; Type SWD for switching fluorescent lighting loads; Type HID for feeding fluorescent and HID lighting circuits.
 - f. Shunt Trip: 120-V trip coil energized from separate circuit, set to trip at 75 percent of rated voltage.
 - g. Undervoltage Trip: Set to operate at 35 to 75 percent of rated voltage with field-adjustable 0.1- to 0.6-second time delay.
 - h. Auxiliary Contacts: One, SPDT switch with "a" and "b" contacts; "a" contacts mimic circuit-breaker contacts and "b" contacts operate in reverse of circuit-breaker contacts.
 - i. Alarm Switch: Single-pole, normally open contact that actuates only when circuit breaker trips.
 - j. Key Interlock Kit: Externally mounted to prohibit circuit-breaker operation; key shall be removable only when circuit breaker is in off position.
 - k. Zone-Selective Interlocking: Integral with electronic trip unit; for interlocking ground-fault protection function with other upstream or downstream devices.
 - l. Multipole units enclosed in factory assembled to operate as a single unit. Use of handle ties is not permitted.
 - m. Handle Padlocking Device: Fixed attachment, for locking circuit-breaker handle in on or off position.
 - n. Handle Clamp: Loose attachment, for holding circuit-breaker handle in on position.
7. New Circuit Breakers in Existing Panelboards:
- a. Circuit breakers shall be of standard manufacture and match existing devices.
 - b. Circuit breakers shall have an AIC rating of not less than the lowest rated device in the panelboard.

2.04 IDENTIFICATION

- A. Panelboard Label: Manufacturer's name and trademark, voltage, amperage, number of phases, and number of poles shall be located on the interior of the panelboard door.
- B. Breaker Labels: Faceplate shall list current rating, UL and IEC certification standards, and AIC rating.
- C. Circuit Directory: Computer-generated circuit directory mounted inside panelboard door with transparent plastic protective cover.
 - 1. Circuit directory shall identify specific purpose with detail sufficient to distinguish it from all other circuits.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify actual conditions with field measurements prior to ordering panelboards to verify that equipment fits in allocated space in, and comply with, minimum required clearances specified in NFPA 70.
- B. Receive, inspect, handle, and store panelboards according to NEMA PB 1.1.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Examine panelboards before installation. Reject panelboards that are damaged, rusted, or have been subjected to water saturation.
- D. Examine elements and surfaces to receive panelboards for compliance with installation tolerances and other conditions affecting performance of the Work.
- E. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 INSTALLATION

- A. Coordinate layout and installation of panelboards and components with other construction that penetrates walls or is supported by them, including electrical and other types of equipment, raceways, piping, encumbrances to workspace clearance requirements, and adjacent surfaces. Maintain required workspace clearances and required clearances for equipment access doors and panels.
- B. Comply with NECA 1.
- C. Install panelboards and accessories according to NEMA PB 1.1.
- D. Equipment Mounting:
 - 1. Attach panelboard to the vertical finished or structural surface behind the panelboard.
- E. Temporary Lifting Provisions: Remove temporary lifting eyes, channels, and brackets and temporary blocking of moving parts from panelboards.
- F. Mount top of trim 90 inches above finished floor unless otherwise indicated.
- G. Mount panelboard cabinet plumb and rigid without distortion of box.
- H. Mount recessed panelboards with fronts uniformly flush with wall finish and mating with back box.
- I. Install overcurrent protective devices and controllers not already factory installed.
 - 1. Set field-adjustable, circuit-breaker trip ranges.
 - 2. Tighten bolted connections and circuit breaker connections using calibrated torque wrench or torque screwdriver per manufacturer's written instructions.
- J. Make grounding connections and bond neutral for services and separately derived systems to ground. Make connections to grounding electrodes, separate grounds for isolated ground bars, and connections to separate ground bars.
- K. Install filler plates in unused spaces.
- L. Stub four 1-inch empty conduits from panelboard into accessible ceiling space or space designated to be ceiling space in the future. Stub four 1-inch empty conduits into raised floor space or below slab not on grade.
- M. Arrange conductors in gutters into groups and bundle and wrap with wire ties.

3.03 IDENTIFICATION

- A. Identify field-installed conductors, interconnecting wiring, and components; install warning signs complying with requirements in Section 260553 "Identification for Electrical Systems."
- B. Create a directory to indicate installed circuit loads; incorporate Owner's final room designations. Obtain approval before installing. Handwritten directories are not acceptable. Install directory inside panelboard door.
- C. Panelboard Nameplates: Label each panelboard with a nameplate complying with requirements for identification specified in Section 260553 "Identification for Electrical Systems."
- D. Device Nameplates: Label each branch circuit device in power panelboards with a nameplate complying with requirements for identification specified in Section 260553 "Identification for Electrical Systems."

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.04 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. Acceptance Testing Preparation:
 - 1. Test insulation resistance for each panelboard bus, component, connecting supply, feeder, and control circuit.
 - 2. Test continuity of each circuit.
- C. Tests and Inspections:
 - 1. Perform each visual and mechanical inspection and electrical test for low-voltage air circuit breakers stated in NETA ATS, Paragraph 7.6 Circuit Breakers. Perform optional tests. Certify compliance with test parameters.
 - 2. Correct malfunctioning units on-site, where possible, and retest to demonstrate compliance; otherwise, replace with new units and retest.
- D. Panelboards will be considered defective if they do not pass tests and inspections.
- E. Prepare test and inspection reports, including a certified report that identifies panelboards included and that describes scanning results, with comparisons of the two scans. Include notation of deficiencies detected, remedial action taken, and observations after remedial action.

3.05 ADJUSTING

- A. Adjust moving parts and operable components to function smoothly, and lubricate as recommended by manufacturer.
- A. Set field-adjustable circuit-breaker trip ranges as specified in Section 260574 Overcurrent Protective Device Arc-Flash Study.
- B. Load Balancing: After Substantial Completion, but not more than 60 days after Final Acceptance, measure load balancing and make circuit changes. Prior to making circuit changes to achieve load balancing, inform Architect of effect on phase color coding.
 - 1. Measure loads during period of normal facility operations.
 - 2. Perform circuit changes to achieve load balancing outside normal facility operation schedule or at times directed by the Architect. Avoid disrupting services such as fax machines and on-line data processing, computing, transmitting, and receiving equipment.
 - 3. After changing circuits to achieve load balancing, recheck loads during normal facility operations. Record load readings before and after changing circuits to achieve load balancing.
 - 4. Tolerance: Maximum difference between phase loads, within a panelboard, shall not exceed 20 percent.

3.06 PROTECTION

- A. Temporary Heating: Prior to energizing panelboards, apply temporary heat to maintain temperature according to manufacturer's written instructions.

END OF SECTION 262416

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

This page intentionally left blank

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

**SECTION 262726
WIRING DEVICES**

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
 - 1. Receptacles, receptacles with integral GFCI, and associated device plates.
 - 2. Weather-resistant receptacles
 - 3. Toggle Switches

1.03 DEFINITIONS

- A. EMI: Electromagnetic interference.
- B. GFCI: Ground-fault circuit interrupter.
- C. Pigtail: Short lead used to connect a device to a branch-circuit conductor.
- D. RFI: Radio-frequency interference.

1.04 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1.05 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For wiring devices to include in all manufacturers' packing-label warnings and instruction manuals that include labeling conditions.

PART 2 PRODUCTS

2.01 GENERAL WIRING-DEVICE REQUIREMENTS

- A. Wiring Devices, Components, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and use.
- B. Comply with NFPA 70.
- C. Comply with NEMA WD 1.
- D. Devices that are manufactured for use with modular plug-in connectors may be substituted under the following conditions:
 - 1. Connectors shall comply with UL 2459 and shall be made with stranding building wire.
 - 2. Devices shall comply with requirements in this Section.
- E. Devices for Owner-Furnished Equipment:
 - 1. Receptacles: Match plug configurations.
 - 2. Cord and Plug Sets: Match equipment requirements.
- F. Device Color:
 - 1. Wiring Devices Connected to Normal Power System: Ivory.
- G. Wall Plate Color: For plastic covers, match device color.
- H. Source Limitations: Obtain each type of wiring device and associated wall plate from single source from single manufacturer.

2.02 STANDARD-GRADE RECEPTACLES

- A. Convenience Receptacles, 125 V, 20 A: Heavy duty specification grade complying with NEMA WD 1, NEMA WD 6 Configuration 5-20R, UL 498, and FS W-C-596.
 - 1. Products: Subject to compliance with requirements, provide one of the following:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Cooper; 5351 (single), CR5362 (duplex).
- b. Hubbell; HBL5351 (single), HBL5352 (duplex).
- c. Pass & Seymour; 5361 (single), 5362 (duplex).
- d. Leviton; 5351

2.03 GFCI RECEPTACLES

- A. General Description:
 1. Straight blade, non-feed through type.
 2. Comply with NEMA WD 1, NEMA WD 6, UL 498, UL 943, Class A, and FS W-C-596.
 3. Include correct wiring/trip indicator light.
- B. Duplex GFCI Convenience Receptacles, 125 V, 20 A:
 1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Cooper; VGF20.
 - b. Hubbell; GFR5352L.
 - c. Pass & Seymour; 2095.
 - d. Leviton; 7899-FE

2.04 TOGGLE SWITCHES

- A. Comply with NEMA WD 1, UL 20, and FS W-S-896.
- B. Switches, 120/277 V, 20 A:
 1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Single Pole:
 - 1) Cooper; AH1221.
 - 2) Hubbell; HBL1221.
 - 3) Pass & Seymour; CSB20AC1.
 - 4) Leviton; 1221-2
 - b. Three Way:
 - 1) Cooper; AH1223.
 - 2) Hubbell; HBL1223.
 - 3) Pass & Seymour; CSB20AC3.
 - 4) Leviton; 1223-2

2.05 WALL PLATES

- A. Single and combination types shall match corresponding wiring devices.
 1. Plate-Securing Screws: Metal with head color to match plate finish.
 2. Material: 0.035-inch-thick, satin-finished, Type 302 stainless steel.
- B. Wet-Location, Weatherproof-in-use Cover Plates: NEMA 250, complying with Type 3R, weather-resistant, die-cast aluminum with lockable cover.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Comply with NECA 1, including mounting heights listed in that standard, unless otherwise indicated.
- B. Coordination with Other Trades:
 1. Protect installed devices and their boxes. Do not place wall finish materials over device boxes, and do not cut holes for boxes with routers that are guided by riding against outside of boxes.
 2. Keep outlet boxes free of plaster, drywall joint compound, mortar, cement, concrete, dust, paint, and other material that may contaminate the raceway system, conductors, and cables.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3. Install device boxes in brick or block walls so that the cover plate does not cross a joint unless the joint is troweled flush with the face of the wall.
 4. Install wiring devices after all wall preparation, including painting, is complete.
- C. Conductors:
1. Do not strip insulation from conductors until right before they are spliced or terminated on devices.
 2. Strip insulation evenly around the conductor using tools designed for the purpose. Avoid scoring or nicking of solid wire or cutting strands from stranded wire.
 3. The length of free conductors at outlets for devices shall comply with NFPA 70, Article 300, without pigtails.
- D. Device Installation:
1. Replace devices that have been in temporary use during construction and that were installed before building finishing operations were complete.
 2. Keep each wiring device in its package or otherwise protected until it is time to connect conductors.
 3. Do not remove surface protection, such as plastic film and smudge covers, until the last possible moment.
 4. Connect devices to branch circuits using pigtails that are not less than 6 inches in length.
 5. When there is a choice, use side wiring with binding-head screw terminals. Wrap solid conductor tightly clockwise, two-thirds to three-fourths of the way around terminal screw.
 6. Use a torque screwdriver when a torque is recommended or required by manufacturer.
 7. When conductors larger than No. 12 AWG are installed on 15- or 20-A circuits, splice No. 12 AWG pigtails for device connections.
 8. Tighten unused terminal screws on the device.
 9. When mounting into metal boxes, remove the fiber or plastic washers used to hold device-mounting screws in yokes, allowing metal-to-metal contact.
- E. Receptacle Orientation: Install ground pin of vertically mounted receptacles down, and on horizontally mounted receptacles to the left.
- F. Device Plates: Do not use oversized or extra-deep plates. Repair wall finishes and remount outlet boxes when standard device plates do not fit flush or do not cover rough wall opening.
- G. Arrangement of Devices: Unless otherwise indicated, mount flush, with long dimension vertical and with grounding terminal of receptacles on top. Group adjacent switches under single, multigang wall plates.
- H. Adjust locations of floor service outlets and service poles to suit arrangement of partitions and furnishings.

3.02 GFCI RECEPTACLES

- A. Install non-feed-through GFCI receptacles where protection of downstream receptacles is not required.

3.03 IDENTIFICATION

- A. Comply with Section 260553 "Identification for Electrical Systems."
- B. Identify each receptacle with panelboard identification and circuit number. Use hot, stamped, or engraved machine printing with white-filled lettering on face of plate, and durable wire markers or tags inside outlet boxes.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.04 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections:
 - 1. Test Instruments: Use instruments that comply with UL 1436.
 - 2. Test Instrument for Receptacles: Digital wiring analyzer with digital readout or illuminated digital-display indicators of measurement.
- B. Tests for Receptacles:
 - 1. Line Voltage: Acceptable range is 105 to 132 V.
 - 2. Percent Voltage Drop under 15-A Load: A value of 6 percent or higher is unacceptable.
 - 3. Ground Impedance: Values of up to 2 ohms are acceptable.
 - 4. GFCI Trip: Test for tripping values specified in UL 1436 and UL 943.
 - 5. Using the test plug, verify that the device and its outlet box are securely mounted.
 - 6. Tests shall be diagnostic, indicating damaged conductors, high resistance at the circuit breaker, poor connections, inadequate fault-current path, defective devices, or similar problems. Correct circuit conditions, remove malfunctioning units and replace with new ones, and retest as specified above.
- C. Wiring device will be considered defective if it does not pass tests and inspections.
- D. Prepare test and inspection reports.

END OF SECTION 262726

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 26 2813

FUSES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Cartridge fuses rated 600-V ac and less for use in:
 - a. Control circuits.
 - b. Motor-control centers.
 - c. Panelboards.
 - d. Switchboards.
 - e. Enclosed controllers.
 - f. Enclosed switches.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of product indicated. Include construction details, material, dimensions, descriptions of individual components, and finishes for spare-fuse cabinets. Include the following for each fuse type indicated:

1. Ambient Temperature Adjustment Information: If ratings of fuses have been adjusted to accommodate ambient temperatures, provide list of fuses with adjusted ratings.
 - a. For each fuse having adjusted ratings, include location of fuse, original fuse rating, local ambient temperature, and adjusted fuse rating.
 - b. Provide manufacturer's technical data on which ambient temperature adjustment calculations are based.
2. Dimensions and manufacturer's technical data on features, performance, electrical characteristics, and ratings.
3. Current-limitation curves for fuses with current-limiting characteristics.
4. Time-current coordination curves (average melt) and current-limitation curves (instantaneous peak let-through current) for each type and rating of fuse.
5. Coordination charts and tables and related data.

1.3 CLOSEOUT SUBMITTALS

A. Operation and Maintenance Data: For fuses to include in emergency, operation, and maintenance manuals. In addition to items specified in Division 01, include the following:

1. Ambient temperature adjustment information.
2. Current-limitation curves for fuses with current-limiting characteristics.
3. Time-current coordination curves (average melt) and current-limitation curves (instantaneous peak let-through current) for each type and rating of fuse.
4. Coordination charts and tables and related data.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.4 QUALITY ASSURANCE

- A. Source Limitations: Obtain fuses, for use within a specific product or circuit, from single source from single manufacturer.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by UL and marked for intended location and application.
- C. Comply with NEMA FU 1 for cartridge fuses.
- D. Comply with NFPA 70.

1.5 PROJECT CONDITIONS

- A. Where ambient temperature to which fuses are directly exposed is less than 40 deg F or more than 100 deg F, apply manufacturer's ambient temperature adjustment factors to fuse ratings.

1.6 COORDINATION

- A. Coordinate fuse ratings with utilization equipment nameplate limitations of maximum fuse size and with system short-circuit current levels.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Mersen USA (Ferraz Shawmut)
 - 2. Cooper Bussman, Inc.
- B. The listing of specific manufacturers above does not imply acceptance of their products that do not meet the specified ratings, features and functions. Manufacturers listed above are not relieved from meeting these specifications in their entirety.

2.2 CARTRIDGE FUSES

- A. Characteristics: NEMA FU 1, nonrenewable cartridge fuses with voltage ratings consistent with circuit voltages.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine fuses before installation. Reject fuses that are moisture damaged or physically damaged.
- B. Examine holders to receive fuses for compliance with installation tolerances and other conditions affecting performance, such as rejection features.
- C. Examine utilization equipment nameplates and installation instructions. Install fuses of sizes and with characteristics appropriate for each piece of equipment.
- D. Evaluate ambient temperatures to determine if fuse rating adjustment factors must be applied to fuse ratings.
- E. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 FUSE APPLICATIONS

- A. Provide fuses in accordance with Division 26 Section "Electrical System Studies".
- B. Cartridge Fuses:
 - 1. Motor Branch Circuits: Class RK1, time delay.
 - 2. Other Branch Circuits: Class RK1, time delay.
 - 3. Control Circuits: Class CC, time delay, and control transformer duty.

3.3 INSTALLATION

- A. Install fuses in fusible devices. Arrange fuses so rating information is readable without removing fuse.

3.4 IDENTIFICATION

- A. Install labels complying with requirements for identification specified in Division 26 Section "Identification for Electrical Systems" and indicating fuse replacement information on inside door of each fused switch and adjacent to each fuse block, and holder.

END OF SECTION

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

THIS PAGE IS INTENTIONALLY BLANK

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 262816
ENCLOSED SWITCHES AND CIRCUIT BREAKERS

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
 - 1. Fusible switches.
 - 2. Non-fusible switches.
 - 3. Molded-case circuit breakers (MCCBs).
 - 4. Enclosures.

1.03 DEFINITIONS

- A. NC: Normally closed.
- B. NO: Normally open.
- C. SPDT: Single pole, double throw.

1.04 ACTION SUBMITTALS

- A. Product Data: For each type of enclosed switch, circuit breaker, accessory, and component indicated. Include dimensioned elevations, sections, weights, and manufacturers' technical data on features, performance, electrical characteristics, ratings, accessories, and finishes.
 - 1. Enclosure types and details for types other than NEMA 250, Type 1.
 - 2. Current and voltage ratings.
 - 3. Short-circuit current ratings (interrupting and withstand, as appropriate).
 - 4. Detail features, characteristics, ratings, and factory settings of individual overcurrent protective devices, accessories, and auxiliary components.
 - 5. Include time-current coordination curves (average melt) for each type and rating of overcurrent protective device; include selectable ranges for each type of overcurrent protective device.
- B. Shop Drawings: For enclosed switches and circuit breakers. Include plans, elevations, sections, details, and attachments to other work.
 - 1. Wiring Diagrams: For power, signal, and control wiring.

1.05 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.
 - 1. Test procedures used.
 - 2. Test results that comply with requirements.
 - 3. Results of failed tests and corrective action taken to achieve test results that comply with requirements.

1.06 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For enclosed switches and circuit breakers to include in emergency, operation, and maintenance manuals. In addition to items specified in Division 01 Section "Operation and Maintenance Data," include the following:
 - 1. Manufacturer's written instructions for testing and adjusting enclosed switches and circuit breakers.
 - 2. Time-current coordination curves (average melt) for each type and rating of overcurrent protective device; include selectable ranges for each type of overcurrent protective device.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.07 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Fuses no fewer than three (3) of each size and type.
 - 2. Fuse Pullers: one for each size and type.

1.08 QUALITY ASSURANCE

- A. Source Limitations: Obtain enclosed switches and circuit breakers, overcurrent protective devices, components, and accessories, within same product category, from single source from single manufacturer.
- B. Product Selection for Restricted Space: Drawings indicate maximum dimensions for enclosed switches and circuit breakers, including clearances between enclosures, and adjacent surfaces and other items. Comply with indicated maximum dimensions.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by UL and marked for intended location and application.
- D. Comply with NFPA 70.
- E. Series rated equipment shall not be used.

1.09 PROJECT CONDITIONS

- A. Environmental Limitations: Rate equipment for continuous operation under the following conditions unless otherwise indicated:
 - 1. Ambient Temperature: Not less than minus 22 deg F and not exceeding 104 deg F.
 - 2. Altitude: Not exceeding 6600 feet.

1.10 COORDINATION

- A. Coordinate layout and installation of switches, circuit breakers, and components with equipment served and adjacent surfaces. Maintain required workspace clearances and required clearances for equipment access doors and panels.

PART 2 PRODUCTS

2.01 FUSIBLE SWITCHES

- A. Subject to compliance with requirements, provide products by one of the following:
 - 1. Eaton Corp. Electrical Group.
 - 2. Schneider Electric, Square D
 - 3. General Electric
 - 4. Siemens
- B. Type HD, Heavy Duty, Single Throw, 240 or 600-V ac, 1200 A and Smaller: UL 98 and NEMA KS 1, horsepower rated, with clips or bolt pads to accommodate specified fuses, lockable handle with capability to accept three padlocks, and interlocked with cover in closed position.
- C. Accessories:
 - 1. Equipment Ground Kit: Internally mounted and labeled for copper and aluminum ground conductors.
 - 2. Neutral Kit: Internally mounted; insulated, capable of being grounded and bonded; labeled for copper and aluminum neutral conductors.
 - 3. Isolated Ground Kit: Internally mounted; insulated, capable of being grounded and bonded; labeled for copper and aluminum neutral conductors.
 - 4. Class R Fuse Kit: Provides rejection of other fuse types when Class R fuses are specified.
 - 5. Auxiliary Contact Kit: One NO/NC (Form "C") auxiliary contact(s), arranged to activate before switch blades open.
 - 6. Hookstick Handle: Allows use of a hookstick to operate the handle.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

7. Lugs: Mechanical type, suitable for number, size, and conductor material.
8. Accessory Control Power Voltage: Remote mounted and powered; 120-V ac.

2.02 NONFUSIBLE SWITCHES

- A. Subject to compliance with requirements, provide products by one of the following:
 1. Eaton Corp. Electrical Group.
 2. Schneider Electric, Square D
 3. General Electric
 4. Siemens
- B. Type HD, Heavy Duty, Single Throw, [240] [600]-V ac, 1200 A and Smaller: UL 98 and NEMA KS 1, horsepower rated, lockable handle with capability to accept three padlocks, and interlocked with cover in closed position.
- C. Accessories:
 1. Equipment Ground Kit: Internally mounted and labeled for copper and aluminum ground conductors.
 2. Neutral Kit: Internally mounted; insulated, capable of being grounded and bonded; labeled for copper and aluminum neutral conductors.
 3. Isolated Ground Kit: Internally mounted; insulated, capable of being grounded and bonded; labeled for copper and aluminum neutral conductors.
 4. Auxiliary Contact Kit: One NO/NC (Form "C") auxiliary contact(s), arranged to activate before switch blades open.
 5. Hookstick Handle: Allows use of a hookstick to operate the handle.
 6. Lugs: Mechanical type, suitable for number, size, and conductor material.
 7. Accessory Control Power Voltage: Remote mounted and powered; 120-V ac.

2.03 MOLDED-CASE CIRCUIT BREAKERS

- A. Subject to compliance with requirements, provide products by one of the following:
 1. Eaton Corp. Electrical Group.
 2. Schneider Electric, Square D
 3. General Electric
 4. Siemens
- B. General Requirements: Comply with UL 489, NEMA AB 1, and NEMA AB 3, with interrupting capacity to comply with available fault currents.
- C. Thermal-Magnetic Circuit Breakers: Inverse time-current element for low-level overloads, and instantaneous magnetic trip element for short circuits. Adjustable magnetic trip setting for circuit-breaker frame sizes 250 A up to 400 A.
- D. Adjustable, Instantaneous-Trip Circuit Breakers: Magnetic trip element with front-mounted, field-adjustable trip setting.
- E. Electronic Trip Circuit Breakers: 400 A and larger. Field-replaceable rating plug, rms sensing, with the following field-adjustable settings:
 1. Instantaneous trip.
 2. Long- and short-time pickup levels.
 3. Long- and short-time time delay adjustments.
 4. Ground-fault pickup level, time delay, and I^2t response.
- F. Ground-Fault, Circuit-Interrupter (GFCI) Circuit Breakers: Single- and two-pole configurations with Class A ground-fault protection (6-mA trip).
- G. Ground-Fault, Equipment-Protection (GFEP) Circuit Breakers: Single- and two-pole configurations with Class B ground-fault protection (30-mA trip).
- H. Features and Accessories:
 1. Standard frame sizes, trip ratings, and number of poles.
 2. Lugs: Mechanical type, suitable for number, size, trip ratings, and conductor material.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3. Application Listing: Appropriate for application; Type SWD for switching fluorescent lighting loads; Type HID for feeding fluorescent and high-intensity discharge lighting circuits.
4. Ground-Fault Protection: Comply with UL 1053; integrally mounted, self-powered type with mechanical ground-fault indicator; relay with adjustable pickup and time-delay settings, push-to-test feature, internal memory, and shunt trip unit; and three-phase, zero-sequence current transformer/sensor.
5. Communication Capability: Integral communication module with functions and features compatible with power monitoring and control system, specified in Division 26 Section "Electrical Power Monitoring and Control."
6. Shunt Trip: Trip coil energized from separate circuit, with coil-clearing contact.
7. Undervoltage Trip: Set to operate at 35 to 75 percent of rated voltage without intentional time delay.
8. Auxiliary Contacts: One SPDT switch with "a" and "b" contacts; "a" contacts mimic circuit-breaker contacts, "b" contacts operate in reverse of circuit-breaker contacts.
9. Electrical Operator: Provide remote control for on, off, and reset operations.
10. Accessory Control Power Voltage: Integrally mounted, self-powered.

2.04 ENCLOSURES

- A. Enclosed Switches and Circuit Breakers: NEMA AB 1, NEMA KS 1, NEMA 250, and UL 50, to comply with environmental conditions at installed location.
 1. Indoor, Dry and Clean Locations: NEMA 250, Type 1.
 2. Outdoor Locations: NEMA 250, Type 3R.
 3. Kitchen, Wash-Down Areas, Other Wet or Damp Indoor Locations: NEMA 250, Type 4X, stainless steel.
 4. Indoor Locations Subject to Dust, Falling Dirt, and Dripping Noncorrosive Liquids: NEMA 250, Type 12.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine elements and surfaces to receive enclosed switches and circuit breakers for compliance with installation tolerances and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 INSTALLATION

- A. Install individual wall-mounted switches and circuit breakers with tops at uniform height unless otherwise indicated.
- B. Temporary Lifting Provisions: Remove temporary lifting eyes, channels, and brackets and temporary blocking of moving parts from enclosures and components.
- C. Install wiring between circuit breakers and switches, and facility's EPMC system.
- D. Install fuses in fusible devices in accordance with Division 26 Section "Overcurrent Protective Device Coordination Study".
- E. Provide GFI circuit breakers with 30 mA sensitivity trip for all freeze protection, temperature maintenance, and heat tracing circuits.
- F. Comply with NECA 1.

3.03 IDENTIFICATION

- A. Comply with requirements in Division 26 Section "Identification for Electrical Systems."
 1. Identify field-installed conductors, interconnecting wiring, and components; provide warning signs.
 2. Label each enclosure with engraved laminated-plastic nameplate.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.04 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. Acceptance Testing Preparation:
 - 1. Test insulation resistance for each enclosed switch and circuit breaker, component, connecting supply, feeder, and control circuit.
 - 2. Test continuity of each circuit.
- C. Tests and Inspections:
 - 1. Perform each visual and mechanical inspection and electrical test stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
 - 2. Correct malfunctioning units on-site, where possible, and retest to demonstrate compliance; otherwise, replace with new units and retest.
 - 3. Test and adjust controls, remote monitoring, and safeties. Replace damaged and malfunctioning controls and equipment.
- D. Enclosed switches and circuit breakers will be considered defective if they do not pass tests and inspections.
- E. Prepare test and inspection report, including a certified report that identifies enclosed switches and circuit breakers and that describes scanning results. Include notation of deficiencies detected, remedial action taken and observations after remedial action.

3.05 ADJUSTING

- A. Adjust moving parts and operable components to function smoothly, and lubricate as recommended by manufacturer.
- B. Set field-adjustable circuit-breaker trip ranges as specified in Division 26 Section "Overcurrent Protective Device Coordination Study".

END OF SECTION 262816

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

This page intentionally left blank

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

**SECTION 262913
ENCLOSED CONTROLLERS**

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section includes controllers mounted in a MCC or separately enclosed, rated 600 V and less:
 - 1. Full-voltage manual.
 - 2. Full-voltage magnetic.
- B. Related Section:
 - 1. Division 23 Section "Variable-Frequency Motor Controllers" for general-purpose, ac, adjustable-frequency, pulse-width-modulated controllers for use on variable torque loads in ranges up to 200 hp.

1.03 DEFINITIONS

- A. CPT: Control power transformer.
- B. MCCB: Molded-case circuit breaker.
- C. N.C.: Normally closed.
- D. N.O.: Normally open.
- E. OCPD: Overcurrent protective device.

1.04 ACTION SUBMITTALS

- A. Product Data: For each type of enclosed controller. Include manufacturer's technical data on features, performance, electrical characteristics, ratings, and enclosure types and finishes.
- B. Shop Drawings: For each enclosed controller. Include dimensioned plans, elevations, sections, details, and required clearances and service spaces around controller enclosures.
 - 1. Show tabulations of the following:
 - a. Each installed unit's type and details.
 - b. Factory-installed devices.
 - c. Nameplate legends.
 - d. Short-circuit current rating of integrated unit.
 - e. Listed and labeled for integrated short-circuit current (withstand) rating of OCPD's in combination controllers by an NRTL acceptable to authorities having jurisdiction.
 - f. Features, characteristics, ratings, and factory settings of individual OCPD's in combination controllers.
 - 2. Wiring Diagrams: For power, signal, and control wiring.

1.05 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.
- B. Load-Current and Overload-Relay Heater List: Compile after motors have been installed, and arrange to demonstrate that selection of heaters suits actual motor nameplate full-load currents.

1.06 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For enclosed controllers to include in emergency, operation, and maintenance manuals. In addition to items specified in Division 01 Section "Operation and Maintenance Data," include the following:
 - 1. Routine maintenance requirements for enclosed controllers and installed components.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Manufacturer's written instructions for testing and adjusting circuit breaker and MCCB trip settings.
3. Manufacturer's written instructions for setting field-adjustable overload relays.

1.07 MATERIALS MAINTENANCE SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 1. Fuses for Fused Switches: Equal to 10 percent of quantity installed for each size and type, but no fewer than three of each size and type.
 2. Control Power Fuses: Equal to 10 percent of quantity installed for each size and type, but no fewer than two of each size and type.

1.08 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by UL and marked for intended location and application.
- B. Comply with NFPA 70.
- C. Comply with Owner Design Standards.
- D. Use of IEC rated components is prohibited.
- E. Controllers shall be a minimum of NEMA size 1.

1.09 DELIVERY, STORAGE, AND HANDLING

- A. Store enclosed controllers indoors in clean, dry space with uniform temperature to prevent condensation. Protect enclosed controllers from exposure to dirt, fumes, water, corrosive substances, and physical damage.
- B. If stored in areas subject to weather, cover enclosed controllers to protect them from weather, dirt, dust, corrosive substances, and physical damage. Remove loose packing and flammable materials from inside controllers.

1.10 PROJECT CONDITIONS

- A. Environmental Limitations: Rate equipment for continuous operation under the following conditions unless otherwise indicated:
 1. Ambient Temperature: Not less than minus 22 deg F and not exceeding 104 deg F.
 2. Altitude: Not exceeding 6600 feet.

1.11 COORDINATION

- A. Coordinate layout and installation of enclosed controllers with other construction including conduit, piping, equipment, and adjacent surfaces. Maintain required workspace clearances and required clearances for equipment access doors and panels.
- B. Coordinate sizes and locations of concrete bases with actual equipment provided. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified in Division 03.
- C. Coordinate installation of roof curbs, equipment supports, and roof penetrations.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with requirements, provide products by one of the following:
 1. Eaton Corp. Electrical Group.
 2. Schneider Electric, Square D
 3. General Electric
 4. Siemens

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.02 FULL-VOLTAGE CONTROLLERS

- A. General Requirements for Full-Voltage Controllers: Comply with NEMA ICS 2, general purpose, Class A.
- B. Motor-Starting Switches: "Quick-make, quick-break" toggle or push-button action; marked to show whether unit is off or on.
 - 1. Configuration: Non-reversing.
 - 2. Surface or flush mounting as indicated on drawings.
 - 3. Red "running" pilot light.
- C. Fractional Horsepower Manual Controllers: "Quick-make, quick-break" toggle or push-button action; marked to show whether unit is off, on, or tripped.
 - 1. Configuration: Non-reversing.
 - 2. Overload Relays: Inverse-time-current characteristics; NEMA ICS 2, Class 10 tripping characteristics; heaters matched to nameplate full-load current of actual protected motor; external reset push button; bimetallic type.
 - 3. Flush or Surface mounting.
 - 4. Red "running" pilot light.
- D. Integral Horsepower Manual Controllers: "Quick-make, quick-break" toggle or push-button action; marked to show whether unit is off, on, or tripped.
 - 1. Configuration: Non-reversing.
 - 2. Overload Relays: Inverse-time-current characteristics; NEMA ICS 2, Class 20 tripping characteristics; heaters and sensors in each phase, matched to nameplate full-load current of actual protected motor and having appropriate adjustment for duty cycle; external reset push button; bimetallic type.
 - 3. [Flush] or [Surface] mounting.
 - 4. Red "running" pilot light.
 - 5. N.O. and N.C. auxiliary contact.
- E. Magnetic Controllers: Full voltage, across the line, electrically held.
 - 1. Configuration: Non-reversing.
 - 2. Contactor Coils: Pressure-encapsulated type with coil transient suppressors.
 - a. Operating Voltage: Depending on contactor NEMA size and line-voltage rating, manufacturer's standard matching control power or line voltage.
 - 3. Power Contacts: Totally enclosed, double-break, silver-cadmium oxide; assembled to allow inspection and replacement without disturbing line or load wiring.
 - 4. Control Circuits 120 V ac; obtained from integral CPT, with primary and secondary fuses, with CPT of sufficient capacity to operate integral devices and remotely located pilot, indicating, and control devices.
 - a. CPT Spare Capacity: 100 VA.
 - 5. Bi -Metallic Thermal Overload Relays:
 - a. Inverse-time-current characteristic.
 - b. Class 20 tripping characteristic.
 - c. Heaters in each phase matched to nameplate full-load current of actual protected motor and with appropriate adjustment for duty cycle.
 - d. Isolated alarm contact.
 - 6. External overload reset push button.
- F. Combination Magnetic Controller: Factory-assembled combination of magnetic controller, OCPD, and disconnecting means.
 - 1. MCCB Disconnecting Means:
 - a. UL 489, NEMA AB 1, and NEMA AB 3, with interrupting capacity to comply with available fault currents; thermal-magnetic MCCB, with inverse time-current

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

element for low-level overloads and instantaneous magnetic trip element for short circuits.

- b. Front-mounted, adjustable magnetic trip setting for circuit-breaker frame sizes 250 A and larger.
- c. Lockable Handle: Accepts three padlocks and interlocks with cover in closed position.
- d. Auxiliary contacts "a" and "b" arranged to activate with MCCB handle.

2.03 ENCLOSURES

- A. Separately Mounted Enclosed Controllers: NEMA ICS 6, to comply with environmental conditions at installed location.
 - 1. Dry and Clean Indoor Locations: Type 1.
 - 2. Outdoor Locations: Type 3R.
 - 3. Kitchens, Wash-Down Areas, Other Wet Indoor Locations: Type 4X, stainless steel.
 - 4. Indoor Locations Subject to Dust, Falling Dirt, and Dripping Noncorrosive Liquids: Type 12.

2.04 ACCESSORIES

- A. General Requirements for Control Circuit and Pilot Devices: NEMA ICS 5; factory installed in controller enclosure cover unless otherwise indicated.
 - 1. Push Buttons, Pilot Lights, and Selector Switches: Heavy, oil-tight type.
 - a. Push Buttons: Shrouded types; maintained or momentary as indicated.
 - b. Pilot Lights: LED types; colors as indicated; push to test.
 - c. Selector Switches: Rotary type.
- B. Reversible N.C. /N.O. auxiliary contact(s) as indicated.
- C. Control Relays: Auxiliary and adjustable solid-state time-delay relays as indicated.
- D. Phase-Failure, Phase-Reversal, and Undervoltage and Overvoltage Relays as indicated: Solid-state sensing circuit with isolated output contacts for hard-wired connections. Provide adjustable undervoltage, overvoltage, and time-delay settings.
- E. Breather and drain assemblies, to maintain interior pressure and release condensation in Type 4X, Type 7, Type 9 enclosures installed outdoors or in unconditioned interior spaces subject to humidity and temperature swings.
- F. Cover gaskets for Type 1 enclosures.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine areas and surfaces to receive enclosed controllers, with Installer present, for compliance with requirements and other conditions affecting performance of the Work.
- B. Examine enclosed controllers before installation. Reject enclosed controllers that are wet, moisture damaged, or mold damaged.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 INSTALLATION

- A. Wall-Mounted Controllers: Install enclosed controllers on walls with tops at uniform height unless otherwise indicated, and by mounting on lightweight structural-steel channels bolted to wall. For controllers not at walls, provide freestanding racks complying with Division 26 Section "Hangers and Supports for Electrical Systems."
- B. Floor-Mounted Controllers: Install enclosed controllers on 4-inch nominal-thickness concrete base. Comply with requirements for concrete base specified in Division 03 Sections.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Install dowel rods to connect concrete base to concrete floor. Unless otherwise indicated, install dowel rods on 18-inch centers around the full perimeter of concrete base.
 2. For supported equipment, install epoxy-coated anchor bolts that extend through concrete base and anchor into structural concrete floor.
 3. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
 4. Install anchor bolts to elevations required for proper attachment to supported equipment.
- C. Temporary Lifting Provisions: Remove temporary lifting eyes, channels, and brackets and temporary blocking of moving parts from enclosures and components.
- D. Install fuses in each fusible-switch enclosed controller.
- E. Install fuses in control circuits if not factory installed. Comply with requirements in Division 26 Section "Fuses."
- F. Install heaters in thermal overload relays. Select heaters based on actual nameplate full-load amperes after motors have been installed.
- G. Comply with NECA 1.

3.03 IDENTIFICATION

- A. Identify enclosed controllers, components, and control wiring. Comply with requirements for identification specified in Division 26 Section "Identification for Electrical Systems."
1. Identify field-installed conductors, interconnecting wiring, and components; provide warning signs.
 2. Label each enclosure with engraved nameplate.
 3. Label each enclosure-mounted control and pilot device.

3.04 CONTROL WIRING INSTALLATION

- A. Bundle, train, and support wiring in enclosures.
- B. Connect selector switches and other automatic-control selection devices where applicable.
1. Connect selector switches to bypass only those manual- and automatic-control devices that have no safety functions when switch is in manual-control position.
 2. Connect selector switches with enclosed-controller circuit in both manual and automatic positions for safety-type control devices such as low- and high-pressure cutouts, high-temperature cutouts, and motor overload protectors.

3.05 FIELD QUALITY CONTROL

- A. Tests and Inspections:
1. Inspect controllers, wiring, components, connections, and equipment installation. Test and adjust controllers, components, and equipment.
 2. Test insulation resistance for each enclosed-controller element, component, connecting motor supply, feeder, and control circuits.
 3. Test continuity of each circuit.
 4. Verify that voltages at controller locations are within plus or minus 10 percent of motor nameplate rated voltages.
 5. Test each motor for proper phase rotation.
 6. Perform each electrical test and visual and mechanical inspection stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
 7. Correct malfunctioning units on-site, where possible, and retest to demonstrate compliance; otherwise, replace with new units and retest.
 8. Test and adjust controls, remote monitoring, and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Enclosed controllers will be considered defective if they do not pass tests and inspections.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Prepare test and inspection reports including a certified report that identifies enclosed controllers and that describes scanning results. Include notation of deficiencies detected, remedial action taken and observations after remedial action.

3.06 ADJUSTING

- A. Set field-adjustable switches, auxiliary relays, time-delay relays, timers, and overload-relay pickup and trip ranges.
- B. Adjust overload-relay heaters or settings if power factor correction capacitors are connected to the load side of the overload relays.
- C. Adjust the trip settings of thermal-magnetic circuit breakers with adjustable instantaneous trip elements. Initially adjust to six times the motor nameplate full-load ampere ratings and attempt to start motors several times, allowing for motor cool-down between starts. If tripping occurs on motor inrush, adjust settings in increments until motors start without tripping. Do not exceed eight times the motor full-load amperes (or 11 times for NEMA Premium Efficient motors if required).
- D. Set field-adjustable circuit-breaker trip ranges as specified in Division 26 Section "Overcurrent Protective Device Coordination Study."

3.07 CLEANING

- A. Vacuum dirt and debris; do not use compressed air to assist in cleaning.

3.08 PROTECTION

- A. Replace controllers whose interiors have been exposed to water or other liquids prior to Substantial Completion.

3.09 DEMONSTRATION

- A. Train Owner's maintenance personnel to adjust, operate, and maintain enclosed controllers.

END OF SECTION 262913

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

**SECTION 265119
LED INTERIOR LIGHTING**

PART 1 GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section includes interior solid-state LED luminaires.

1.03 SYSTEM DESCRIPTION

- A. Catalog numbers indicated in the Luminaire Schedule are a design series reference and do not necessarily represent the exact catalog number, size, voltage, wattage, type of light bar, driver, finish trim, ceiling type, mounting hardware or special requirements as specified or as required by the particular installations. Provide complete luminaire to correspond with the features, accessories, number of lamps, wattage and/or size specified in the text description of each luminaire type. Additional features, accessories and options specified shall be included.
- B. Provide all frames, supplementary support structures, hangers, spacers, stems, aligner canopies, auxiliary junction boxes and other hardware as required for a complete and proper installation. Recessed luminaires shall have frames that are compatible with the ceiling systems.
- C. Luminaire voltage shall match the voltage of the circuit serving same.

1.04 DEFINITIONS

- A. CCT: Correlated color temperature.
- B. CRI: Color Rendering Index.
- C. Fixture: See "Luminaire."
- D. IP: International Protection or Ingress Protection Rating.
- E. LED: Light-emitting diode.
- F. Lumen: Measured output of lamp and luminaire, or both.
- G. Luminaire: Complete lighting unit, including lamp, reflector, and housing.

1.05 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Material and physical description of luminaire including dimensions.
 - 2. Energy-efficiency data.
 - 3. Life, output (lumens, CCT, and CRI), Kelvin temperature, and energy-efficiency data for lamps.
 - 4. Photometric data and adjustment factors based on laboratory tests, complying with IESNA Lighting Measurements Testing & Calculation Guides, of each luminaire type. The adjustment factors shall be for light bars, drivers, and accessories identical to those indicated for the luminaire as applied in this Project.
 - a. Testing Agency Certified Data: For indicated luminaires, photometric data shall be certified by a qualified independent testing agency. Photometric data for remaining luminaires shall be certified by manufacturer. LM-79 and LM-80 data for solid state lighting.
 - b. Manufacturer Certified Data: Photometric data shall be certified by a manufacturer's laboratory with a current accreditation under the National Voluntary Laboratory Accreditation Program for Energy Efficient Lighting Products.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

5. Photometric data, certified by a qualified independent testing agency, in IESNA format, based on certified results of laboratory tests of each luminaire type, outfitted with lamps, drivers and accessories identical to those indicated for the luminaire as applied in the Project.
 6. Low voltage transformers.
 7. LED power supplies.
 8. Types of LED's, including manufacturer, wattage, and Color Rendering Index (CRI) and color temperature in degrees Kelvin (K).
- B. Shop Drawings: For nonstandard or custom luminaires.
1. Include plans, elevations, sections, and mounting and attachment details.
 2. Include details of luminaire assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
 3. Include diagrams for power, signal, and control wiring.
- C. Product Schedule: For luminaires and lamps. Use same designations indicated on Drawings.

1.06 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For luminaires and lighting systems to include in operation and maintenance manuals.
1. Provide a list of all lamp types used on Project; use ANSI and manufacturers' codes.

1.07 QUALITY ASSURANCE

- A. Luminaire Photometric Data Testing Laboratory Qualifications: Provided by an independent agency, with the experience and capability to conduct the testing indicated, that is an NRTL as defined by OSHA in 29 CFR 1910.7, accredited under the NVLAP for Energy Efficient Lighting Products, and complying with the applicable IES testing standards.
- B. Provide luminaires from a single manufacturer for each luminaire type.
- C. Each luminaire type shall be binned within a three-step MacAdam Ellipse to ensure color consistency among luminaires.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Protect finishes of exposed surfaces by applying a strippable, temporary protective covering before shipping.

1.09 WARRANTY

- A. Warranty: Manufacturer and Installer agree to repair or replace components of luminaires that fail in materials or workmanship within specified warranty period.
- B. Warranty Period: Five year(s) from date of Substantial Completion.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide products as listed in the Lighting Fixture Schedule or comparable products approved in writing by Owner.

2.02 LUMINAIRE REQUIREMENTS

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Factory-Applied Labels: Comply with UL 1598. Include recommended lamps. Locate labels where they will be readily visible to service personnel, but not seen from normal viewing angles when lamps are in place.
1. Label shall include the following lamp characteristics:
 - a. "USE ONLY" and include specific lamp type.
 - b. Lamp diameter, shape, size, wattage, and coating.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

c. CCT and CRI.

C. Recessed luminaires shall comply with NEMA LE 4.

2.03 LED LUMINAIRES AND DRIVERS

A. All Luminaires

1. Comply with IES LM-79-08 Approved Method for measuring lumen maintenance of LED light sources.
2. Comply with IES LM-80-08 Approved Method for electrical and photometric measurement of SSL product.
3. Comply with In-Situ testing for more reliable results.
4. LED's shall be Restriction of Hazardous Substances Directive (RoHS) compliant.
5. LED arrays shall be sealed, high performance, long life type; minimum 70% rated output at 50,000 hours.
6. LED luminaires shall deliver a minimum of 80 lumens per watt.
 - a. LED's shall be "Bin No. 1" quality.
7. Drivers shall be solid state and accept 120 through 277 VAC at 60 Hz input.
8. The LED light source shall be fully dimmable with use of compatible dimmers switch designated for low voltage loads.
9. LED color temperatures: CRI > 85, 3500 as noted, +/- 275K.
10. Luminaires shall have internal thermal protection.
11. Luminaires shall not draw power in the off state. Luminaires with integral occupancy, motion, photo-controls, or individually addressable luminaires with external control and intelligence are exempt from this requirement. The power draw for such luminaires shall not exceed 0.5 watts when in the off state.
12. Color spatial uniformity shall be within .004 of CIE 1976 diagram.
13. Color maintenance over rated life shall be within .007 of CIE 1976.
14. Indoor luminaires shall have a minimum CRI of 85.
15. Luminaire manufacturers shall adhere to device manufacturer guidelines, certification programs, and test procedures for thermal management
16. LED package(s)/module(s)/array(s) used in qualified luminaires shall deliver a minimum 70% of initial lumens, when installed in-situ, for a minimum of 50,000 hours.
17. Luminaires shall be fully accessible from below ceiling plane for changing drivers, power supplies and arrays.

B. Power Supplies and Drivers

1. Power Factor: 0.90 or higher
2. Maximum driver case temperature not to exceed driver manufacturer recommended in-situ operation.
3. Output operating frequency: 60Hz.
4. Interference: EMI and RFI compliant with FCC 47 CFR Part 15.
5. Total Harmonic Distortion Rating: 20% Maximum.
6. Meet electrical and thermal conditions as described in LM-80 Section 5.0.
7. Fully dimmable, 0 – 10 VDC standard.
8. Secondary Current: Confirm secondary current specified by individual luminaire manufacturers.
9. Compatibility of dimming switches: Certified by manufacturer for use with individually specified luminaire and individually specified control components.

2.04 MATERIALS

A. Metal Parts:

1. Free of burrs and sharp corners and edges.
2. Sheet metal components shall be steel unless otherwise indicated.
3. Form and support to prevent warping and sagging.

B. Steel:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. ASTM A36/A36M for carbon structural steel.
 2. ASTM A568/A568M for sheet steel.
- C. Stainless Steel:
1. 1. Manufacturer's standard grade.
 2. 2. Manufacturer's standard type, ASTM A240/240M.
- D. Galvanized Steel: ASTM A653/A653M.
- E. Aluminum: ASTM B209.

2.05 METAL FINISHES

- A. Variations in finishes are unacceptable in the same piece. Variations in finishes of adjoining components are acceptable if they are within the range of approved Samples and if they can be and are assembled or installed to minimize contrast.

2.06 LUMINAIRE SUPPORT

- A. Comply with requirements in Section 260529 "Hangers and Supports for Electrical Systems" for channel and angle iron supports and nonmetallic channel and angle supports.
- B. Single-Stem Hangers: 1/2-inch steel tubing with swivel ball fittings and ceiling canopy. Finish same as luminaire.
- C. Wires: ASTM A641/A641M, Class 3, soft temper, zinc-coated steel, 12 gage.
- D. Rod Hangers: 3/16-inch minimum diameter, cadmium-plated, threaded steel rod.
- E. Hook Hangers: Integrated assembly matched to luminaire, line voltage, and equipment with threaded attachment, cord, and locking-type plug.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in for luminaire to verify actual locations of luminaire and electrical connections before luminaire installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 INSTALLATION

- A. Comply with NECA 1.
- B. Install luminaires level, plumb, and square with ceilings and walls unless otherwise indicated.
- C. Install lamps in each luminaire.
- D. Supports:
1. Sized and rated for luminaire weight.
 2. Able to maintain luminaire position after cleaning and relamping.
 3. Provide support for luminaire without causing deflection of ceiling or wall.
 4. Luminaire-mounting devices shall be capable of supporting a horizontal force of 100 percent of luminaire weight and a vertical force of 400 percent of luminaire weight.
- E. Flush-Mounted Luminaires:
1. Secured to outlet box.
 2. Attached to ceiling structural members at four points equally spaced around circumference of luminaire.
 3. Trim ring flush with finished surface.
- F. Wall-Mounted Luminaires:
1. Attached to structural members in walls.
 2. Do not attach luminaires directly to gypsum board.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- G. Suspended Luminaires:
 - 1. Ceiling Mount:
 - a. Two 5/32-inch-diameter aircraft cable supports adjustable to 10 feet in length.
 - 2. Pendants and Rods: Where longer than 48 inches, brace to limit swinging.
 - 3. Stem-Mounted, Single-Unit Luminaires: Suspend with twin-stem hangers. Support with approved outlet box and accessories that hold stem and provide damping of luminaire oscillations. Support outlet box vertically to building structure using approved devices.
 - 4. Continuous Rows of Luminaires: Use tubing or stem for wiring at one point and tubing or rod for suspension for each unit length of luminaire chassis, including one at each end.
 - 5. Do not use ceiling grid as support for pendant luminaires. Connect support wires or rods to building structure.
- H. Ceiling-Grid-Mounted Luminaires:
 - 1. Secure to any required outlet box.
 - 2. Secure luminaire to the luminaire opening using approved fasteners in a minimum of two locations, spaced near corners of luminaire.
 - 3. Use approved devices and support components to connect luminaire to ceiling grid and building structure in a minimum of four locations, spaced near corners of luminaire.
- I. Comply with requirements in Section 260519 "Low-Voltage Electrical Power Conductors and Cables" for wiring connections.

3.03 IDENTIFICATION

- A. Identify system components, wiring, cabling, and terminals. Comply with requirements for identification specified in Section 260553 "Identification for Electrical Systems."

3.04 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections:
 - 1. Operational Test: After installing luminaires, switches, and accessories, and after electrical circuitry has been energized, test units to confirm proper operation.
 - 2. Test for Emergency Lighting: Interrupt power supply to demonstrate proper operation. Verify transfer from normal power to battery power and retransfer to normal.
- B. Luminaire will be considered defective if it does not pass operation tests and inspections.
- C. Prepare test and inspection reports.

3.05 CLEANING AND ADJUSTING

- A. Remove protective plastic covers from luminaires and luminaire diffusers only after construction work, painting and clean-up are completed. Remove, clean, and reinstall all dirty lamps, reflectors and diffusers.
- B. Clean luminaires internally and externally after installation. Use methods and materials recommended by manufacturer for cleaning Alzak reflectors and other surfaces.
- C. Make final adjustment of aimable luminaires and adjustable light settings under the direction of the Architect and/or Lighting Designer during a scheduled period of time prior to the completion of the Project, after normal business hours if required. Include all equipment and personnel expenses including overtime required for focusing.
- D. Luminaires, reflectors, louvers and accessories which are damaged, blemished, or impregnated with fingerprints shall be replaced at this Contractor's expense. All finishes shall be unmarred upon Project completion.

END OF SECTION 265119

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 28 31 11

DIGITAL, ADDRESSABLE FIRE ALARM SYSTEM

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
- B. The electrical contractor shall furnish and install a Point-Addressable type manual and automatic fire alarm system in accordance with these specifications and as shown on the project specific documents.
- C. All equipment must be U.L. listed and shall be so labeled. The installation must meet the requirements of applicable codes and the authority having jurisdiction.
- D. The completed system shall be certified on State Fire Marshal Form FM-12A in accordance with Public Act 144.

1.2 DESCRIPTION OF WORK

- A. General: Provide basic materials and methods for electrical work and install in accordance with the Contract Documents.
- B. Major items of work and equipment included under this Section of the Specifications are duct smoke detectors, wiring and supervision for a fully functional fire alarm system, approved by Local Authorities and conforming to applicable code connected to the existing National Time & Signal Fire Alarm Control Panel.

1.3 GENERAL

- A. The contractor is responsible for providing a complete and operational system with certification from the appropriate state and/or local authority having jurisdiction. Electrical drawings and specifications provide minimum requirements for installation of equipment and devices. The bid equipment specified shall be manufactured by National Time and Signal Corporation (800-326-8456) and is of the type and quality required. Alternate manufacturers will not be accepted.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product, including furnished options and accessories.
 - 1. Include construction details, material descriptions, dimensions, profiles, and finishes.
 - 2. Include rated capacities, operating characteristics, and electrical characteristics.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

B. Shop Drawings: For fire-alarm system.

1. Comply with recommendations and requirements in the "Documentation" section of the "Fundamentals" chapter in NFPA 72.
2. Include plans, elevations, sections, details, and attachments to other work.
3. Include details of equipment assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and locations. Indicate conductor sizes, indicate termination locations and requirements, and distinguish between factory and field wiring.
4. Detail assembly and support requirements.
5. Include voltage drop calculations for notification-appliance circuits.
6. Include battery-size calculations.
7. Include input/output matrix.
8. Include statement from manufacturer that all equipment and components have been tested as a system and meet all requirements in this Specification and in NFPA 72.
9. Include performance parameters and installation details for each detector.
10. Verify that each duct detector is listed for complete range of air velocity, temperature, and humidity possible when air-handling system is operating.
11. Provide program report showing that air-sampling detector pipe layout balances pneumatically within the airflow range of the air-sampling detector.
12. Include plans, sections, and elevations of heating, ventilating, and air-conditioning ducts, drawn to scale; coordinate location of duct smoke detectors and access to them.
 - a. Show critical dimensions that relate to placement and support of sampling tubes, detector housing, and remote status and alarm indicators
 - b. Show field wiring required for HVAC unit shutdown on alarm.
 - c. Show field wiring and equipment required for HVAC unit shutdown on alarm and override by firefighters' control system.
 - d. Show field wiring and equipment required for HVAC unit shutdown on alarm and override by firefighters' smoke-evacuation system.
 - e. Locate detectors according to manufacturer's written recommendations.
 - f. Show air-sampling detector pipe routing.
13. Include floor plans to indicate final outlet locations showing address of each addressable device. Show size and route of cable and conduits and point-to-point wiring diagrams.

C. General Submittal Requirements:

1. Submittals shall be approved by authorities having jurisdiction prior to submitting them to Architect.
2. Shop Drawings shall be prepared by persons with the following qualifications:
 - a. Trained and certified by manufacturer in fire-alarm system design.
 - b. NICET-certified, fire-alarm technician; Level III minimum.
 - c. Licensed or certified by authorities having jurisdiction.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.5 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.

1.6 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For fire-alarm systems and components to include in emergency, operation, and maintenance manuals.

- 1. In addition to items specified in Section 01 78 23 "Operation and Maintenance Data," include the following:

- a. Comply with the "Records" section of the "Inspection, Testing and Maintenance" chapter in NFPA 72.
 - b. Provide "Fire Alarm and Emergency Communications System Record of Completion Documents" according to the "Completion Documents" Article in the "Documentation" section of the "Fundamentals" chapter in NFPA 72.
 - c. Complete wiring diagrams showing connections between all devices and equipment. Each conductor shall be numbered at every junction point with indication of origination and termination points.
 - d. Riser diagram.
 - e. Device addresses.
 - f. Air-sampling system sample port locations and modeling program report showing layout meets performance criteria.
 - g. Record copy of site-specific software.
 - h. Provide "Inspection and Testing Form" according to the "Inspection, Testing and Maintenance" chapter in NFPA 72, and include the following:
 - i. Equipment tested.
 - ii. Frequency of testing of installed components.
 - iii. Frequency of inspection of installed components.
 - iv. Requirements and recommendations related to results of maintenance.
 - v. Manufacturer's user training manuals.
 - i. Manufacturer's required maintenance related to system warranty requirements.
 - j. Abbreviated operating instructions for mounting at fire-alarm control unit and each annunciator unit.

1.6 DELIVERY, STORAGE, AND HANDLING:

- A. Fire alarm shall be delivered in its original containers with all necessary parts and manufacturer's label intact and legible. Handle materials with care to prevent damage.

1.7 OPERATION

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- A. The activation of any pull station, smoke detector, duct smoke detector, heat detector, kitchen Ansul, or water flow switch shall cause the following events to occur:
- B. Sound a code 3 temporal pattern signal on all alarm horns.
- C. Flash all system strobes with a synchronized sequence.
- D. List the device and location of the alarm via LCD displays on the control panel and remote annunciator (as indicated by drawings).
- E. Close all smoke barrier doors.
- F. Activate alarm contacts
- G. Activation of any duct smoke detector shall shut down the associated unit.
- H. Log the event in a non-volatile history que.
- I. Silencing of the system will deactivate all audible appliances but the strobes will continue to operate. A subsequent receipt of an alarm condition from any other initiating device will reactivate all audible appliances.
- J. Upon restoring the activated device to its normal condition from alarm condition, a manual reset of the system must be performed to restore the system to normal.
- K. The operation of any system tamper or low-pressure switch will sound a supervisory tone within the control panel and light a dedicated supervisory LED. The supervisory tone may be silenced but a visual indication (LED) will remain active until the condition is cleared a manual reset of the system must be performed to restore the system to normal.
- L. Any wiring disarrangement, open circuit or a ground condition will sound a trouble tone within the control panel, light a dedicated trouble LED and display the fault condition on the main control panel LCD display. Trouble tone may be silenced but a visual indication will remain active until the condition is cleared. Upon correction of the condition, the system shall restore itself to normal.

PART 2 - PRODUCTS

2.1 DUCT SMOKE DETECTORS

- A. Furnish photoelectric addressable duct smoke detectors with appropriate size sampling tubes.
 - 1. Duct smoke detectors must not be mounted on the exterior of the building due to U.L. listed temperature operation of the detector.
- B. The duct detector shall accomplish fan control by use of a control module.
- C. Model No. D900-DD PHOTO

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Furnish ionization addressable duct smoke detectors with appropriate size sampling tubes.
 - 1. Duct smoke detectors must not be mounted on the exterior of the building due to U.L. listed temperature operation of the detector.
- E. The duct detector shall accomplish fan control by use of a control module.
- F. Model No. D900-DD ION

2.7 DUCT DETECTOR REMOTE INDICATOR

- A. Furnish remote alarm indicator for flush mounting to a single gang box. One required for each detector. Alarm indicators shall be mounted 60" A.F.F. or in the ceiling tile below unit when concealed.
- B. Model No. D900-DD RMT LED

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and conditions for compliance with requirements for ventilation, temperature, humidity, and other conditions affecting performance of the Work.
 - 1. Verify that manufacturer's written instructions for environmental conditions have been permanently established in spaces where equipment and wiring are installed, before installation begins.
- B. Examine roughing-in for electrical connections to verify actual locations of connections before installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 EQUIPMENT INSTALLATION

- A. Comply with NFPA 72, NFPA 101, and requirements of authorities having jurisdiction for installation and testing of fire-alarm equipment. Install all electrical wiring to comply with requirements in NFPA 70 including, but not limited to, Article 760, "Fire Alarm Systems."
 - 1. Devices placed in service before all other trades have completed cleanup shall be replaced.
 - 2. Devices installed but not yet placed in service shall be protected from construction dust, debris, dirt, moisture, and damage according to manufacturer's written storage instructions.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- B. Connecting to Existing Equipment: Verify that existing fire-alarm system is operational before making changes or connections.
 - 1. Connect new equipment to existing control panel in existing part of the building.
 - 2. Connect new equipment to existing monitoring equipment at the supervising station.
 - 3. Expand, modify, and supplement existing equipment as necessary to extend existing functions to the new points. New components shall be capable of merging with existing configuration without degrading the performance of either system.
- C. Duct Smoke Detectors: Comply with NFPA 72 and NFPA 90A. Install sampling tubes so they extend the full width of duct. Tubes more than 36 inches long shall be supported at both ends.
 - 1. Do not install smoke detector in duct smoke-detector housing during construction. Install detector only during system testing and prior to system turnover.
- D. Air-Sampling Smoke Detectors: If using multiple pipe runs, the runs shall be pneumatically balanced.
- E. Device Location-Indicating Lights: Locate in public space near the device they monitor.

3.3 PATHWAYS

- A. Pathways above recessed ceilings and in nonaccessible locations shall be installed in EMT.
 - 1. Exposed pathways shall be installed in EMT.

3.4 CONNECTIONS

- B. Make addressable connections with a supervised interface device to the following devices and systems. Install the interface device less than 36 inches from the device controlled. Make an addressable confirmation connection when such feedback is available at the device or system being controlled.

3.5 IDENTIFICATION

- A. Identify system components, wiring, cabling, and terminals. Comply with requirements for identification specified in Section 26 05 53 "Identification for Electrical Systems."
- B. Install framed instructions in a location visible from fire-alarm control unit.

3.6 GROUNDING

- C. Ground shielded cables at the control panel location only. Insulate shield at device location.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.7 FIELD QUALITY CONTROL

- A. Field tests shall be witnessed by authorities having jurisdiction.
- B. Manufacturer's Field Service: Engage a factory-authorized service representative to test and inspect components, assemblies, and equipment installations, including connections.
- C. Perform tests and inspections.
 - 1. Visual Inspection: Conduct visual inspection prior to testing.
 - a. Inspection shall be based on completed record Drawings and system documentation that is required by the "Completion Documents, Preparation" table in the "Documentation" section of the "Fundamentals" chapter in NFPA 72.
 - b. Comply with the "Visual Inspection Frequencies" table in the "Inspection" section of the "Inspection, Testing and Maintenance" chapter in NFPA 72; retain the "Initial/Reacceptance" column and list only the installed components.
 - 2. System Testing: Comply with the "Test Methods" table in the "Testing" section of the "Inspection, Testing and Maintenance" chapter in NFPA 72.
 - 3. Factory-authorized service representative shall prepare the "Fire Alarm System Record of Completion" in the "Documentation" section of the "Fundamentals" chapter in NFPA 72 and the "Inspection and Testing Form" in the "Records" section of the "Inspection, Testing and Maintenance" chapter in NFPA 72.
- D. Reacceptance Testing: Perform reacceptance testing to verify the proper operation of added or replaced devices and appliances.
- E. Fire-alarm system will be considered defective if it does not pass tests and inspections.
- F. Prepare test and inspection reports.

3.8 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain fire-alarm system.

3.9 GUARANTEE / OWNERS MANUALS

- A. The Electrical Contractor shall guarantee all equipment and labor to be free of defects for a period of one year after final acceptance of the system or from the date of beneficial use of any portion thereof by the Owner. This information shall be included in two copies of owner's manuals to be provided to the owner at time of training.

END OF SECTION

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 221616 – NATURAL GAS PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
- B. Specifications throughout all Divisions of the Project Manual are directly applicable to this Section, and this Section is directly applicable to them.

1.2 SUMMARY

- A. Section Includes:
 - 1. Aboveground pipe and fittings from meter and main regulator to building equipment.
 - 2. Piping specialties.
 - 3. Piping and tubing joining materials.
 - 4. Valves.
 - 5. Pressure regulators.

1.3 REFERENCE STANDARDS

- A. The latest published edition of a reference shall be applicable to this Project unless identified by a specific edition date.
- B. All reference amendments adopted prior to the effective date of this Contract shall be applicable to this Project.
- C. All materials, installation and workmanship shall comply with the applicable requirements and standards addressed within the following references:
 - 1. 2015 Edition of the International Fuel Gas Code.
 - 2. Latest Edition of NFPA 54, National Fuel Gas Code.

1.4 PERFORMANCE REQUIREMENTS

- A. Minimum Operating-Pressure Ratings:
 - 1. Piping and Valves: 100 psig minimum unless otherwise indicated.
 - 2. Service Regulators: 100 psig minimum unless otherwise indicated.
- B. Natural-Gas System Pressure within Buildings: 2.0 psig or less

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.5 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Welding certificates.
- C. Field quality-control reports.
- D. Operation and maintenance data.

1.6 QUALITY ASSURANCE

- A. Steel Support Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code - Steel."
- B. Pipe Welding Qualifications: Qualify procedures and operators according to ASME Boiler and Pressure Vessel Code.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- D. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three (3) years documented experience.
- E. Installer Qualifications: Company specializing in performing the Work of this Section with minimum three (3) years documented experience.

1.7 DELIVERY, STORAGE and HANDLING

- A. Accept valves on Site in shipping containers with labeling in place, inspect for damage and store with a minimum of handling. Store plastic piping under cover out of direct sunlight. Do not store materials directly on the ground.
- B. Protect piping systems from entry of foreign materials by temporary covers, completing sections of the work and isolating parts of completed system.

PART 2 - PRODUCTS

2.1 GENERAL

- A. All materials shall meet or exceed all applicable referenced standards, federal, state and local requirements, and conform to codes and ordinances of authorities having jurisdiction.

2.2 PIPES, TUBES, AND FITTINGS

- A. Steel Pipe: ASTM A 53/A 53M, black steel, Schedule 40, Type E or S, Grade B.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Malleable-Iron Threaded Fittings: ASME B16.3, Class 150, standard pattern.
2. Wrought-Steel Welding Fittings: ASTM A 234/A 234M for butt welding and socket welding.
3. Unions: ASME B16.39, Class 150, malleable iron with brass-to-iron seat, ground joint, and threaded ends.

2.3 JOINING MATERIALS

- A. Joint Compound and Tape: Suitable for natural gas.
- B. Welding Filler Metals: Comply with AWS D10.12/D10.12M for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.
- C. Brazing Filler Metals: Alloy with melting point greater than 1000 deg F complying with AWS A5.8/A5.8M. Brazing alloys containing more than 0.05 percent phosphorus are prohibited.

2.4 GAS VALVES

- A. All valves shall be designed, manufactured and approved for natural gas service.
- B. Line Shut-off Valves sizes 2 inches and smaller shall be iron body lubricated plug valve conforming to ASTM-A-126, U.L. Listed and A.G.A. Approved for natural gas service with threaded ends, wrench operation, rated for 200 WOG service pressure and -20 to 200 degrees F., manufactured by Nordstrom Model 142 or equal by Resun or McDonald, A. Y. Mfg. Co.
- C. Line Shut-off Valves sizes 2½ inches and larger shall be iron body lubricated plug valve conforming to ASTM-A-126, U.L. Listed and A.G.A. Approved for natural gas service with flanged ends, wrench operation, rated for 200 WOG service pressure and -20 to 200 degrees F., manufactured by Nordstrom Model 143 or equal by Resun or McDonald, A. Y. Mfg. Co.
- D. Appliance/Equipment Shut-off Valves at local connections sizes 2 inches and smaller shall be bronze body, full port ball or butterfly type, U.L. Listed and A.G.A. Approved for natural gas service with threaded ends, quarter turn lever handle operation, rated for 175 W.O.G. service pressure and 30 to 275 degrees F., manufactured by Nibco Model T585-70-UL or equal by Milwaukee or Apollo.
- E. Manual Emergency Shut-off Valves sizes 2 inches and smaller shall be bronze body, full port ball or butterfly type, U.L. Listed and A.G.A. Approved for natural gas service with threaded ends, quarter turn lever handle operation, rated for 175 W.O.G. service pressure and 30 to 275 degrees F., manufactured by Nibco Model T585-70-UL or equal by Milwaukee or Apollo.
- F. Automatic Emergency Shut-off Valves shall be U.L. Listed F.M. Approved for natural gas service, 2-way electrically tripped solenoid type; fail safe closed; manual reset; Type 1 solenoid enclosure; NBR seals and disc; stainless steel core tube and springs; copper coil; manufactured by ASCO Red Hat Series 8044 or equal by Honeywell or Jefferson.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.5 PRESSURE REGULATORS

A. General Requirements:

1. Single stage and suitable for natural gas.
2. Steel jacket and corrosion-resistant components.
3. Elevation compensator.
4. End Connections: Threaded for regulators NPS 2 and smaller.

B. Appliance Pressure Regulators: Comply with ANSI Z21.18.

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Itron
 - b. Elster American Meter
 - c. Marsh Bellofram - BelGas
2. Body and Diaphragm Case: Die-cast aluminum.
3. Springs: Zinc-plated steel; interchangeable.
4. Diaphragm Plate: Zinc-plated steel.
5. Seat Disc: Nitrile rubber.
6. Seal Plug: Ultraviolet-stabilized, mineral-filled nylon.
7. Factory-Applied Finish: Minimum three-layer polyester and polyurethane paint finish.
8. Regulator may include vent limiting device, instead of vent connection, if approved by authorities having jurisdiction.
9. Maximum Inlet Pressure: 2 psig

2.6 DIELECTRIC UNIONS

A. Dielectric Unions:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Hart Industries International, Inc.
 - b. McDonald, A. Y. Mfg. Co.
 - c. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
 - d. Wilkins; a Zurn company.
2. Description:
 - a. Standard: ASSE 1079.
 - b. Pressure Rating: 125 psig 180 deg F.
 - c. End Connections: Solder-joint copper alloy and threaded ferrous.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

PART 3 - EXECUTION

3.1 OUTDOOR PIPING INSTALLATION

- A. Comply with NFPA 54 for installation and purging of natural-gas piping.
- B. Install underground, natural-gas piping buried at least [36 inches] below finished grade. Comply with requirements in Division 31 Section "Earth Moving" for excavating, trenching, and backfilling.
 - 1. If natural-gas piping is installed less than 36 inches below finished grade, install it in containment conduit.
- C. Install underground, PE, natural-gas piping according to ASTM D 2774.
- D. Install fittings for changes in direction and branch connections.
- E. Install pressure gage downstream from each service regulator. Pressure gages are specified in Division 23 Section "Meters and Gages for HVAC Piping."
- F. Install underground warning tape.

3.2 INDOOR PIPING INSTALLATION

- A. Comply with NFPA 54 for installation and purging of natural-gas piping.
- B. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements are used to size pipe and calculate friction loss, expansion, and other design considerations. Install piping as indicated unless deviations to layout are approved on Coordination Drawings.
- C. Arrange for pipe spaces, chases, slots, sleeves, and openings in building structure during progress of construction, to allow for mechanical installations.
- D. Install piping in concealed locations unless otherwise indicated and except in equipment rooms and service areas.
- E. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- F. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- G. Locate valves for easy access.
- H. Install piping free of sags and bends.
- I. Install fittings for changes in direction and branch connections.
- J. Verify final equipment locations for roughing-in.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- K. Comply with requirements in Sections specifying gas-fired appliances and equipment for roughing-in requirements.
 - L. Drips and Sediment Traps: Install drips at points where condensate may collect, including service-meter outlets. Locate where accessible to permit cleaning and emptying. Do not install where condensate is subject to freezing.
 - 1. Construct drips and sediment traps using tee fitting with bottom outlet plugged or capped. Use nipple a minimum length of 3 pipe diameters, but not less than 3 inches long and same size as connected pipe. Install with space below bottom of drip to remove plug or cap.
 - M. Extend relief vent connections for service regulators, line regulators, and overpressure protection devices to outdoors and terminate with weatherproof vent cap.
 - N. Conceal pipe installations in walls, pipe spaces, utility spaces, above ceilings, unless indicated to be exposed to view.
 - O. Use eccentric reducer fittings to make reductions in pipe sizes. Install fittings with level side down.
 - P. Connect branch piping from top or side of horizontal piping.
 - Q. Install unions in pipes NPS 2 and smaller, adjacent to each valve, at final connection to each piece of equipment.
 - R. Do not use natural-gas piping as grounding electrode.
 - S. Install strainer on inlet of each line-pressure regulator and automatic or electrically operated valve.
 - T. Install pressure gage downstream from each line regulator. Pressure gages are specified in Division 23 Section "Meters and Gages for HVAC Piping."
 - U. Install sleeves for piping penetrations of walls, ceilings, and floors, concrete walls or slabs. Comply with requirements for sleeves specified in Division 23 Section "Common Work Results for HVAC."
 - V. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Division 23 Section "Common Work Results for HVAC."
- 3.3 VALVE INSTALLATION
- A. Install manual gas shutoff valve for each gas appliance.
 - B. Install regulators and overpressure protection devices with maintenance access space adequate for servicing and testing.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.4 PIPING JOINT CONSTRUCTION

- A. Ream ends of pipes and tubes and remove burrs.
- B. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
- C. Threaded Joints:
 - 1. Thread pipe with tapered pipe threads complying with ASME B1.20.1.
 - 2. Cut threads full and clean using sharp dies.
 - 3. Ream threaded pipe ends to remove burrs and restore full inside diameter of pipe.
 - 4. Apply appropriate tape or thread compound to external pipe threads unless dryseal threading is specified.
 - 5. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
- D. Welded Joints:
 - 1. Construct joints according to AWS D10.12/D10.12M, using qualified processes and welding operators.
 - 2. Bevel plain ends of steel pipe.
 - 3. Patch factory-applied protective coating as recommended by manufacturer at field welds and where damage to coating occurs during construction.

3.5 HANGER AND SUPPORT INSTALLATION

- A. Comply with requirements for pipe hangers and supports specified in Division 23 Section "Hangers and Supports for HVAC Piping and Equipment."
- B. Install hangers for horizontal steel piping with the following maximum spacing and minimum rod sizes:
 - 1. NPS 1 and Smaller: Maximum span, 96 inches; minimum rod size, 3/8 inch.
 - 2. NPS 1-1/4: Maximum span, 108 inches; minimum rod size, 3/8 inch.
 - 3. NPS 1-1/2 and NPS 2: Maximum span, 108 inches; minimum rod size, 3/8 inch.

3.6 CONNECTIONS

- A. Connect to utility's gas main after meter and regulator.
- B. Install natural-gas piping electrically continuous, and bonded to gas appliance equipment grounding conductor of the circuit powering the appliance according to NFPA 70.
- C. Install piping adjacent to appliances to allow service and maintenance of appliances.
- D. Connect piping to appliances using manual gas shutoff valves and unions. Install valve within 72 inches of each gas-fired appliance and equipment. Install union between valve and appliances or equipment.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- E. Sediment Traps: Install tee fitting with capped nipple in bottom to form drip, as close as practical to inlet of each appliance.

3.7 LABELING AND IDENTIFYING

- A. Comply with requirements in Division 23 Section "Identification for HVAC Piping and Equipment" for piping and valve identification.

3.8 FIELD QUALITY CONTROL

- A. Test, inspect, and purge natural gas according to NFPA 54 and authorities having jurisdiction.
- B. Natural-gas piping will be considered defective if it does not pass tests and inspections.
- C. Prepare test and inspection reports.

3.9 INDOOR PIPING SCHEDULE

- A. Aboveground, branch & distribution piping NPS 2 and smaller shall the following:
 - 1. Steel pipe with malleable-iron fittings and threaded joints.
 - 2. EXCEPTIONS:
 - a. All exposed piping 1½ inches and smaller located within areas utilized as return air plenums shall have welded joints with Schedule 40 socket welded forged steel fittings conforming to ASME B16.11.
 - b. All exposed piping 1½ inches and smaller serving laboratories from main natural gas riser to each emergency shut-off valve shall have welded joints with Schedule 40 socket welded forged steel fittings conforming to ASME B16.11.
- B. Aboveground, branch & distribution piping larger than NPS 2 shall the following:
 - 1. Steel pipe with wrought-steel fittings and welded joints.

END OF SECTION 221616

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 230500 - COMMON WORK RESULTS FOR HVAC

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:

1. Piping materials and installation instructions common to most piping systems.
2. Dielectric fittings.
3. Mechanical sleeve seals.
4. Sleeves.
5. Escutcheons.
6. Grout.
7. HVAC Demolition.
8. Equipment installation requirements common to equipment sections.
9. Concrete bases.
10. Supports and anchorages.

1.3 DEFINITIONS

- A. Finished Spaces: Spaces other than mechanical and electrical equipment rooms, furred spaces, pipe and duct chases, unheated spaces immediately below roof, spaces above ceilings, unexcavated spaces, crawlspace, and tunnels.
- B. Exposed, Interior Installations: Exposed to view indoors. Examples include finished occupied spaces and mechanical equipment rooms.
- C. Exposed, Exterior Installations: Exposed to view outdoors or subject to outdoor ambient temperatures and weather conditions. Examples include rooftop locations.
- D. Concealed, Interior Installations: Concealed from view and protected from physical contact by building occupants. Examples include above ceilings and chases.
- E. Concealed, Exterior Installations: Concealed from view and protected from weather conditions and physical contact by building occupants but subject to outdoor ambient temperatures. Examples include installations within unheated shelters.
- F. The following are industry abbreviations for rubber materials:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. EPDM: Ethylene-propylene-diene terpolymer rubber.
2. NBR: Acrylonitrile-butadiene rubber.

1.4 REFERENCES AND STANDARDS:

- A. The editions recognized by latest Michigan **Building Code** of the following are hereby included in and made a part of Division 23:

1. NFPA National Fire Protection Association
2. UL Underwriters' Laboratories, Inc.
3. AFI Air Filter Institute
4. NEMA National Electrical Manufacturer's Association
5. NEC National Electric Code
6. ASHRAE American Society of Heating, Refrigeration and Air Conditioning Engineers
7. ARI American Refrigeration Institute
8. AMCA Air Moving and Conditioning Association
9. ASME American Society of Mechanical Engineers
10. AWS American Welding Society
11. ANSI American National Standards Institute
12. AGA American Gas Association
13. SMACNA Sheet Metal and Air Conditioning Contractors National Association
14. HI Hydronics Institute
15. OSHA Occupational Safety and Health Act

1.5 SUBMITTALS

- A. Product Data: For the following:

1. Transition fittings.
2. Dielectric fittings.
3. Mechanical sleeve seals.
4. Escutcheons.

- B. Welding certificates.

1.6 QUALITY ASSURANCE

- A. Steel Support Welding: Qualify processes and operators according to AWS D1.1, "Structural Welding Code--Steel."

- B. Steel Pipe Welding: Qualify processes and operators according to ASME Boiler and Pressure Vessel Code: Section IX, "Welding and Brazing Qualifications."

1. Comply with provisions in ASME B31 Series, "Code for Pressure Piping."
2. Certify that each welder has passed AWS qualification tests for welding processes involved and that certification is current.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Electrical Characteristics for Equipment: Equipment of higher electrical characteristics may be furnished provided such proposed equipment is approved in writing and connecting electrical services, circuit breakers, and conduit sizes are appropriately modified. If minimum energy ratings or efficiencies are specified, equipment shall comply with requirements.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Piping, duct, equipment, and associated accessories kept on-site should be stored off the ground on skids, ends should be capped or sealed, and these items should be covered with plastic to prevent fouling or contact with excessive moisture. Piping, duct, and equipment should be cleaned of debris inside and out before installation and should be kept clean and protected throughout construction.
- B. Store plastic pipes protected from direct sunlight. Support to prevent sagging and bending.

1.8 COORDINATION

- A. Arrange for pipe spaces, chases, slots, and openings in building structure during progress of construction, to allow for HVAC installations.
- B. Coordinate installation of required supporting devices and set sleeves in poured-in-place concrete and other structural components as they are constructed.
- C. Coordinate requirements for access panels and doors for HVAC items requiring access that are concealed behind finished surfaces. Access panels and doors are specified in Division 08 Section "Access Doors and Frames."

PART 2 - PRODUCTS

2.1 EQUIPMENT AND MATERIALS:

- A. All equipment and materials shall be furnished in strict accordance with the equipment named and according to Specification requirements. Each bid shall be based upon one of the materials or manufacturers specified.
- B. Equipment and materials specified shall be considered to have prior approval, but submittal for approval is required. Furnish construction drawings to other Contractors when required to coordinate construction.
- C. Where multiple manufacturers are named the drawings and specifications are based on the requirements and layouts for the equipment of the first named manufacturer. Any change required by the use of other named manufacturers such as revisions to foundations, bases, piping, controls, wiring, openings, and appurtenances shall be made by the Contractor at no additional cost to the Owner.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.2 PIPE, TUBE, AND FITTINGS

- A. Refer to individual Division 23 piping Sections for pipe, tube, and fitting materials and joining methods.
- B. Pipe Threads: ASME B1.20.1 for factory-threaded pipe and pipe fittings.

2.3 JOINING MATERIALS

- A. Refer to individual piping Sections for special joining materials not listed below.
- B. Pipe-Flange Gasket Materials: Suitable for chemical and thermal conditions of piping system contents.
 - 1. ASME B16.21, nonmetallic, flat, asbestos-free, 1/8-inch maximum thickness unless thickness or specific material is indicated.
 - a. Full-Face Type: For flat-face, Class 125, cast-iron and cast-bronze flanges.
 - b. Narrow-Face Type: For raised-face, Class 250, cast-iron and steel flanges.
 - 2. AWWA C110, rubber, flat face, 1/8 inch thick, unless otherwise indicated; and full-face or ring type, unless otherwise indicated.
- C. Plastic, Pipe-Flange Gasket, Bolts, and Nuts: Type and material recommended by piping system manufacturer, unless otherwise indicated.
- D. Flange Bolts and Nuts: ASME B18.2.1, carbon steel, unless otherwise indicated.
- E. Solder Filler Metals: ASTM B 32, 95/5 lead-free alloys. Include water-flushable flux according to ASTM B 813.
- F. Brazing Filler Metals: AWS A5.8, BCuP Series, copper-phosphorus alloys for general-duty brazing, unless otherwise indicated; and AWS A5.8, BAgl, silver alloy for refrigerant piping, unless otherwise indicated.
- G. Welding Filler Metals: Comply with AWS D10.12 for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.
- H. Solvent Cements for Joining Plastic Piping:
 - 1. ABS Piping: ASTM D 2235.
 - 2. CPVC Piping: ASTM F 493.
 - 3. PVC Piping: ASTM D 2564. Include primer according to ASTM F 656.
 - 4. PVC to ABS Piping Transition: ASTM D 3138.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.4 DIELECTRIC FITTINGS

- A. Description: Combination fitting of copper alloy and ferrous materials with threaded, solder-joint, plain, or weld-neck end connections that match piping system materials.
- B. Insulating Material: Suitable for system fluid, pressure, and temperature.
- C. Dielectric Unions: Factory-fabricated, union assembly, for 250-psig minimum working pressure at 180 deg F
- D. Dielectric Flanges: Factory-fabricated, companion-flange assembly, for 150- or 300-psig minimum working pressure as required to suit system pressures.
- E. Dielectric Couplings: Galvanized-steel coupling with inert and non-corrosive, thermoplastic lining; threaded ends; and 300-psig minimum working pressure at 225 deg F
- F. Dielectric Nipples: Electroplated steel nipple with inert and non-corrosive, thermoplastic lining; plain, threaded, or grooved ends; and 300-psig minimum working pressure at 225 deg F

2.5 MECHANICAL SLEEVE SEALS

- A. Description: Modular sealing element unit, designed for field assembly, to fill annular space between pipe and sleeve.
 - 1. Manufacturers:
 - a. Link-Seal.
 - b. Metraflex Co.
 - c. Fernco
 - 2. Sealing Elements: EPDM interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
 - 3. Pressure Plates: Carbon steel. Include two for each sealing element.
 - 4. Connecting Bolts and Nuts: Carbon steel with corrosion-resistant coating of length required to secure pressure plates to sealing elements. Include one for each sealing element.

2.6 SLEEVES

- A. Galvanized-Steel Sheet: 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint.
- B. Steel Pipe: ASTM A 53, Type E, Grade B, Schedule 40, galvanized, plain ends.
- C. Cast Iron: Cast or fabricated "wall pipe" equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop, unless otherwise indicated.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Stack Sleeve Fittings: Manufactured, cast-iron sleeve with integral clamping flange. Include clamping ring and bolts and nuts for membrane flashing.
 - 1. Underdeck Clamp: Clamping ring with set screws.

2.7 ESCUTCHEONS

- A. Description: Manufactured wall and ceiling escutcheons and floor plates, with an ID to closely fit around pipe, tube, and insulation of insulated piping and an OD that completely covers opening.
- B. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with polished chrome-plated finish.
- C. One-Piece, Stamped-Steel Type: With set screw or spring clips and chrome-plated finish.
- D. One-Piece, Cast-Brass Type: With set screw and polished chrome-plated finish
- E. Split-Plate, Stamped-Steel Type: With concealed hinge, set screw or spring clips, and chrome-plated finish.
- F. One-Piece, Floor-Plate Type: Cast-iron floor plate.
- G. Split-Casting, Floor-Plate Type: Cast brass with concealed hinge and set screw.

2.8 GROUT

- A. Description: ASTM C 1107, Grade B, nonshrink and nonmetallic, dry hydraulic-cement grout.
 - 1. Characteristics: Post-hardening, volume-adjusting, nonstaining, noncorrosive, nongaseous, and recommended for interior and exterior applications.
 - 2. Design Mix: 5000-psi, 28-day compressive strength.
 - 3. Packaging: Premixed and factory packaged.

PART 3 - EXECUTION

3.1 HVAC DEMOLITION

- A. Refer to Division 01 Section "Cutting and Patching" and Division 02 Section "Selective Structure Demolition" for general demolition requirements and procedures.
- B. Disconnect, demolish, and remove HVAC systems, equipment, and components indicated to be removed.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.
 2. Piping to Be Abandoned in Place: Drain piping and cap or plug piping with same or compatible piping material.
 3. Ducts to Be Removed: Remove portion of ducts indicated to be removed and plug remaining ducts with same or compatible ductwork material.
 4. Ducts to Be Abandoned in Place: Cap or plug ducts with same or compatible ductwork material.
 5. Equipment to Be Removed: Disconnect and cap services and remove equipment.
 6. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make equipment operational.
 7. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.
- C. If pipe, insulation, or equipment to remain is damaged in appearance or is unserviceable, remove damaged or unserviceable portions and replace with new products of equal capacity and quality.

3.2 PIPING SYSTEMS - COMMON REQUIREMENTS

- A. Install piping according to the following requirements and Division 23 Sections specifying piping systems.
- B. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on Coordination Drawings.
- C. Install piping in concealed locations, unless otherwise indicated and except in equipment rooms and service areas.
- D. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- E. Piping shall not project beyond walls or steel lines nor shall it hang below slabs more than is absolutely necessary. Particular attention shall be paid to the required clearances.
- F. Offset piping where required to avoid interference with other work, to provide greater headroom or clearance, or to conceal pipe more readily. Offsets shall be properly drained or trapped where necessary.
- G. Provide swing joints and expansion bends wherever required to allow the piping to expand without undue stress to connections or equipment.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- H. Exposed piping around fixtures or in other conspicuous places shall not show tool marks at fittings.
- I. Isolate pipe from the building construction to prevent transmission of vibration to the structure and to eliminate noise.
- J. Install piping such that any equipment connected to piping may be removed by disconnecting two (2) flanges or unions and removing only one or two pipe sections. All equipment shall have bolted or screwed flanges or unions at pipe connections.
- K. Install fittings for changes in direction and branch connections. T-drill system for mechanically formed tee connections and couplings, and Victaulic hole cut piping system are not allowed.
- L. Do not route piping through transformer vaults or above transformers, panelboards, or switchboards, including the required service space for this equipment, unless the piping is serving this equipment.
- M. Install groups of pipes parallel to each other, spaced to permit applying insulation and servicing of valves.
- N. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- O. Install piping to permit valve servicing.
- P. Install piping at indicated slopes.
- Q. Install piping free of sags and bends.
- R. Install piping to allow application of insulation.
- S. Cap and plug all openings in pipes during construction with suitable metal plugs or cap to keep out dirt and rubbish until equipment is connected.
- T. Install drains, consisting of a tee fitting, NPS 3/4 full port-ball valve, and short NPS 3/4 threaded nipple with cap, at low points in piping system mains and elsewhere as required for system drainage.
- U. Select system components with pressure rating equal to or greater than system operating pressure.
- V. Install escutcheons for penetrations of walls, ceilings, and floors
- W. All pipes extending through the roof shall be flashed per Architectural details.
- X. Install sleeves for pipes passing through concrete and masonry walls and concrete floor and roof slabs.
 - 1. Sleeves placed in floors shall be flush with the ceiling and shall have planed, square ends, extending 2 inches above the finished floor, unless otherwise specified or detailed.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Where sleeves pass through reinforced concrete floors, they shall be properly set in position before the concrete is poured, and shall be maintained in position by the Contractor until the concrete is set.
 3. Sleeves placed in concrete beams shall be flush with the side of the beam and large enough to accommodate the bare pipe only. All other sleeves shall be of adequate size to accommodate pipe insulation undiminished in size.
 4. Pipes passing through below grade perimeter walls or slabs on grade shall have the space between the pipe and sleeve sealed watertight.
 5. Pipes passing through above grade floor slabs and masonry walls shall have the space between the pipe or insulation and the sleeve packed with non-asbestos wicking or other suitable, approved, non-combustible material.
 6. Pipes passing through walls of Mechanical Equipment Rooms shall be made gas-tight by caulking the space between the pipe and sleeve with a fiber saturated with an approved type of plastic material.
 7. Except for underground wall penetrations, seal annular space between sleeve and pipe or pipe insulation, using joint sealants appropriate for size, depth, and location of joint. Refer to Division 07 Section "Joint Sealants" for materials and installation.
- Y. Aboveground, Exterior-Wall Pipe Penetrations: Seal penetrations using sleeves and mechanical sleeve seals. Select sleeve size to allow for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
1. Install steel pipe for sleeves smaller than 6 inches in diameter.
 2. Install cast-iron "wall pipes" for sleeves 6 inches and larger in diameter.
 3. Mechanical Sleeve Seal Installation: Select type and number of sealing elements required for pipe material and size. Position pipe in center of sleeve. Assemble mechanical sleeve seals and install in annular space between pipe and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.
- Z. Underground, Exterior-Wall Pipe Penetrations: Install cast-iron "wall pipes" for sleeves. Seal pipe penetrations using mechanical sleeve seals. Select sleeve size to allow for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
1. Mechanical Sleeve Seal Installation: Select type and number of sealing elements required for pipe material and size. Position pipe in center of sleeve. Assemble mechanical sleeve seals and install in annular space between pipe and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.
- AA. Fire-Barrier Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with firestop materials. Refer to Division 07 Section "Penetration Firestopping" for materials.
- BB. Verify final equipment locations for roughing-in.
- CC. Refer to equipment specifications in other Sections of these Specifications for roughing-in requirements.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.3 PIPING JOINT CONSTRUCTION

- A. Join pipe and fittings according to the following requirements and Division 23 Sections specifying piping systems.
- B. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- C. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
- D. Soldered Joints: Apply ASTM B 813, water-flushable flux, unless otherwise indicated, to tube end. Construct joints according to ASTM B 828 or CDA's "Copper Tube Handbook," using lead-free solder alloy complying with ASTM B 32.
- E. Brazed Joints: Construct joints according to AWS's "Brazing Handbook," "Pipe and Tube" Chapter, using copper-phosphorus brazing filler metal complying with AWS A5.8.
- F. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
 - 1. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.
 - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
- G. Welded Joints: Construct joints according to AWS D10.12, using qualified processes and welding operators according to Part 1 "Quality Assurance" Article.
- H. Flanged Joints: Select appropriate gasket material, size, type, and thickness for service application. Install gasket concentrically positioned. Use suitable lubricants on bolt threads.
- I. Plastic Piping Solvent-Cement Joints: Clean and dry joining surfaces. Join pipe and fittings according to the following:
 - 1. Comply with ASTM F 402, for safe-handling practice of cleaners, primers, and solvent cements.
 - 2. ABS Piping: Join according to ASTM D 2235 and ASTM D 2661 Appendixes.
 - 3. CPVC Piping: Join according to ASTM D 2846/D 2846M Appendix.
 - 4. PVC Pressure Piping: Join schedule number ASTM D 1785, PVC pipe and PVC socket fittings according to ASTM D 2672. Join other-than-schedule-number PVC pipe and socket fittings according to ASTM D 2855.
 - 5. PVC Nonpressure Piping: Join according to ASTM D 2855.
 - 6. PVC to ABS Nonpressure Transition Fittings: Join according to ASTM D 3138 Appendix.
- J. Plastic Pressure Piping Gasketed Joints: Join according to ASTM D 3139.
- K. Plastic Nonpressure Piping Gasketed Joints: Join according to ASTM D 3212.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- L. PE Piping Heat-Fusion Joints: Clean and dry joining surfaces by wiping with clean cloth or paper towels. Join according to ASTM D 2657.
 - 1. Plain-End Pipe and Fittings: Use butt fusion.
 - 2. Plain-End Pipe and Socket Fittings: Use socket fusion.
 - 3. Fiberglass Bonded Joints: Prepare pipe ends and fittings, apply adhesive, and join according to pipe manufacturer's written instructions.

3.4 PIPING CONNECTIONS

- A. Make connections according to the following, unless otherwise indicated:
 - 1. Install unions, in piping NPS 2 and smaller, adjacent to each valve and at final connection to each piece of equipment.
 - 2. Install flanges, in piping NPS 2-1/2 and larger, adjacent to flanged valves and at final connection to each piece of equipment.
 - 3. Install dielectric fittings to connect piping materials of dissimilar metals.
- B. Unions shall be used in preference to couplings where their use will facilitate dismantling the pipe for maintenance.
- C. Pipe sizes indicated shall be carried full size to equipment served. Any change of size to match equipment connection shall be made within one foot of the equipment. At temperature control valves with sizes smaller than connected lines, reduction shall be made immediately adjacent to valves.

3.5 EQUIPMENT INSTALLATION - COMMON REQUIREMENTS

- A. Install equipment to allow maximum possible headroom unless specific mounting heights are not indicated.
- B. Install equipment level and plumb, parallel and perpendicular to other building systems and components in exposed interior spaces, unless otherwise indicated.
- C. Install HVAC equipment to facilitate service, maintenance, and repair or replacement of components. Connect equipment for ease of disconnecting, with minimum interference to other installations. Extend grease fittings to accessible locations.
- D. Install equipment to allow right of way for piping installed at required slope.

3.6 CONCRETE BASES

- A. Concrete Bases: Anchor equipment to concrete base according to equipment manufacturer's written instructions and according to seismic codes at Project.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Construct concrete bases of dimensions indicated, but not less than 4 inches larger in both directions than supported unit. Install dowel rods to connect concrete base to concrete floor.
2. Unless otherwise indicated, install dowel rods on 18-inch centers around the full perimeter of the base.
3. Install epoxy-coated anchor bolts for supported equipment that extend through concrete base, and anchor into structural concrete floor.
4. Place and secure anchorage devices. Use supported equipment manufacturer's setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
5. Install anchor bolts to elevations required for proper attachment to supported equipment.
6. Install anchor bolts according to anchor-bolt manufacturer's written instructions.
7. Use 3000-psi, 28-day compressive-strength concrete and reinforcement as specified in Division 03 Section "Cast-in-Place Concrete"

3.7 ERECTION OF METAL SUPPORTS AND ANCHORAGES

- A. Refer to Division 05 Section "Metal Fabrications" for structural steel.
- B. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor HVAC materials and equipment.
- C. Field Welding: Comply with AWS D1.1.

3.8 ERECTION OF WOOD SUPPORTS AND ANCHORAGES

- A. Cut, fit, and place wood grounds, nailers, blocking, and anchorages to support, and anchor HVAC materials and equipment.
- B. Select fastener sizes that will not penetrate members if opposite side will be exposed to view or will receive finish materials. Tighten connections between members. Install fasteners without splitting wood members.
- C. Attach to substrates as required to support applied loads.

3.9 GROUTING

- A. Mix and install grout for HVAC equipment base bearing surfaces, pump and other equipment base plates, and anchors.
- B. Clean surfaces that will come into contact with grout.
- C. Provide forms as required for placement of grout.
- D. Avoid air entrapment during placement of grout.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- E. Place grout, completely filling equipment bases.
- F. Place grout on concrete bases and provide smooth bearing surface for equipment.
- G. Place grout around anchors.
- H. Cure placed grout.

END OF SECTION 230500

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 230513 - COMMON MOTOR REQUIREMENTS FOR HVAC EQUIPMENT

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes general requirements for single-phase and polyphase, general-purpose, horizontal, small and medium, squirrel-cage induction motors for use on ac power systems up to 600 V and installed at equipment manufacturer's factory or shipped separately by equipment manufacturer for field installation.

1.2 COORDINATION

- A. Coordinate features of motors, installed units, and accessory devices to be compatible with the following:
 - 1. Motor controllers.
 - 2. Torque, speed, and horsepower requirements of the load.
 - 3. Ratings and characteristics of supply circuit and required control sequence.
 - 4. Ambient and environmental conditions of installation location.

PART 2 - PRODUCTS

2.1 GENERAL MOTOR REQUIREMENTS

- A. Comply with requirements in this Section except when stricter requirements are specified in HVAC equipment schedules or Sections.
- B. Comply with NEMA MG 1 unless otherwise indicated.

2.2 MOTOR CHARACTERISTICS

- A. Duty: Continuous duty at ambient temperature of 40 deg C and at altitude of 3300 feet above sea level.
- B. Capacity and Torque Characteristics: Sufficient to start, accelerate, and operate connected loads at designated speeds, at installed altitude and environment, with indicated operating sequence, and without exceeding nameplate ratings or considering service factor.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.3 POLYPHASE MOTORS

- A. Description: NEMA MG 1, Design B, medium induction motor.
- B. Efficiency: Premium Efficiency, as defined in NEMA MG 1.
- C. Service Factor: 1.15.
- D. Multispeed Motors: Variable torque.
 - 1. For motors with 2:1 speed ratio, consequent pole, single winding.
 - 2. For motors with other than 2:1 speed ratio, separate winding for each speed.
- E. Rotor: Random-wound, squirrel cage.
- F. Bearings: Regreasable, shielded, antifriction ball bearings suitable for radial and thrust loading.
- G. Temperature Rise: Match insulation rating.
- H. Insulation: Class F.
- I. Code Letter Designation:
 - 1. Motors 15 HP and Larger: NEMA starting Code F or Code G.
 - 2. Motors Smaller than 15 HP: Manufacturer's standard starting characteristic.
- J. Enclosure Material: Cast iron for motor frame sizes 324T and larger; rolled steel for motor frame sizes smaller than 324T.

2.4 POLYPHASE MOTORS WITH ADDITIONAL REQUIREMENTS

- A. Motors Used with Reduced-Voltage, Multispeed Controllers: Match wiring connection requirements for controller with required motor leads. Provide terminals in motor terminal box, suited to control method.
- B. Motors Used with Variable Frequency Controllers: (Ratings, characteristics, and features coordinated with and approved by controller manufacturer.)
 - 1. Windings: Copper magnet wire with moisture-resistant insulation varnish, designed and tested to resist transient spikes, high frequencies, and short time rise pulses produced by pulse-width modulated inverters.
 - 2. Inverter-Duty Motors: Class F temperature rise; Class H insulation.
 - 3. Thermal Protection: Comply with NEMA MG 1 requirements for thermally protected motors.
 - 4. Motor manufacture shall ensure specified motor operational and performance characteristics are suitable for inverter drive operation.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

5. Motor shall be provided with minimum of one shaft mounted grounding protection ring to discharge pulse width modulation induced shaft voltages and bearing currents in reducing the effects of bearing pitting and scoring.
6. Motor shall include factory wired internal automatic reset high temperature thermal protector switch wired to oversized motor terminal box.

2.5 SINGLE-PHASE MOTORS

- A. Motors larger than 1/20 hp shall be one of the following, to suit starting torque and requirements of specific motor application:
 1. Permanent-split capacitor.
 2. Split phase.
 3. Capacitor start, inductor run.
 4. Capacitor start, capacitor run.
- B. Multispeed Motors: Variable-torque, permanent-split-capacitor type.
- C. Bearings: Prelubricated, antifriction ball bearings or sleeve bearings suitable for radial and thrust loading.
- D. Motors 1/20 HP and Smaller: Shaded-pole type.
- E. Thermal Protection: Internal protection to automatically open power supply circuit to motor when winding temperature exceeds a safe value calibrated to temperature rating of motor insulation. Thermal-protection device shall automatically reset when motor temperature returns to normal range.

PART 3 - EXECUTION (Not Applicable)

END OF SECTION 230513

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 230553 - IDENTIFICATION FOR HVAC

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Equipment labels.
 - 2. Warning signs and labels.
 - 3. Pipe labels.
 - 4. Duct labels.

1.3 SUBMITTAL

- A. Product Data: For each type of product indicated.

PART 2 - PRODUCTS

2.1 EQUIPMENT LABELS

- A. Metal Labels for Equipment:
 - 1. Material and Thickness: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.
 - 2. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
 - 3. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
 - 4. Fasteners: Stainless-steel rivets or self-tapping screws.
 - 5. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- B. Plastic Labels for Equipment:
 - 1. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Letter Color: White.
 3. Background Color: Black.
 4. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
 5. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
 6. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
 7. Fasteners: Stainless-steel rivets or self-tapping screws.
 8. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- C. Label Content: Include equipment's Drawing designation or unique equipment number, Drawing numbers where equipment is indicated (plans, details, and schedules), plus the Specification Section number and title where equipment is specified.
- D. Equipment Label Schedule: For each item of equipment to be labeled, on 8-1/2-by-11-inch bond paper. Tabulate equipment identification number and identify Drawing numbers where equipment is indicated (plans, details, and schedules), plus the Specification Section number and title where equipment is specified. Equipment schedule shall be included in operation and maintenance data.

2.2 WARNING SIGNS AND LABELS

- A. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
- B. Letter Color: White.
- C. Background Color: Red.
- D. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
- E. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
- F. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- G. Fasteners: Stainless-steel rivets or self-tapping screws.
- H. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- I. Label Content: Include caution and warning information, plus emergency notification instructions.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.3 PIPE LABELS

- A. General Requirements for Manufactured Pipe Labels: Preprinted, color-coded, with lettering indicating service, and showing flow direction.
- B. Pretensioned Pipe Labels: Precoiled, semirigid plastic formed to cover full circumference of pipe and to attach to pipe.
- C. Self-Adhesive Pipe Labels: Printed plastic with contact-type, permanent-adhesive backing.
- D. Pipe Label Contents: Include identification of piping service using same designations or abbreviations as used on Drawings, pipe size, and an arrow indicating flow direction.
 - 1. Flow-Direction Arrows: Integral with piping system service lettering to accommodate both directions, or as separate unit on each pipe label to indicate flow direction.
 - 2. Lettering Size: At least 1-1/2 inches high.

2.4 DUCT LABELS

- A. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
- B. Letter Color: White.
- C. Background Color: Red.
- D. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
- E. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
- F. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- G. Fasteners: Stainless-steel rivets or self-tapping screws.
- H. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- I. Duct Label Contents: Include identification of duct service using same designations or abbreviations as used on Drawings, duct size, and an arrow indicating flow direction.
 - 1. Flow-Direction Arrows: Integral with duct system service lettering to accommodate both directions, or as separate unit on each duct label to indicate flow direction.
 - 2. Lettering Size: At least 1-1/2 inches high.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

PART 3 - EXECUTION

3.1 PREPARATION

- A. Clean piping and equipment surfaces of substances that could impair bond of identification devices, including dirt, oil, grease, release agents, and incompatible primers, paints, and encapsulants.

3.2 EQUIPMENT LABEL INSTALLATION

- A. Install or permanently fasten labels on each major item of mechanical equipment.
- B. Locate equipment labels where accessible and visible.

3.3 PIPE LABEL INSTALLATION

- A. Piping Color-Coding: Painting of piping is specified in Division 09 Section "Interior Painting."
- B. Locate and install pipe labels (pretensioned or self-adhesive) where piping is exposed or above accessible ceilings in finished spaces; machine rooms; accessible maintenance spaces such as shafts, tunnels, and plenums; and exterior exposed locations as follows:
 - 1. Near each valve and control device.
 - 2. Near each branch connection, excluding short takeoffs for fixtures and terminal units. Where flow pattern is not obvious, mark each pipe at branch.
 - 3. Near penetrations through walls, floors, ceilings, and inaccessible enclosures.
 - 4. At access doors, manholes, and similar access points that permit view of concealed piping.
 - 5. Near major equipment items and other points of origination and termination.
 - 6. Spaced at maximum intervals of 50 feet along each run. Reduce intervals to 25 feet in areas of congested piping and equipment.
 - 7. On piping above removable acoustical ceilings. Omit intermediately spaced labels.
- C. Pipe Label Color Schedule:
 - 1. Color coding of piping shall be in accordance with ANSI A13.1.

3.4 DUCT LABEL INSTALLATION

- A. Install self-adhesive duct labels with permanent adhesive on air ducts in the following color codes:
 - 1. Blue: For cold-air supply ducts.
 - 2. Yellow: For hot-air supply ducts.
 - 3. Green: For exhaust-, outside-, relief-, return-, and mixed-air ducts.
 - 4. ASME A13.1 Colors and Designs: For hazardous material exhaust.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- B. Locate labels near points where ducts enter into concealed spaces and at maximum intervals of 50 feet in each space where ducts are exposed or concealed by removable ceiling system.

END OF SECTION 230553

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 230593 - TESTING, ADJUSTING, AND BALANCING

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes testing, adjusting and balancing HVAC systems to provide design conditions as indicated by the associated drawings. This Section includes, but is not limited to the following:
1. Balancing Air Systems - Variable-air-volume systems.
 2. Balancing Hydronic Piping Systems - Variable-flow hydronic systems.
 3. Measuring the electrical performance of HVAC equipment.
 4. Verification that automatic control devices are functioning properly.
 5. Measurement of sound levels as related to rotating mechanical equipment.
 6. Vibration testing and analysis of all rotating equipment greater than or equal to 10 hp.
 7. Measurement of duct leakage.
 8. Reporting results of the activities and procedures specified in this Section.

1.2 DEFINITIONS

- A. AABC: Associated Air Balance Council.
- B. Adjust: To regulate fluid flow rates and air patterns at the system or terminal level. At the system level an example would be reducing fan speed; at the terminal level an example would be changing a damper position.
- C. Balance: To proportion air or water flows within the distribution system, including submains, branches and terminals with respect to design quantities.
- D. Draft: A current of air, when referring to localized effect caused by one or more factors of high air velocity, low ambient temperature, or direction of airflow, whereby more heat is withdrawn from a person's skin than is normally dissipated.
- E. Independent: Not affiliated with or in employment of any Contractor.
- F. NEBB: National Environmental Balancing Bureau.
- G. Procedure: An approach to and execution of a sequence of work operations to yield repeatable results.
- H. Report Forms: Test data sheets for recording test data in logical order.
- I. Static Head: The pressure due to the weight of the fluid above the point of measurement. In a closed system, static head is equal on both sides of the pump.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- J. Suction Head: The height of fluid surface above the centerline of the pump on the suction side.
- K. System Effect: A phenomenon that can create undesired or unpredicted conditions that cause reduced capacities in all or part of a system.
- L. System Effect Factors: Allowances used to calculate a reduction of the performance ratings of a fan when installed under conditions different from those presented when the fan was performance tested.
- M. TAB: Testing, adjusting, and balancing.
- N. TABB: Testing, Adjusting, and Balancing Bureau.
- O. TAB Specialist: An entity engaged to perform TAB Work.
- P. Testing, Adjusting and Balancing (TAB) Agent: The entity responsible for performing and reporting the TAB procedures.
- Q. Terminal: A point where the controlled medium (fluid or energy) enters or leaves the distribution system.

1.3 SUBMITTALS

- A. Strategies and Procedures Plan: Within 60 days of Contractor's Notice to Proceed, submit TAB strategies and step-by-step procedures as specified in "Preparation" Article.
- B. Certified TAB reports.

1.4 QUALITY ASSURANCE

- A. TAB Contractor Qualifications: Engage a TAB entity certified by AABC, NEBB, or TABB.
 - 1. TAB Field Supervisor: Employee of the TAB contractor and certified by AABC, NEBB, or TABB.
 - 2. TAB Technician: Employee of the TAB contractor and who is certified by AABC, NEBB, or TABB as a TAB technician.
- B. Certify TAB field data reports and perform the following:
 - 1. Review field data reports to validate accuracy of data and to prepare certified TAB reports.
 - 2. Certify that the TAB team complied with the approved TAB plan and the procedures specified and referenced in this Specification.
- C. TAB Report Forms: Use standard TAB contractor's forms approved by Architect and Commissioning Authority.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Instrumentation Type, Quantity, Accuracy, and Calibration: As described in ASHRAE 111, Section 5, "Instrumentation."

PART 2 - PRODUCTS (Not Applicable)

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine the Contract Documents to become familiar with Project requirements and to discover conditions in systems' designs that may preclude proper TAB of systems and equipment.
- B. Existing HV units shall be balanced for their CFM as listed on the original building documents.**
- C. Examine systems for installed balancing devices, such as test ports, gage cocks, thermometer wells, flow-control devices, balancing valves and fittings, and manual volume dampers. Verify that locations of these balancing devices are accessible.
- D. Examine the approved submittals for HVAC systems and equipment.
- E. Examine design data including HVAC system descriptions, statements of design assumptions for environmental conditions and systems' output, and statements of philosophies and assumptions about HVAC system and equipment controls.
- F. Examine ceiling plenums and underfloor air plenums used for supply, return, or relief air to verify that they meet the leakage class of connected ducts as specified in Division 23 Section "Metal Ducts" and are properly separated from adjacent areas. Verify that penetrations in plenum walls are sealed and fire-stopped if required.
- G. Examine equipment performance data including fan and pump curves.
1. Relate performance data to Project conditions and requirements, including system effects that can create undesired or unpredicted conditions that cause reduced capacities in all or part of a system.
 2. Calculate system-effect factors to reduce performance ratings of HVAC equipment when installed under conditions different from the conditions used to rate equipment performance. To calculate system effects for air systems, use tables and charts found in AMCA 201, "Fans and Systems," or in SMACNA's "HVAC Systems - Duct Design." Compare results with the design data and installed conditions.
- H. Examine system and equipment installations and verify that field quality-control testing, cleaning, and adjusting specified in individual Sections have been performed.
- I. Examine test reports specified in individual system and equipment Sections.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- J. Examine HVAC equipment and filters and verify that bearings are greased, belts are aligned and tight, and equipment with functioning controls is ready for operation.
- K. Examine terminal units, such as variable-air-volume boxes, and verify that they are accessible and their controls are connected and functioning.
- L. Examine strainers. Verify that startup screens are replaced by permanent screens with indicated perforations.
- M. Examine three-way valves for proper installation for their intended function of diverting or mixing fluid flows.
- N. Examine heat-transfer coils for correct piping connections and for clean and straight fins.
- O. Examine system pumps to ensure absence of entrained air in the suction piping.
- P. Examine operating safety interlocks and controls on HVAC equipment.
- Q. Report deficiencies discovered before and during performance of TAB procedures. Observe and record system reactions to changes in conditions. Record default set points if different from indicated values.

3.2 PREPARATION

- A. Prepare a TAB plan that includes strategies and step-by-step procedures.
- B. Complete system-readiness checks and prepare reports. Verify the following:
 - 1. Permanent electrical-power wiring is complete.
 - 2. Hydronic systems are filled, clean, and free of air.
 - 3. Automatic temperature-control systems are operational.
 - 4. Equipment and duct access doors are securely closed.
 - 5. Balance, smoke, and fire dampers are open.
 - 6. Isolating and balancing valves are open and control valves are operational.
 - 7. Ceilings are installed in critical areas where air-pattern adjustments are required and access to balancing devices is provided.
 - 8. Windows and doors can be closed so indicated conditions for system operations can be met.

3.3 GENERAL PROCEDURES FOR TESTING AND BALANCING

- A. Perform testing and balancing procedures on each system according to the procedures contained in AABC's "National Standards for Total System Balance" or NEBB's "Procedural Standards for Testing, Adjusting, and Balancing of Environmental Systems" or SMACNA's "HVAC Systems - Testing, Adjusting, and Balancing" and in this Section.
 - 1. Comply with requirements in ASHRAE 62.1-2016, Section 7.2.2, "Air Balancing."

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- B. Cut insulation, ducts, pipes, and equipment cabinets for installation of test probes to the minimum extent necessary for TAB procedures.
 - 1. After testing and balancing, patch probe holes in ducts with same material and thickness as used to construct ducts.
 - 2. Install and join new insulation that matches removed materials. Restore insulation, coverings, vapor barrier, and finish according to Division 23 Section "HVAC Insulation."
- C. Mark equipment and balancing devices, including damper-control positions, valve position indicators, fan-speed-control levers, and similar controls and devices, with paint or other suitable, permanent identification material to show final settings.
- D. Take and report testing and balancing measurements in inch-pound (IP) units.

3.4 GENERAL PROCEDURES FOR BALANCING AIR SYSTEMS

- A. Prepare test reports for both fans and outlets. Obtain manufacturer's outlet factors and recommended testing procedures. Crosscheck the summation of required outlet volumes with required fan volumes.
- B. Prepare schematic diagrams of systems' "as-built" duct layouts.
- C. For variable-air-volume systems, develop a plan to simulate diversity.
- D. Determine the best locations in main and branch ducts for accurate duct-airflow measurements.
- E. Check airflow patterns from the outdoor-air louvers and dampers and the return- and exhaust-air dampers through the supply-fan discharge and mixing dampers.
- F. Locate start-stop and disconnect switches, electrical interlocks, and motor starters.
- G. Verify that motor starters are equipped with properly sized thermal protection.
- H. Check dampers for proper position to achieve desired airflow path.
- I. Check for airflow blockages.
- J. Check condensate drains for proper connections and functioning.
- K. Check for proper sealing of air-handling-unit components.
- L. Verify that air duct system is sealed as specified in Division 23 Section "Metal Ducts."

3.5 PROCEDURES FOR CONSTANT-VOLUME AIR SYSTEMS

- A. Adjust fans to deliver total indicated airflows within the maximum allowable fan speed listed by fan manufacturer.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Measure total airflow.
 - a. Where sufficient space in ducts is unavailable for Pitot-tube traverse measurements, measure airflow at terminal outlets and inlets and calculate the total airflow.
 2. Measure fan static pressures as follows to determine actual static pressure:
 - a. Measure outlet static pressure as far downstream from the fan as practical and upstream from restrictions in ducts such as elbows and transitions.
 - b. Measure static pressure directly at the fan outlet or through the flexible connection.
 - c. Measure inlet static pressure of single-inlet fans in the inlet duct as near the fan as possible, upstream from the flexible connection, and downstream from duct restrictions.
 - d. Measure inlet static pressure of double-inlet fans through the wall of the plenum that houses the fan.
 3. Measure static pressure across each component that makes up an air-handling unit, rooftop unit, and other air-handling and -treating equipment.
 - a. Report the cleanliness status of filters and the time static pressures are measured.
 4. Measure static pressures entering and leaving other devices, such as sound traps, heat-recovery equipment, and air washers, under final balanced conditions.
 5. Review Record Documents to determine variations in design static pressures versus actual static pressures. Calculate actual system-effect factors. Recommend adjustments to accommodate actual conditions.
 6. Obtain approval from Engineer for adjustment of fan speed higher or lower than indicated speed. Comply with requirements in Division 23 Sections for air-handling units for adjustment of fans, belts, and pulley sizes to achieve indicated air-handling-unit performance.
 7. Do not make fan-speed adjustments that result in motor overload. Consult equipment manufacturers about fan-speed safety factors. Modulate dampers and measure fan-motor amperage to ensure that no overload will occur. Measure amperage in full-cooling, full-heating, economizer, and any other operating mode to determine the maximum required brake horsepower.
- B. Adjust volume dampers for main duct, submain ducts, and major branch ducts to indicated airflows within specified tolerances.
1. Measure airflow of submain and branch ducts.
 - a. Where sufficient space in submain and branch ducts is unavailable for Pitot-tube traverse measurements, measure airflow at terminal outlets and inlets and calculate the total airflow for that zone.
 2. Measure static pressure at a point downstream from the balancing damper, and adjust volume dampers until the proper static pressure is achieved.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3. Remeasure each submain and branch duct after all have been adjusted. Continue to adjust submain and branch ducts to indicated airflows within specified tolerances.
- C. Measure air outlets and inlets without making adjustments.
1. Measure terminal outlets using a direct-reading hood or outlet manufacturer's written instructions and calculating factors.
- D. Adjust air outlets and inlets for each space to indicated airflows within specified tolerances of indicated values. Make adjustments using branch volume dampers rather than extractors and the dampers at air terminals.
1. Adjust each outlet in same room or space to within specified tolerances of indicated quantities without generating noise levels above the limitations prescribed by the Contract Documents.
 2. Adjust patterns of adjustable outlets for proper distribution without drafts.

3.6 GENERAL PROCEDURES FOR HYDRONIC SYSTEMS

- A. Prepare test reports with pertinent design data, and number in sequence starting at pump to end of system. Check the sum of branch-circuit flows against the approved pump flow rate. Correct variations that exceed plus or minus 5 percent.
- B. Prepare schematic diagrams of systems' "as-built" piping layouts.
- C. Prepare hydronic systems for testing and balancing according to the following, in addition to the general preparation procedures specified above:
1. Open all manual valves for maximum flow.
 2. Check liquid level in expansion tank.
 3. Check makeup water-station pressure gage for adequate pressure for highest vent.
 4. Set differential-pressure control valves at the specified differential pressure. Do not set at fully closed position when pump is positive-displacement type unless several terminal valves are kept open.
 5. Set system controls so automatic valves are wide open to heat exchangers.
 6. Check pump-motor load. If motor is overloaded, throttle main flow-balancing device so motor nameplate rating is not exceeded, or inform Engineer if pump does not have a flow control device at the discharge of the pump.
 7. Check air vents for a forceful liquid flow exiting from vents when manually operated.

3.7 PROCEDURES FOR VARIABLE-FLOW HYDRONIC SYSTEMS

- A. Balance systems with automatic two- and three-way control valves by setting systems at maximum flow through heat-exchange terminals and proceed as specified above for hydronic systems.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.8 Systems installed with pressure independent control valves shall not require full hydronic system balancing. Flow shall be verified for the pressure independent valve assembly (valve and actuator combination) for field conditions using the pressure independent control valve manufacturer's documented procedure for [20%] [50%] [100%] of the total installed product. Exact locations of tested product to be coordinated with the drawings.

3.9 PROCEDURES FOR MOTORS

A. Motors, 1/2 HP and Larger: Test at final balanced conditions and record the following data:

1. Manufacturer's name, model number, and serial number.
2. Motor horsepower rating.
3. Motor rpm.
4. Efficiency rating.
5. Nameplate and measured voltage, each phase, 100% speed.
6. Nameplate and measured amperage, each phase, 100% speed.
7. Starter thermal-protection-element rating.
8. Current limit setting on Variable Frequency Drive.
9. Minimum speed setting on Variable Frequency Drive.

B. Motors Driven by Variable-Frequency Controllers: Test for proper operation at speeds varying from minimum to maximum..Test the manual bypass of the controller to prove proper operation.] Record observations including name of controller manufacturer, model number, serial number, and nameplate data.

- 1.

3.10 PROCEDURES FOR CONDENSING UNITS

- A. Verify proper rotation of fans.
- B. Measure entering- and leaving-air temperatures.
- C. Record compressor data.

3.11 PROCEDURES FOR HEAT-TRANSFER COILS

A. Measure, adjust, and record the following data for each water coil:

1. Entering- and leaving-water temperature.
2. Water flow rate.
3. Water pressure drop.
4. Dry-bulb temperature of entering and leaving air.
5. Wet-bulb temperature of entering and leaving air for cooling coils.
6. Airflow.
7. Air pressure drop.

B. Measure, adjust, and record the following data for each electric heating coil:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Nameplate data.
2. Airflow.
3. Entering- and leaving-air temperature at full load.
4. Voltage and amperage input of each phase at full load and at each incremental stage.
5. Calculated kilowatt at full load.
6. Fuse or circuit-breaker rating for overload protection.

C. Measure, adjust, and record the following data for each steam coil:

1. Dry-bulb temperature of entering and leaving air.
2. Airflow.
3. Air pressure drop.
4. Inlet steam pressure.

D. Measure, adjust, and record the following data for each refrigerant coil:

1. Dry-bulb temperature of entering and leaving air.
2. Wet-bulb temperature of entering and leaving air.
3. Airflow.
4. Air pressure drop.
5. Refrigerant suction pressure and temperature.

3.12 TOLERANCES

A. Set HVAC system's air flow rates and water flow rates within the following tolerances:

1. Supply, Return, and Exhaust Fans and Equipment with Fans: Plus or minus 5 percent.
2. Air Outlets and Inlets: Plus or minus 5 percent.

B. Adjust pumps to within 5% of design GPM at design temperature. Excess pump pressure shall be eliminated by trimming the pump impeller by the Mechanical Contractor (this shall be carried out by the mechanical contractor).

3.13 REPORTING

A. Initial Construction-Phase Report: Based on examination of the Contract Documents as specified in "Examination" Article, prepare a report on the adequacy of design for systems' balancing devices. Recommend changes and additions to systems' balancing devices to facilitate proper performance measuring and balancing. Recommend changes and additions to HVAC systems and general construction to allow access for performance measuring and balancing devices.

B. Status Reports: Prepare bi-weekly progress reports to describe completed procedures, procedures in progress, and scheduled procedures. Include a list of deficiencies and problems found in systems being tested and balanced. Prepare a separate report for each system and each building floor for systems serving multiple floors.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.14 FINAL REPORT

- A. General: Prepare a certified written report; tabulate and divide the report into separate sections for tested systems and balanced systems.
1. Include a certification sheet at the front of the report's binder, signed and sealed by the certified testing and balancing engineer.
 2. Include a list of instruments used for procedures, along with proof of calibration.
- B. Final Report Contents: In addition to certified field-report data, include the following:
1. Pump curves.
 2. Fan curves.
 3. Manufacturers' test data.
 4. Field test reports prepared by system and equipment installers.
 5. Other information relative to equipment performance; do not include Shop Drawings and product data.
- C. General Report Data: In addition to form titles and entries, include the following data:
1. Title page.
 2. Name and address of the TAB contractor.
 3. Project name.
 4. Project location.
 5. Architect's name and address.
 6. Engineer's name and address.
 7. Contractor's name and address.
 8. Report date.
 9. Signature of TAB supervisor who certifies the report.
 10. Table of Contents with the total number of pages defined for each section of the report. Number each page in the report.
 11. Summary of contents including the following:
 - a. Indicated versus final performance.
 - b. Notable characteristics of systems.
 - c. Description of system operation sequence if it varies from the Contract Documents.
 12. Nomenclature sheets for each item of equipment.
 13. Data for terminal units, including manufacturer's name, type, size, and fittings.
 14. Notes to explain why certain final data in the body of reports vary from indicated values.
 15. Test conditions for fans and pump performance forms including the following:
 - a. Settings for outdoor-, return-, and exhaust-air dampers.
 - b. Conditions of filters.
 - c. Cooling coil, wet- and dry-bulb conditions.
 - d. Face and bypass damper settings at coils.
 - e. Fan drive settings including settings and percentage of maximum pitch diameter.
 - f. Inlet vane settings for variable-air-volume systems.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- g. Settings for supply-air, static-pressure controller.
 - h. Settings for differential pressure, hydronic differential control
 - i. Other system operating conditions that affect performance.
- D. System Diagrams: Include schematic layouts of air and hydronic distribution systems. Present each system with single-line diagram and include the following:
- 1. Quantities of outdoor, supply, return, and exhaust airflows.
 - 2. Water and steam flow rates.
 - 3. Duct, outlet, and inlet sizes.
 - 4. Pipe and valve sizes and locations.
 - 5. Terminal units.
 - 6. Balancing stations.
 - 7. Position of balancing devices.

3.15 ADDITIONAL TESTS

- A. Within 90 days of completing TAB, perform additional TAB to verify that balanced conditions are being maintained throughout and to correct unusual conditions.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- B. Seasonal Periods: If initial TAB procedures were not performed during near-peak summer and winter conditions, perform additional TAB during near-peak summer and winter conditions.

END OF SECTION 230593

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 230700 - HVAC INSULATION

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Insulation Materials:
 - a. Flexible elastomeric.
 - b. Mineral fiber.
2. Insulating cements.
3. Adhesives.
4. Mastics.
5. Sealants.
6. Field-applied jackets.
7. Tapes.
8. Securements.
9. Corner angles.

B. Related Sections:

1. Division 22 Section "Plumbing Insulation."
2. Division 23 Section "Metal Ducts" for duct liners.

1.2 SUBMITTALS

A. Product Data: For each type of product indicated.

B. Shop Drawings:

1. Detail application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
2. Detail attachment and covering of heat tracing inside insulation.
3. Detail application of field-applied jackets.
4. Detail field application for each equipment type.

1.3 QUALITY ASSURANCE

- A. Fire-Test-Response Characteristics: Insulation and related materials shall have fire-test-response characteristics indicated, as determined by testing identical products per ASTM E 84, by a testing and inspecting agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing and inspecting agency.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.
- B. Materials and installation in accordance with NFPA 255 and UL 723.
- C. Insulation thickness shall meet the requirements of ASHRAE Standard 90.1.

PART 2 - PRODUCTS

2.1 INSULATION MATERIALS

- A. Comply with requirements in Part 3 schedule articles for where insulating materials shall be applied.
- B. Products shall not contain asbestos, lead, mercury, or mercury compounds.
- C. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871.
- D. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.
- E. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.
- F. Flexible Elastomeric: Closed-cell, sponge- or expanded-rubber materials. Comply with ASTM C 534, Type I for tubular materials and Type II for sheet materials.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Aeroflex USA Inc.; Aerocel.
 - b. Armacell LLC; AP Armaflex.
 - c. RBX Corporation; Insul-Sheet 1800 and Insul-Tube 180.
- G. Mineral-Fiber Blanket Insulation: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 553, Type II and ASTM C 1290, Type III with factory-applied FSK jacket. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. CertainTeed Corp.; Duct Wrap.
 - b. Johns Manville; Microlite.
 - c. Knauf Insulation; Duct Wrap.
 - d. Owens Corning; All-Service Duct Wrap.
- H. Mineral-Fiber Board Insulation: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 612, Type IA or Type IB. For duct and plenum applications, provide

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

insulation with factory-applied FSK jacket. For equipment applications, provide insulation with factory-applied ASJ. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.

1. Products: Subject to compliance with requirements, provide one of the following:
 - a. CertainTeed Corp.; Commercial Board.
 - b. Johns Manville; 800 Series Spin-Glas.
 - c. Knauf Insulation; Insulation Board.
 - d. Owens Corning; Fiberglas 700 Series.

I. Mineral-Fiber, Preformed Pipe Insulation:

1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Johns Manville; Micro-Lok.
 - b. Knauf Insulation; 1000 Pipe Insulation.
 - c. Owens Corning; Fiberglas Pipe Insulation.
2. Type I, 850 deg F Materials: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 547, Type I, Grade A, with factory-applied ASJ. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.

2.2 INSULATING CEMENTS

- A. Mineral-Fiber, Hydraulic-Setting Insulating and Finishing Cement: Comply with ASTM C 449/C 449M.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Insulco, Division of MFS, Inc.; SmoothKote.
 - b. P. K. Insulation Mfg. Co., Inc.; PK No. 127, and Quik-Cote.
 - c. Rock Wool Manufacturing Company; Delta One Shot.

2.3 ADHESIVES

- A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated, unless otherwise indicated.
- B. Adhesives to be waterproof fire-retardant type.
- C. For indoor applications, use adhesive for Flexible Elastomeric, ASJ, and PVC Jacket that has a VOC content of 50 g/L or less and for Mineral-Fiber Adhesive that has a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

2.4 MASTICS

- A. Materials shall be compatible with insulation materials, jackets, and substrates.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.5 SEALANTS

A. Joint Sealants:

1. Materials shall be compatible with insulation materials, jackets, and substrates.
2. Permanently flexible, elastomeric sealant.
3. Service Temperature Range: Minus 100 to plus 300 deg F.
4. For indoor applications, use sealants that have a VOC content of 420 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

B. FSK and Metal Jacket Flashing Sealants:

1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Childers Products, Division of ITW; CP-76-8.
 - b. Foster Products Corporation, H. B. Fuller Company; 95-44.
 - c. Vimasco Corporation; 750.
2. Materials shall be compatible with insulation materials, jackets, and substrates.
3. Fire- and water-resistant, flexible, elastomeric sealant.
4. Service Temperature Range: Minus 40 to plus 250 deg F.
5. Color: Aluminum.

C. ASJ Flashing Sealants, and Vinyl, PVDC, and PVC Jacket Flashing Sealants:

1. Materials shall be compatible with insulation materials, jackets, and substrates.
2. Fire- and water-resistant, flexible, elastomeric sealant.
3. Service Temperature Range: Minus 40 to plus 250 deg F.
4. Color: White.
5. For indoor applications, use sealants that have a VOC content of 420 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

2.6 FACTORY-APPLIED JACKETS

A. Insulation system schedules indicate factory-applied jackets on various applications. When factory-applied jackets are indicated, comply with the following:

1. ASJ: White, kraft-paper, fiberglass-reinforced scrim with aluminum-foil backing; complying with ASTM C 1136, Type I.
2. FSK Jacket: Aluminum-foil, fiberglass-reinforced scrim with kraft-paper backing; complying with ASTM C 1136, Type II.

2.7 FIELD-APPLIED JACKETS

- A. Field-applied jackets shall comply with ASTM C 921, Type I, unless otherwise indicated.
- B. FSK Jacket: Aluminum-foil-face, fiberglass-reinforced scrim with kraft-paper backing.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. PVC Jacket: High-impact-resistant, UV-resistant PVC complying with ASTM D 1784, Class 16354-C; thickness as scheduled; roll stock ready for shop or field cutting and forming. Thickness is indicated in field-applied jacket schedules.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Johns Manville; Zeston.
 - b. P.I.C. Plastics, Inc.; FG Series.
 - c. Proto PVC Corporation; LoSmoke.
 - d. Speedline Corporation; SmokeSafe.
 2. Adhesive: As recommended by jacket material manufacturer.
 3. Color: White.
 4. Factory-fabricated fitting covers to match jacket if available; otherwise, field fabricate.
 - a. Shapes: 45- and 90-degree, short- and long-radius elbows, tees, valves, flanges, unions, reducers, end caps, soil-pipe hubs, traps, mechanical joints, and P-trap and supply covers for lavatories.
 5. Factory-fabricated tank heads and tank side panels.

2.8 TAPES

- A. ASJ Tape: White vapor-retarder tape matching factory-applied jacket with acrylic adhesive, complying with ASTM C 1136.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0835.
 - b. Compac Corp.; 104 and 105.
 - c. Ideal Tape Co., Inc., an American Biltrite Company; 428 AWF ASJ.
 - d. Venture Tape; 1540 CW Plus, 1542 CW Plus, and 1542 CW Plus/SQ.
 2. Width: 3 inches.
 3. Thickness: 11.5 mils.
 4. Adhesion: 90 ounces force/inch in width.
 5. Elongation: 2 percent.
 6. Tensile Strength: 40 lbf/inch in width.
 7. ASJ Tape Disks and Squares: Precut disks or squares of ASJ tape.
- B. FSK Tape: Foil-face, vapor-retarder tape matching factory-applied jacket with acrylic adhesive; complying with ASTM C 1136.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0827.
 - b. Compac Corp.; 110 and 111.
 - c. Ideal Tape Co., Inc., an American Biltrite Company; 491 AWF FSK.
 - d. Venture Tape; 1525 CW, 1528 CW, and 1528 CW/SQ.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Width: 3 inches.
 3. Thickness: 6.5 mils.
 4. Adhesion: 90 ounces force/inch in width.
 5. Elongation: 2 percent.
 6. Tensile Strength: 40 lbf/inch in width.
 7. FSK Tape Disks and Squares: Precut disks or squares of FSK tape.
- C. PVC Tape: White vapor-retarder tape matching field-applied PVC jacket with acrylic adhesive. Suitable for indoor and outdoor applications.
1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0555.
 - b. Compac Corp.; 130.
 - c. Ideal Tape Co., Inc., an American Biltrite Company; 370 White PVC tape.
 - d. Venture Tape; 1506 CW NS.
 2. Width: 2 inches.
 3. Thickness: 6 mils.
 4. Adhesion: 64 ounces force/inch in width.
 5. Elongation: 500 percent.
 6. Tensile Strength: 18 lbf/inch in width.

2.9 SECUREMENTS

- A. Aluminum Bands: ASTM B 209, Alloy 3003, 3005, 3105, or 5005; Temper H-14, 0.020 inch thick, 1/2 inch wide with wing or closed seal.
- B. Insulation Pins and Hangers:
1. Metal, Adhesively Attached, Perforated-Base Insulation Hangers: Baseplate welded to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
 - a. Baseplate: Perforated, galvanized carbon-steel sheet, 0.030 inch thick by 2 inches square.
 - b. Spindle: Copper- or zinc-coated, low carbon steel, fully annealed, 0.106-inch-diameter shank, length to suit depth of insulation indicated.
 - c. Adhesive: Recommended by hanger manufacturer. Product with demonstrated capability to bond insulation hanger securely to substrates indicated without damaging insulation, hangers, and substrates.
 2. Self-Sticking-Base Insulation Hangers: Baseplate welded to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
 - a. Baseplate: Galvanized carbon-steel sheet, 0.030 inch thick by 2 inches square.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- b. Spindle: Copper- or zinc-coated, low carbon steel, fully annealed, 0.106-inch-diameter shank, length to suit depth of insulation indicated.
 - c. Adhesive-backed base with a peel-off protective cover.
3. Insulation-Retaining Washers: Self-locking washers formed from 0.016-inch-thick, galvanized-steel sheet, with beveled edge sized as required to hold insulation securely in place but not less than 1-1/2 inches in diameter.
- a. Protect ends with capped self-locking washers incorporating a spring steel insert to ensure permanent retention of cap in exposed locations.
- C. Wire: 0.062-inch soft-annealed, stainless steel.

2.10 CORNER ANGLES

- A. PVC Corner Angles: 30 mils thick, minimum 1 by 1 inch, PVC according to ASTM D 1784, Class 16354-C. White or color-coded to match adjacent surface.
- B. Aluminum Corner Angles: 0.040 inch thick, minimum 1 by 1 inch, aluminum according to ASTM B 209, Alloy 3003, 3005, 3105 or 5005; Temper H-14.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.
- B. Coordinate insulation installation with the trade installing heat tracing. Comply with requirements for heat tracing that apply to insulation.
- C. Mix insulating cements with clean potable water; if insulating cements are to be in contact with stainless-steel surfaces, use demineralized water.

3.2 GENERAL INSTALLATION REQUIREMENTS

- A. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of equipment, ducts and fittings, and piping including fittings, valves, and specialties.
- B. Install insulation materials, forms, vapor barriers or retarders, jackets, and thicknesses required for each item of equipment, duct system, and pipe system as specified in insulation system schedules.
- C. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- E. Install multiple layers of insulation with longitudinal and end seams staggered.
- F. Do not weld brackets, clips, or other attachment devices to piping, fittings, and specialties.
- G. Keep insulation materials dry during application and finishing.
- H. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- I. Install insulation with least number of joints practical.
- J. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
 - 1. Install insulation continuously through hangers and around anchor attachments.
 - 2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.
 - 3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
 - 4. Cover inserts with jacket material matching adjacent pipe insulation. Install shields over jacket, arranged to protect jacket from tear or puncture by hanger, support, and shield.
- K. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- L. Install insulation with factory-applied jackets as follows:
 - 1. Draw jacket tight and smooth.
 - 2. Cover circumferential joints with 3-inch-wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
 - 3. Overlap jacket longitudinal seams at least 1-1/2 inches. Install insulation with longitudinal seams at bottom of pipe. Clean and dry surface to receive self-sealing lap.
 - 4. Cover joints and seams with tape as recommended by insulation material manufacturer to maintain vapor seal.
 - 5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to duct and pipe flanges and fittings.
- M. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- N. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- O. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

P. For above ambient services, do not install insulation to the following:

1. Vibration-control devices.
2. Testing agency labels and stamps.
3. Nameplates and data plates.
4. Manholes.
5. Handholes.
6. Cleanouts.

3.3 PENETRATIONS

A. Insulation Installation at Roof Penetrations: Install insulation continuously through roof penetrations.

1. Seal penetrations with flashing sealant.
2. For applications requiring only indoor insulation, terminate insulation above roof surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
3. Extend jacket of outdoor insulation outside roof flashing at least 2 inches below top of roof flashing.
4. Seal jacket to roof flashing with flashing sealant.

B. Insulation Installation at Underground Exterior Wall Penetrations: Terminate insulation flush with sleeve seal. Seal terminations with flashing sealant.

C. Insulation Installation at Aboveground Exterior Wall Penetrations: Install insulation continuously through wall penetrations.

1. Seal penetrations with flashing sealant.
2. For applications requiring only indoor insulation, terminate insulation inside wall surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
3. Extend jacket of outdoor insulation outside wall flashing and overlap wall flashing at least 2 inches.
4. Seal jacket to wall flashing with flashing sealant.

D. Insulation Installation at Interior Wall and Partition Penetrations (That Are Not Fire Rated): Install insulation continuously through walls and partitions.

E. Insulation Installation at Fire-Rated Wall and Partition Penetrations: Install insulation continuously through penetrations of fire-rated walls and partitions. Terminate insulation at fire damper sleeves for fire-rated wall and partition penetrations. Externally insulate damper sleeves to match adjacent insulation and overlap duct insulation at least 2 inches.

1. Comply with requirements in Division 07 Section "Penetration Firestopping" firestopping and fire-resistive joint sealers.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

F. Insulation Installation at Floor Penetrations:

1. Duct: Install insulation continuously through floor penetrations that are not fire rated. For penetrations through fire-rated assemblies, terminate insulation at fire damper sleeves and externally insulate damper sleeve beyond floor to match adjacent duct insulation. Overlap damper sleeve and duct insulation at least 2 inches.
2. Pipe: Install insulation continuously through floor penetrations.
3. Seal penetrations through fire-rated assemblies. Comply with requirements in Division 07 Section "Penetration Firestopping."

G. Insulation Installation on Pumps:

1. Fabricate metal boxes lined with insulation. Fit boxes around pumps and coincide box joints with splits in pump casings. Fabricate joints with outward bolted flanges. Bolt flanges on 6-inch centers, starting at corners. Install 3/8-inch-diameter fasteners with wing nuts. Alternatively, secure the box sections together using a latching mechanism.
2. Fabricate boxes from aluminum, at least 0.050 inch thick.
3. For below ambient services, install a vapor barrier at seams, joints, and penetrations. Seal between flanges with replaceable gasket material to form a vapor barrier.

3.4 GENERAL PIPE INSULATION INSTALLATION

A. Requirements in this article generally apply to all insulation materials except where more specific requirements are specified in various pipe insulation material installation articles.

B. Insulation Installation on Fittings, Valves, Strainers, Flanges, and Unions:

1. Install insulation over fittings, valves, strainers, flanges, unions, and other specialties with continuous thermal and vapor-retarder integrity, unless otherwise indicated.
2. Insulate pipe elbows using preformed fitting insulation or mitered fittings made from same material and density as adjacent pipe insulation. Each piece shall be butted tightly against adjoining piece and bonded with adhesive. Fill joints, seams, voids, and irregular surfaces with insulating cement finished to a smooth, hard, and uniform contour that is uniform with adjoining pipe insulation.
3. Insulate tee fittings with preformed fitting insulation or sectional pipe insulation of same material and thickness as used for adjacent pipe. Cut sectional pipe insulation to fit. Butt each section closely to the next and hold in place with tie wire. Bond pieces with adhesive.
4. Insulate valves using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. For valves, insulate up to and including the bonnets, valve stuffing-box studs, bolts, and nuts. Fill joints, seams, and irregular surfaces with insulating cement.
5. Insulate strainers using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. Fill joints, seams, and irregular surfaces with insulating cement. Insulate strainers so strainer basket flange or plug can be easily removed and

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

replaced without damaging the insulation and jacket. Provide a removable reusable insulation cover. For below ambient services, provide a design that maintains vapor barrier.

6. Insulate flanges and unions using a section of oversized preformed pipe insulation. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker.
 7. Cover segmented insulated surfaces with a layer of finishing cement and coat with a mastic. Install vapor-barrier mastic for below ambient services and a breather mastic for above ambient services. Reinforce the mastic with fabric-reinforcing mesh. Trowel the mastic to a smooth and well-shaped contour.
 8. For services not specified to receive a field-applied jacket except for flexible elastomeric, install fitted PVC cover over elbows, tees, strainers, valves, flanges, and unions. Terminate ends with PVC end caps. Tape PVC covers to adjoining insulation facing using PVC tape.
 9. Stencil or label the outside insulation jacket of each union with the word "UNION." Match size and color of pipe labels.
- C. Insulate instrument connections for thermometers, pressure gages, pressure temperature taps, test connections, flow meters, sensors, switches, and transmitters on insulated pipes, vessels, and equipment. Shape insulation at these connections by tapering it to and around the connection with insulating cement and finish with finishing cement, mastic, and flashing sealant.
- D. Install removable insulation covers at locations indicated. Installation shall conform to the following:
1. Make removable flange and union insulation from sectional pipe insulation of same thickness as that on adjoining pipe. Install same insulation jacket as adjoining pipe insulation.
 2. When flange and union covers are made from sectional pipe insulation, extend insulation from flanges or union long at least two times the insulation thickness over adjacent pipe insulation on each side of flange or union. Secure flange cover in place with stainless-steel or aluminum bands. Select band material compatible with insulation and jacket.
 3. Construct removable valve insulation covers in same manner as for flanges except divide the two-part section on the vertical center line of valve body.
 4. When covers are made from block insulation, make two halves, each consisting of mitered blocks wired to stainless-steel fabric. Secure this wire frame, with its attached insulation, to flanges with tie wire. Extend insulation at least 2 inches over adjacent pipe insulation on each side of valve. Fill space between flange or union cover and pipe insulation with insulating cement. Finish cover assembly with insulating cement applied in two coats. After first coat is dry, apply and trowel second coat to a smooth finish.
 5. Unless a PVC jacket is indicated in field-applied jacket schedules, finish exposed surfaces with a metal jacket.

3.5 FLEXIBLE ELASTOMERIC INSULATION INSTALLATION

- A. Seal longitudinal seams and end joints with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

B. Insulation Installation on Pipe Flanges:

1. Install pipe insulation to outer diameter of pipe flange.
2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of sheet insulation of same thickness as pipe insulation.
4. Secure insulation to flanges and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

C. Insulation Installation on Pipe Fittings and Elbows:

1. Install mitered sections of pipe insulation.
2. Secure insulation materials and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

D. Insulation Installation on Valves and Pipe Specialties:

1. Install preformed valve covers manufactured of same material as pipe insulation when available.
2. When preformed valve covers are not available, install cut sections of pipe and sheet insulation to valve body. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
3. Install insulation to flanges as specified for flange insulation application.
4. Secure insulation to valves and specialties and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

3.6 MINERAL-FIBER INSULATION INSTALLATION

A. Insulation Installation on Straight Pipes and Tubes:

1. Secure each layer of preformed pipe insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
3. For insulation with factory-applied jackets secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.

B. Insulation Installation on Pipe Flanges:

1. Install preformed pipe insulation to outer diameter of pipe flange.
2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with mineral-fiber blanket insulation.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

4. Install jacket material with manufacturer's recommended adhesive, overlap seams at least 1 inch, and seal joints with flashing sealant.
- C. Insulation Installation on Pipe Fittings and Elbows:
1. Install preformed sections of same material as straight segments of pipe insulation when available.
 2. When preformed insulation elbows and fittings are not available, install mitered sections of pipe insulation, to a thickness equal to adjoining pipe insulation. Secure insulation materials with wire or bands.
- D. Insulation Installation on Valves and Pipe Specialties:
1. Install preformed sections of same material as straight segments of pipe insulation when available.
 2. When preformed sections are not available, install mitered sections of pipe insulation to valve body.
 3. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
 4. Install insulation to flanges as specified for flange insulation application.
- E. Blanket and Board Insulation Installation on Ducts and Plenums: Secure with adhesive and insulation pins.
1. Apply adhesives according to manufacturer's recommended coverage rates per unit area.
 2. Apply adhesive to entire circumference of ducts and to all surfaces of fittings and transitions.
 3. Install either capacitor-discharge-weld pins and speed washers or cupped-head, capacitor-discharge-weld pins on sides and bottom of horizontal ducts and sides of vertical ducts as follows:
 - a. On duct sides with dimensions 18 inches and smaller, place pins along longitudinal centerline of duct. Space 3 inches maximum from insulation end joints, and 16 inches o.c.
 - b. On duct sides with dimensions larger than 18 inches, place pins 16 inches o.c. each way, and 3 inches maximum from insulation joints. Install additional pins to hold insulation tightly against surface at cross bracing.
 - c. Pins may be omitted from top surface of horizontal, rectangular ducts and plenums.
 - d. Do not overcompress insulation during installation.
 - e. Impale insulation over pins and attach speed washers.
 - f. Cut excess portion of pins extending beyond speed washers or bend parallel with insulation surface. Cover exposed pins and washers with tape matching insulation facing.
 4. For ducts and plenums with surface temperatures below ambient, install a continuous unbroken vapor barrier. Create a facing lap for longitudinal seams and end joints with insulation by removing 2 inches from 1 edge and 1 end of insulation segment. Secure laps to adjacent insulation section. Install vapor barrier consisting of factory- or field-applied jacket, adhesive, vapor-barrier mastic, and sealant at joints, seams, and protrusions.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Repair punctures, tears, and penetrations with tape or mastic to maintain vapor-barrier seal.
 - b. Install vapor stops for ductwork and plenums operating below 50 deg F at 18-foot intervals. Vapor stops shall consist of vapor-barrier mastic applied in a Z-shaped pattern over insulation face, along butt end of insulation, and over the surface. Cover insulation face and surface to be insulated a width equal to 2 times the insulation thickness but not less than 3 inches.
5. Overlap unfaced blankets a minimum of 2 inches on longitudinal seams and end joints. At end joints, secure with steel bands spaced a maximum of 18 inches o.c.
 6. For Blanket Insulation Install insulation on rectangular duct elbows and transitions with a full insulation section for each surface. Install insulation on round and flat-oval duct elbows with individually mitered gores cut to fit the elbow.
 7. For Board Insulation Install insulation on rectangular duct elbows and transitions with a full insulation section for each surface. Groove and score insulation to fit as closely as possible to outside and inside radius of elbows. Install insulation on round and flat-oval duct elbows with individually mitered gores cut to fit the elbow.
 8. Insulate duct stiffeners, hangers, and flanges that protrude beyond insulation surface with 6-inch-wide strips of same material used to insulate duct. Secure on alternating sides of stiffener, hanger, and flange with pins spaced 6 inches o.c.

3.7 FIELD-APPLIED JACKET INSTALLATION

- A. Where FSK jackets are indicated, install as follows:
 1. Draw jacket material smooth and tight.
 2. Install lap or joint strips with same material as jacket.
 3. Secure jacket to insulation with manufacturer's recommended adhesive.
 4. Install jacket with 1-1/2-inch laps at longitudinal seams and 3-inch-wide joint strips at end joints.
 5. Seal openings, punctures, and breaks in vapor-retarder jackets and exposed insulation with vapor-barrier mastic.
- B. Where PVC jackets are indicated, install with 1-inch overlap at longitudinal seams and end joints; for horizontal applications, install with longitudinal seams along top and bottom of tanks and vessels. Seal with manufacturer's recommended adhesive.
 1. Apply two continuous beads of adhesive to seams and joints, one bead under lap and the finish bead along seam and joint edge.
- C. Where metal jackets are indicated, install with 2-inch overlap at longitudinal seams and end joints. Overlap longitudinal seams arranged to shed water. Seal end joints with weatherproof sealant recommended by insulation manufacturer. Secure jacket with stainless-steel bands 12 inches o.c. and at end joints.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.8 FINISHES

- A. Duct, Equipment, and Pipe Insulation with ASJ or Other Paintable Jacket Material: Paint jacket with paint system identified below and as specified in Division 09 painting Sections.
 - 1. Flat Acrylic Finish: Two finish coats over a primer that is compatible with jacket material and finish coat paint. Add fungicidal agent to render fabric mildew proof.
 - a. Finish Coat Material: Interior, flat, latex-emulsion size.
- B. Flexible Elastomeric Thermal Insulation: After adhesive has fully cured, apply two coats of insulation manufacturer's recommended protective coating for outdoor applications. Armaflex WB Finish or equal product weather resistant to ultraviolet (UV) and ozone.
- C. Color: Final color as selected by Architect. Vary first and second coats to allow visual inspection of the completed Work.
- D. Do not field paint aluminum or stainless-steel jackets.

3.9 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. Tests and Inspections:
 - 1. Inspect ductwork, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to three location(s) for each duct system defined in the "Duct Insulation Schedule, General" Article.
 - 2. Inspect field-insulated equipment, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to three location(s) for each type of equipment defined in the "Equipment Insulation Schedule" Article. For large equipment, remove only a portion adequate to determine compliance.
 - 3. Inspect pipe, fittings, strainers, and valves, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to three locations of straight pipe, three locations of threaded fittings, three locations of welded fittings, two locations of threaded strainers, two locations of welded strainers, three locations of threaded valves, and three Insert number locations of flanged valves for each pipe service defined in the "Piping Insulation Schedule, General" Article.
- C. All insulation applications will be considered defective Work if sample inspection reveals noncompliance with requirements.

3.10 DUCT INSULATION SCHEDULE, GENERAL

- A. Plenums and Ducts Requiring Insulation:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Indoor, concealed and exposed supply and outdoor air.
2. Indoor, exhaust between isolation damper and penetration of building exterior.
3. Outdoor, exposed supply and return.

B. Items Not Insulated:

1. Fibrous-glass ducts.
2. Metal ducts with duct liner of sufficient thickness to comply with energy code and ASHRAE/IESNA 90.1.
3. Factory-insulated flexible ducts.
4. Factory-insulated plenums and casings.
5. Flexible connectors.
6. Vibration-control devices.
7. Factory-insulated access panels and doors.

3.11 INDOOR DUCT AND PLENUM INSULATION SCHEDULE

- A. Concealed, Supply-Air Duct and Plenum Insulation: Mineral-fiber blanket, 1-1/2 inches thick and 0.75-lb/cu. ft. nominal density.
- B. Concealed, Return-Air and Outdoor Air Duct and Plenum Insulation: Mineral-fiber blanket, 1-1/2 inches thick and 0.75-lb/cu. ft. nominal density.
- C. Exposed in Unconditioned Space, Supply-Air, Return-Air, and Outdoor Air Duct and Plenum Insulation: Mineral-fiber board, 1.5 inches thick and 3-lb/cu. ft. nominal density.
- D. Concealed or exposed exhaust between isolation damper and penetration of building exterior. Mineral-fiber blanket, 2 inches thick and 0.75-lb/cu. ft. nominal density.

3.12 ABOVEGROUND, OUTDOOR DUCT AND PLENUM INSULATION SCHEDULE

- A. Insulation materials and thicknesses are identified below. If more than one material is listed for a duct system, selection from materials listed is Contractor's option.
- B. Exposed, Supply-Air and Return-Air Duct and Plenum Insulation: Mineral-fiber board, 2 inches thick and 3-lb/cu. ft. nominal density.

3.13 EQUIPMENT INSULATION SCHEDULE

- A. Insulation materials and thicknesses are identified below. If more than one material is listed for a type of equipment, selection from materials listed is Contractor's option.
- B. Insulate indoor and outdoor equipment in paragraphs below that is not factory insulated.
- C. Heat-Exchanger (Water-to-Water for Heating Service) Insulation: Mineral-fiber pipe and tank, 2 inches thick.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.14 INDOOR PIPING INSULATION SCHEDULE

- a. None

3.15 OUTDOOR, ABOVEGROUND PIPING INSULATION SCHEDULE

A. Refrigerant Suction (non-VRF system): Insulation shall be one of the following:

1. Flexible Elastomeric
2. Insulation Thickness
 - a. Pipe Size 1" and less = 0.75"
 - b. Pipe Size 1 ½"-2" = 1.0"

B. For Flexible Elastomeric, apply finish coat with brush or roller. Apply at temperatures above 50°F and when no freezing temperatures are expected for 24 hours. Allow first coat to dry for four (4) hours minimum before application of second coat, and allow at least 24 hours to dry completely.

END OF SECTION 230700

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 230923 - DIRECT DIGITAL CONTROL SYSTEMS FOR HVAC

PART 1 - GENERAL

1.1 REFERENCES

- A. The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by the basic designation only.

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS (ASHRAE)

ASHRAE 90.1 (2010) Energy Standard for Buildings Except Low-Rise Residential Buildings

ASHRAE 135 (2016) BACnet—A Data Communication Protocol for Building Automation and Control Networks

ARCNET TRADE ASSOCIATION (ATA)

ATA 878.1 (1999) Local Area Network: Token Bus

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

IEEE C57.13 (2016) Standard Requirements for Instrument Transformers

IEEE C62.41.1 (2002) Guide on the Surges Environment in Low-Voltage (1000 V and Less) AC Power Circuits

IEEE C62.41.2 (2002) Recommended Practice on Characterization of Surges in Low-Voltage (1000 V and Less) AC Power Circuits

IEEE C62.45 (2002) Recommended Practice on Surge Testing for Equipment Connected to Low-Voltage (1000v and less)AC Power Circuits

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION (ISO)

ISO 8802-3 (2017) Information Technology - Telecommunications and Information Exchange Between Systems

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2017) National Electrical Code

NFPA 72 (2016) National Fire Alarm and Signaling Code

NFPA 90A (2018) Standard for the Installation of Air Conditioning and Ventilating Systems

SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION (SMACNA)

SMACNA (2005) HVAC Duct Construction Standards Metal and Flexible, 3rd Edition

UNDERWRITERS LABORATORIES (UL)

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

UL 1449	(2014) Surge Protective Devices
UL 506	(2017) Specialty Transformers
UL 508A	(2018) Industrial Control Panels
UL 916	(2015) Standard for Energy Management Equipment

1.2 DEFINITIONS

A. ANSI/ASHRAE Standard 135

1. ANSI/ASHRAE Standard 135: BACnet - A Data Communication Protocol for Building Automation and Control Networks, referred to as "BACnet". ASHRAE developed BACnet to provide a method for diverse building automation devices to communicate and share data over a network.

B. ARCNET

1. ATA 878.1 - Attached Resource Computer Network. ARCNET is a deterministic LAN technology; meaning it's possible to determine the maximum delay before a device is able to transmit a message.

C. BACnet

1. Building Automation and Control Network; the common name for the communication standard ASHRAE 135. The standard defines methods and protocol for cooperating building automation devices to communicate over a variety of LAN technologies.

D. BACnet/IP

1. An extension of BACnet, Annex J, defines this mechanism using a reserved UDP socket to transmit BACnet messages over IP networks. A BACnet/IP network is a collection of one or more IP subnetworks that share the same BACnet network number. See also "BACnet Broadcast Management Device".

E. BACnet Internetwork

1. Two or more BACnet networks, possibly using different LAN technologies, connected with routers. In a BACnet internetwork, there exists only one message path between devices.

F. BACnet Network

1. One or more BACnet segments that have the same network address and are interconnected by bridges at the physical and data link layers.

G. BACnet Segment

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. One or more physical segments of BACnet devices on a BACnet network, connected at the physical layer by repeaters.
- H. BBMD
1. BACnet Broadcast Management Device (BBMD). A communications device typically combined with a BACnet router. A BBMD forwards BACnet broadcast messages to BACnet/IP devices and other BBMDs connected to the same BACnet/IP network. Every IP subnetwork that is part of a BACnet/IP network must have only one BBMD. See also "BACnet/IP".
- I. BIBBs
1. BACnet Interoperability Building Blocks. A collection of BACnet services used to describe supported tasks. BIBBs are often described in terms of "A" (client) and "B" (server) devices. The "A" device uses data provided by the "B" device, or requests an action from the "B" device.
- J. BI
1. BACnet International, formerly two organizations: the BACnet Manufacturers Association (BMA) and the BACnet Interest Group - North America (BIG-NA).
- K. BI/BTL
1. BACnet International/BACnet Testing Laboratories (Formerly BMA/BTL). The organization responsible for testing products for compliance with the BACnet standard, operated under the direction of BACnet International.
- L. Bridge
1. Network hardware that connects two or more network (or BACnet internetwork) segments at the physical and data link layers. A bridge may also filter messages.
- M. Broadcast
1. A message sent to all devices on a network segment.
- N. Device
1. Any control system component, usually a digital controller that contains a BACnet Device Object and uses BACnet to communicate with other devices. See also "Digital Controller".
- O. Device Object
1. Every BACnet device requires one Device Object, whose properties represent the network visible properties of that device.
 2. Every Device Object requires a unique Object Identifier number on the BACnet internetwork. This number is often referred to as the device instance.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

P. Device Profile

1. A collection of BIBBs determining minimum BACnet capabilities of a device, defined in ASHRAE Standard 135-2004, Annex L.
2. Standard device profiles include BACnet Operator Workstations (B-OWS), BACnet Building Controllers (B-BC), BACnet Advanced Application Controllers (B-AAC), BACnet Application Specific Controllers (B-ASC), BACnet Smart Actuator (B-SA), and BACnet Smart Sensor (B-SS).
3. Each device used in new construction is required to have a PICS statement listing BIBBs supported.

Q. Digital Controller

1. An electronic controller, usually with internal programming logic and digital and analog input/output capability, which performs control functions. In most cases, synonymous with a BACnet device described in this specification.
2. See also "Device".

R. Direct Digital Control (DDC)

1. Digital controllers performing control logic.
2. Usually the controller directly senses physical values, makes control decisions with internal programs, and outputs control signals to directly operate switches, valves, dampers, and motor controllers.

S. DDC System

1. A network of digital controllers, communication architecture, and user interfaces. A DDC system may include programming, sensors, actuators, switches, relays, factory controls, operator workstations, and various other devices, components, and attributes.

T. Ethernet

1. A family of local-area-network technologies providing high-speed networking features over various media.

U. Firmware

1. Software programmed into read only memory (ROM), flash memory, electrically erasable programmable read only memory (EEPROM), or erasable programmable read only memory (EPROM) chips.

V. Gateway

1. Communication hardware connecting two or more different protocols, similar to human language translators.
2. The Gateway translates one protocol into equivalent concepts for the other protocol.
3. In BACnet applications, a gateway has BACnet on one side and non-BACnet (usually proprietary) protocols on the other side.

W. Half Router

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. A device that participates as one partner in a BACnet point-to-point (PTP) connection.
 2. Two half-routers in an active PTP connection combine to form a single router.
- X. Hub
1. A common connection point for devices on a network.
- Y. Internet Protocol (IP, TCP/IP, UDP/IP)
1. A communication method, the most common use is the World Wide Web.
 2. At the lowest level, it is based on Internet Protocol (IP), a method for conveying and routing packets of information over various LAN media.
 3. Two common protocols using IP are User Datagram Protocol (UDP) and Transmission Control Protocol (TCP). UDP conveys information to well-known "sockets" without confirmation of receipt. TCP establishes "sessions", which have end-to-end confirmation and guaranteed sequence of delivery.
- Z. Input/Output (I/O)
1. Physical inputs and outputs to and from a device, although the term sometimes describes software, or "virtual" I/O. See also "Points".
- AA. I/O Expansion Unit
1. An I/O expansion unit provides additional point capacity to a digital controller.
- BB. IP subnet
1. Internet protocol (IP) identifies individual devices with a 32-bit number divided into four groups from 0 to 255.
 2. Devices are often grouped and share some portion of this number. For example, one device has IP address 209.185.47.68 and another device has IP address 209.185.47.82. These two devices share Class C subnet 209.185.47.00
- CC. Local-Area Network (LAN)
1. A communication network that spans a limited geographic area and uses the same basic communication technology throughout.
- DD. MAC Address
1. Media Access Control address.
 2. The physical node address that identifies a device on a Local Area Network.
- EE. Master-Slave/Token-Passing (MS/TP)
1. ISO 8802-3. One of the LAN options for BACnet.
 2. MSTP uses twisted-pair wiring for relatively low speed and low cost communication (up to 4,000 ft at 76.8K bps).
- FF. Native BACnet Device

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. A device that uses BACnet as its primary, if not only, method of communication with other BACnet devices without intermediary gateways.
2. A system that uses native BACnet devices at all levels is a native BACnet system.

GG. Network

1. Communication technology for data communications. BACnet approved network types are BACnet over Internet Protocol (IP), Point to Point (PTP) Ethernet, ARCNET, MS/TP, and LonTalk®.

HH. Network Number

1. A site-specific number assigned to each network segment to identify for routing.
2. This network number must be unique throughout the BACnet internetwork.

II. Object

1. The concept of organizing BACnet information into standard components with various associated properties. Examples include analog input objects and binary output objects.

JJ. Object Identifier

1. An object property used to identify the object, including object type and instance. Object Identifiers must be unique within a device.

KK. Object Properties

1. Attributes of an object. Examples include present value and high limit properties of an analog input object.
2. Properties are defined in ASHRAE 135; some are optional and some are required. Objects are controlled by reading from and writing to object properties.

LL. Owner

1. Owner - Wayne State

MM. Peer-to-Peer

1. Peer-to-peer refers to devices where any device can initiate and respond to communication with other devices.

NN. Performance Verification Test (PVT)

1. The procedure for determining if the installed system meets design criteria prior to final acceptance. The PVT is performed after installation, testing, and balancing of mechanical systems. Typically the PVT is performed by the Contractor in the presence of the Engineer.

OO. PID

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Proportional, integral, and derivative control; three parameters used to control modulating equipment to maintain a setpoint. Derivative control is often not required for HVAC systems (leaving "PI" control).

PP. PICS

1. Protocol Implementation Conformance Statement (PICS), describing the BACnet capabilities of a device. See BACnet, Annex A for the standard format and content of a PICS statement.

QQ. Points

1. Physical and virtual inputs and outputs. See also "Input/Output".

RR. PTP

1. Point-to-Point protocol connects individual BACnet devices or networks using serial connections like modem-to-modem links.

SS. PVT

1. Performance Verification Testing

TT. Repeater

1. A network component that connects two or more physical segments at the physical layer.

UU. Router

1. A BACnet router is a component that joins together two or more networks using different LAN technologies. Examples include joining a BACnet Ethernet LAN to a BACnet MS/TP LAN.

VV. Stand-Alone Control

1. Refers to devices performing equipment-specific and small system control without communication to other devices or computers for physical I/O, excluding outside air and other common shared conditions.
2. Devices are located near controlled equipment, with physical input and output points limited to 64 or less per device, except for complex individual equipment or systems.
3. Failure of any single device will not cause other network devices to fail.
4. BACnet "Smart" actuators (B-SA profile) and sensors (B-SS profile) communicating on a network with a parent device are exempt from stand-alone requirements.

1.3 BACnet DIRECT DIGITAL CONTROL SYSTEMS FOR HVAC DESCRIPTION

A. Design Requirements

B. Control System Drawings Title Sheet

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Provide a title sheet for the control system drawing set.
2. Include the project title, project location, contract number, the controls contractor preparing the drawings, an index of the control drawings in the set, and a legend of the symbols and abbreviations used throughout the control system drawings.

C. List of I/O Points

1. Also known as a Point Schedule, provide for each input and output point physically connected to a digital controller:
 - a. Point name, Point description, Point type (Analog Output (AO), Analog Input (AI), Binary Output (BO), Binary Input (BI)), point sensor range, point actuator range, point address, BACnet object, associated BIBBS (where applicable), and point connection terminal number.
 - b. Typical schedules for multiple identical equipment are allowed unless otherwise requested in design or contract criteria.

D. Control System Components List

1. Provide a complete list of control system components installed on this project.
 - a. Include for each controller and device: control system schematic name, control system schematic designation, device description, manufacturer, and manufacturer part number.
 - b. For sensors, include point name, sensor range, and operating limits.
 - c. For valves, include body style, Cv, design flow rate, pressure drop, valve characteristic (linear or equal percentage), and pipe connection size.
 - d. For actuators, include point name, spring or non-spring return, modulating or two-position action, normal (power fail) position, nominal control signal operating range (0-10 volts DC or 4-20 milliamps), and operating limits.

E. Control System Schematics

1. Provide control system schematics.
2. Typical schematics for multiple identical equipment are allowed unless otherwise requested in design or contract criteria. Include the following:
 - a. Location of each input and output device
 - b. Flow diagram for each piece of HVAC equipment
 - c. Name or symbol for each control system component, such as V-1 for a valve
 - d. Setpoints, with differential or proportional band values
 - e. Written sequence of operation for the HVAC equipment
 - f. Valve and Damper Schedules, with normal (power fail) position

F. HVAC Equipment Electrical Ladder Diagrams

1. Provide HVAC equipment electrical ladder diagrams. Indicate required electrical interlocks.

G. Component Wiring Diagrams

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Provide a wiring diagram for each type of input device and output device. Indicate how each device is wired and powered; showing typical connections at the digital controller and power supply. Show for all field connected devices such as control relays, motor starters, actuators, sensors, and transmitters.

H. Terminal Strip Diagrams

1. Provide a diagram of each terminal strip. Indicate the terminal strip location, termination numbers, and associated point names.

I. BACnet Communication Architecture Schematic

1. Provide a schematic showing the project's entire BACnet communication network, including addressing used for LANs, LAN devices including routers and bridges, gateways, controllers, workstations, and field interface devices. If applicable, show connection to existing networks.

J. SUBMITTALS

1. Submit detailed and annotated manufacturer's data, drawings, and specification sheets for each item listed, that clearly show compliance with the project specifications.
2. Shop Drawings Include the following in the project's control system drawing set:
 - a. Control system drawings title sheet
 - b. List of I/O Points
 - c. Control System Components List
 - d. Control system schematics
 - e. HVAC Equipment Electrical Ladder diagrams
 - f. Component wiring diagrams
 - g. Terminal strip diagrams
 - h. BACnet communication architecture schematic
 - i. Sequence of Operation
3. Product Data
 - a. Direct Digital Controllers
 - 1) Include BACnet PICS for each controller/device type, including smart sensors (B-SS) and smart actuators (B-SA).
 - b. BACnet Gateways
 - 1) Include BACnet and workstation display information; bi-directional communication ability; compliance with interoperability schedule; expansion capacity; handling of alarms, events, scheduling and trend data; and single device capability (not depending on multiple devices for exchanging information from either side of the gateway).
 - c. BACnet Protocol Analyzer

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1) Include capability to store and report data traffic on BACnet networks, measure bandwidth usage, filter information, and identify BACnet devices.

d. DDC Software

e. BACnet Operator Workstation DDC Software

1) Include BACnet PICS for Operator Workstation software.

f. Sensors and Input Hardware

g. Output Hardware

h. Surge and transient protection

i. Indicators

j. Design Data

k. Performance Verification Testing Plan

l. Pre-Performance Verification Testing Checklist - Test Reports

m. Performance Verification Testing Report - Certificates

n. Contractor's Qualifications

o. Manufacturer's Field Reports

p. Pre-PVT Checklist

q. Operation and Maintenance Data

r. Controls System Operators Manuals

s. Closeout Submittals

t. Training documentation

1.4 QUALITY ASSURANCE

A. If anything listed herein cannot be met, then all exceptions taken are to be included with the bid.

B. Provide with bid any and all licensing requirements.

C. Standard Products

1. Provide material and equipment that are standard manufacturer's products currently in production and supported by a local service organization.

D. Delivery, Storage, and Handling

1. Handle, store, and protect equipment and materials to prevent damage before and during installation according to manufacturer's recommendations.

2. Replace damaged or defective items.

E. Operating Environment

1. Protect components from humidity and temperature variation, dust, and contaminants.

2. If components are stored before installation, keep them within the manufacturer's limits.

F. Finish of New Equipment

1. New equipment finishing shall be factory provided.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Manufacturer's standard factory finishing shall be proven to withstand 125 hours in a salt-spray fog test.
 - a. Equipment located outdoors shall be proven to withstand 500 hours in a salt-spray fog test.
 - b. Salt-spray fog test shall be according to ASTM B117, with acceptance criteria as follows: immediately after completion of the test, the finish shall show no signs of degradation or loss of adhesion beyond 3.175 mm 0.125 inch on either side of the scratch mark.

- G. Verification of Dimensions
 1. The contractor shall verify all dimensions in the field, and advise the Construction Manager of any discrepancy before performing work.

- H. Contractor's Qualifications
 1. Submit documentation certifying the controls Contractor performing the work has completed at least three DDC systems installations of a similar design to this project, and programmed similar sequences of operation for at least two years.
 2. All bidders must have a minimum of three (3), installed, web-based systems. Systems must be accessible via the Internet from the Owners office and shall be able to demonstrate these systems, prior to award of contract, using only an Owner provided web browser.

- I. Project Sequence - The control system work for this project shall proceed in the following order:
 1. Submit and receive approval on the Shop Drawings, Product Data, and Certificates specified under the paragraph entitled "SUBMITTALS."
 2. Perform the control system installation work, including all field check-outs and tuning.
 3. Provide support to TAB personnel as specified under the paragraph "TEST AND BALANCE SUPPORT."
 4. Provide support to Commissioning Agent.
 5. Submit and receive approval of the Controls System Operators Manual specified under the paragraph "CONTROLS SYSTEM OPERATORS MANUALS."
 6. Submit and receive approval of the Performance Verification Testing Plan and the Pre-PVT Checklist specified under the paragraph "PERFORMANCE VERIFICATION TESTING."
 7. Perform the Performance Verification Testing.
 8. Submit and receive approval on the PVT Report.
 9. Provide one year trend data
 10. Submit and receive approval on the Training Documentation at least 30 days before training.
 11. Deliver the final Controls System Operators Manuals.
 12. Conduct the Phase I Training.
 13. Conduct the Phase II Training.
 14. Submit and receive approval of Closeout Submittals

- J. Control systems shall meet the requirements of ASHRAE Standard 90.1, 2010.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.5 COORDINATION

- A. Coordinate location of thermostats, room humidity sensors, CO2 sensors, and other exposed control sensors with plans and room details before installation.
- B. DDC System Contractor shall furnish and install:
 - 1. A fully integrated BACnet building automation system, UL listed, incorporating direct digital control (DDC) for energy management, equipment monitoring and control.
 - 2. Necessary conduit, wiring, enclosures, and panels, for all DDC temperature control equipment and devices. Installation shall comply with applicable local and national codes.
 - 3. All components and control devices necessary to provide a complete and operable DDC system as specified herein.
 - 4. All conduit and wiring for power to all DDC System devices.
 - 5. DDC System Contractor shall be responsible for all low voltage electrical work associated with the DDC System and as called for on the Drawings. This DDC System control wiring shall be furnished and installed in accordance with the Electrical requirements as specified in Division 26, the National Electric Code, and all applicable local codes.
 - 6. DDC System Contractor shall furnish and install all LAN, WAN and Modbus Communication cables as required that are not already provided under Division 27. Electronic and fiber-optic cables for control wiring are specified in Division 27 Section "Structured Cable Systems".
 - 7. DDC System Contractor shall provide programming modifications necessary to fine tune sequences during commissioning and through warranty period of systems at no additional cost.
- C. Mechanical Contractor provides:
 - 1. All wells and openings for water and air monitoring devices, temperature sensors, flow switches and alarms furnished by DDC System Contractor.
 - 2. Installation of all control valves furnished by DDC System Contractor.
 - 3. Installation of control dampers external to air handling units furnished by DDC System Contractor, and adjacent access doors for smoke; outdoor air, return air, exhaust air.
- D. Electrical Contractor provides:
 - 1. Electrical Contractor shall provide dedicated 120 volt, 20 amp circuits and circuit breakers from normal and/or emergency power panel for each Direct Digital Controller. Run power circuit within 5 feet of equipment installed and connected by DDC System Contractor.
 - 2. Wall mounted junction box and conduit to ceiling space for all room temperature sensors, relative humidity sensors and Carbon Dioxide sensors.

1.6 WARRANTY

- A. One (1) year manufacturer's warranty on all DDC control system components from universal warranty start date defined in front end documents.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

PART 2 - PRODUCTS

2.1 DDC SYSTEM

- A. Provide a networked DDC system for stand-alone control in compliance with the latest revision of the ASHRAE 135 BACnet standard. Include all programming, objects, and services required to meet the sequence of control. Provide BACnet communications between the DDC system and native BACnet devices furnished with HVAC equipment [and plant equipment including boilers, chillers, and variable frequency drives]. Devices provided shall be certified in the BACnet Testing Laboratories (BTL) Product Listing.
- B. Provide an operator workstation software on a computer (furnished under technology) with complete interface software capable of programming, configuring, and monitoring the digital controllers. All software and licenses necessary to make changes or expand the system must be included.
- C. No Mercury Containing Devices
- D. All Direct Digital Controllers, except Cabinet Unit Heater Direct Digital Controllers, are to be fully software programmable. That is programming utilizing DIP switches to access standard control sequences built into the controller are not allowed. Note: this includes VAV Box controllers.
- E. The DDC Operator Workstation software shall be BACnet compliant per BACnet Testing Laboratory

2.2 BACNET CONFORMANCE

- A. The DDC System Contractor shall supply a BACnet (ANSI/ASHRAE 135-2010) compliant system. BACnet compatible systems that employ the use of proprietary 'gateways' will not be accepted. All DDC System Contractors shall supply, prior to bid, Protocol Implementation Conformance Statements (PICS) and BACnet Interoperability Building Block (BIBB) summaries to the Associate Engineer for final approval.
- B. The BACnet system shall be capable of Internet Protocol (IP) communications. BACnet/IP and BACnet MS/TP will be considered the basis of design. All other configurations must be submitted prior to bid, in writing, for final approval.
- C. The secondary or sub-network shall utilize the Master-Slave/Token-Passing protocol, as acknowledged by the ANSI/ASHRAE 135 standard. Proprietary RS-485 or equivalent links will not be considered. The MS/TP link shall operate at a 76.8 Kbps minimum, and utilize no more than 2 repeaters in any instance.

2.3 DIGITAL CONTROLLER BACNET INTERNETWORK

- A. Provide a BACnet internetwork with control products, communication media, connectors, repeaters, hubs, and routers. Controller and operator interface communication shall conform to

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

ASHRAE 135, BACnet. If a controller becomes non-responsive, the remaining controllers shall continue operating and not be affected by the failed controller.

1. Communications Ports
 - a. Direct-Connect Interface Ports: Provide at least one extra communication port at each local BACnet network for direct connecting a notebook computer or BACnet hand-held terminal so all network BACnet objects and properties may be viewed and edited by the operator.
2. BACnet Communications to Plant Equipment
 - a. Provide BACnet communication ports, whenever available as a plant equipment OEM standard option (unless noted otherwise that allow hard wired points instead of BACnet communication, such as for the VFD's), for DDC integration via a single communication cable. Typical BACnet controlled plant equipment includes, but is not limited to, boilers, chillers, and variable frequency motor drives. Gateways are not allowed, unless required for communicating to equipment utilizing MODbus.

2.4 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
 1. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.

2.5 CONTROL SYSTEM

- A. Vendors (in alphabetical order) – See Front End Section “Instructions to Bidders” for detailed information.
 1. Automated Logic
 2. Siemens
 3. Trane
 4. Johnson Controls
- B. Control system shall consist of sensors, indicators, actuators, final control elements, interface equipment, other apparatus, accessories, and software connected to distributed controllers operating in multiuser, multitasking environment on token-passing network and programmed to control mechanical systems. An operator workstation permits interface with the network via dynamic color graphics with each mechanical system, building floor plan, and control device depicted by point-and-click graphics.
- C. All temperature control wiring shall be provided for a complete and operable system. All wiring shall be installed in accordance with Division 26, NEC and all local Codes.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. The Controls Contractor will be responsible for all system graphics software, graphic creation, alarming as specified, scheduling as specified and, shall train the Owner on how to set-up alarms, trending and scheduling.
- E. Control systems shall meet the requirements of ASHRAE Standard 90.1.
- F. Direct Digital Controllers
 - 1. Direct digital controllers shall be UL 916 rated.
- G. I/O Point Limitation
 - 1. The total number of I/O hardware points used by a single stand-alone digital controller, including I/O expansion units, shall not exceed 64, except for complex individual equipment or systems.
 - 2. Place I/O expansion units in the same cabinet as the digital controller.
- H. Environmental Limits
 - 1. Controllers shall be suitable for, or placed in protective enclosures suitable for the environment (temperature, humidity, dust, and vibration) where they are located.
- I. Stand-Alone Control
 - 1. Provide stand-alone digital controllers.
- J. Internal Clock
 - 1. Provide internal clocks for all BACnet Building Controllers (B-BC) and BACnet Advanced Application Controllers (B-AAC) using BACnet time synchronization services.
 - a. Automatically synchronize system clocks daily from an operator-designated controller.
 - b. The system shall automatically adjust for daylight saving time.
- K. Memory
 - 1. Provide sufficient memory for each controller to support the required control, communication, trends, alarms, and messages.
 - a. Protect programs residing in memory with EEPROM, flash memory, or by an uninterruptible power source (battery or uninterruptible power supply).
 - b. The backup power source shall have capacity to maintain the memory during a 72-hour continuous power outage.
 - c. Rechargeable power sources shall be constantly charged while the controller is operating under normal line power. Batteries shall be replaceable without soldering.
 - d. Trend and alarm history collected during normal operation shall not be lost during power outages less than 72 hours long.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

L. Immunity to Power Fluctuations

1. Controllers shall operate at 90 percent to 110 percent nominal voltage rating.

M. Transformer

1. The controller power supply shall be fused or current limiting and rated at 125 percent power consumption.

N. Wiring Terminations

1. Use screw terminal wiring terminations for all field-installed controllers.
 - a. Provide field-removable modular terminal strip or a termination card connected by a ribbon cable for all controllers other than terminal units.

O. Input and Output Interface

1. Provide hard-wired input and output interface for all controllers as follows:
 - a. Protection: Shorting an input or output point to itself, to another point, or to ground shall cause no controller damage. Input or output point contact with sources up to 24 volts AC or DC for any duration shall cause no controller damage.
 - b. Binary Inputs: Binary inputs shall monitor on and off contacts from a "dry" remote device without external power, and external 5-24 VDC voltage inputs.
 - c. Pulse Accumulation Inputs: Pulse accumulation inputs shall conform to binary input requirements and accumulate pulses at a resolution suitable to the application.
 - d. Analog Inputs: Analog inputs shall monitor low-voltage (0-10 VDC), current (4-20 mA), or resistance (thermistor or RTD) signals.
 - e. Binary Outputs: Binary outputs shall send a pulsed 24 VDC low-voltage signal for modulation control, or provide a maintained open-closed position for on-off control.
 - f. Analog Outputs: Analog outputs shall send modulating 0-10 VDC or 4-20 mA signals to control output devices.
 - g. Tri-State Outputs: Tri-State outputs shall provide three-point floating control of terminal unit electronic actuators.

P. Digital Controller BACnet Internetwork

1. Provide a BACnet internetwork with control products, communication media, connectors, repeaters, hubs, and routers.
2. Provide intermediate gateways, only when requested by the Engineer and shown on the contract drawings, to connect existing non-BACnet devices to the BACnet internetwork. Controller and operator interface communication shall conform to ASHRAE 135, BACnet. If a controller becomes non-responsive, the remaining controllers shall continue operating and not be affected by the failed controller.

Q. Communications Ports

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Direct-Connect Interface Ports:
 - a. Provide at least one extra communication port at each local BACnet network for direct connecting a notebook computer or BACnet hand-held terminal so all network BACnet objects and properties may be viewed and edited by the operator.
2. Telecommunications Interface Port:
 - a. Provide telephone communication port so that DDC System can send alarms to cell phones.

R. BACnet Gateways

1. Provide BACnet communication ports, whenever available as a plant equipment OEM standard option, for DDC integration via a single communication cable. Typical BACnet controlled plant equipment includes, but is not limited to, boilers, chillers, and variable frequency motor drives.
2. Provide gateways only when specifically requested and approved by the Engineer, and shown on the Engineer approved BACnet Communication Architecture Schematic.
3. Provide with each gateway an interoperability schedule [Use gateway interoperability schedules shown on design drawings or other project documents], showing each point or event on the legacy side that the BACnet "client" will read, and each parameter that the BACnet network will write to.
4. Describe this interoperability in terms of BACnet services, or Interoperability Building Blocks (BIBBS), defined in ASHRAE 135 Annex K. Provide two-year minimum warranty for each gateway, including parts and labor.
5. The following minimum capabilities are required:
 - a. Gateways shall be able to read and view all readable object properties listed in the interoperability schedule on the non-BACnet network to the BACnet network and vice versa where applicable.
 - b. Gateways shall be able to write to all writeable object properties listed in the interoperability schedule on the non-BACnet network from the BACnet network and vice versa where applicable.
 - c. Gateways shall provide single-pass (only one protocol to BACnet without intermediary protocols) translation from the non-BACnet protocol to BACnet and vice versa.
 - d. Gateways shall meet the requirements of Data Sharing Read Property (DS-RP-B), Data Sharing Write Property (DS-WP-B), Device Management Dynamic Device Binding-B (DM-DDB-B), and Device Management Communication Control (DM-DCC-B) BIBBs, in accordance with ASHRAE 135.
 - e. Gateways shall include all hardware, software, software licenses, and configuration tools for operator-to-gateway communications.
6. Provide backup programming and parameters on CD media and the ability to modify, download, backup, and restore gateway configuration.

S. Digital Controller Cabinet

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Provide each digital controller in a factory fabricated cabinet enclosure.
 - a. Cabinets located indoors shall protect against dust and have a minimum NEMA 1 rating, except where indicated otherwise.
 - b. Cabinets located outdoors or in damp environments shall protect against all outdoor conditions and have a minimum NEMA 4 rating.
2. Outdoor control panels and controllers must be able to withstand extreme ambient conditions, without malfunction or failure, whether or not the controlled equipment is running.
3. If necessary, provide a thermostatically controlled panel heater in freezing locations, and an internal ventilating fan in locations exposed to direct sunlight. Cabinets shall have a hinged lockable door and an offset removable metal back plate, except controllers integral with terminal units, like those mounted on VAV boxes.
4. Provide like-keyed locks for all hinged panels provided and a set of two keys at each panel, with one key inserted in the lock.

T. Main Power Switch and Receptacle

1. Provide each control cabinet with a main external power on/off switch located inside the cabinet.
2. Also provide each cabinet with a separate 120 VAC duplex receptacle.

2.6 DDC Software

A. Programming

1. Provide programming to execute the sequence of operation indicated. Provide all programming and tools to configure and program all controllers.
2. Provide programming routines in simple, easy-to-follow logic with detailed text comments describing what the logic does and how it corresponds to the project's written sequence of operation.
 - a. Graphic-based programming shall use a library of function blocks made from pre-programmed code designed for DDC SYSTEM control. Function blocks shall be assembled with interconnecting lines, depicting the control sequence in a flowchart. If providing a computer with device programming tools as part of the project, graphic programs shall be viewable in real time showing present values and logical results from each function block.
 - b. Menu-based programming shall be done by entering parameters, definitions, conditions, requirements, and constraints.
 - c. For line-by-line and text-based programming, declare variable types (local, global, real, integer, etc.) at the beginning of the program. Use descriptive comments frequently to describe the programming.
 - d. If providing a computer with device programming tools as part of the project, provide a means for detecting program errors and testing software strategies with a simulation tool.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3. Simulation may be inherent within the programming software suite, or provided by physical controllers mounted in a NEMA 1 test enclosure.
4. The test enclosure shall contain one dedicated controller of each type provided under this contract, complete with power supply and relevant accessories.

B. Parameter Modification

1. All writeable object properties, and all other programming parameters needed to comply with the project specification shall be adjustable for devices at any network level, including those accessible with web-browser communication, and regardless of programming methods used to create the applications.

C. Short Cycling Prevention

1. Provide setpoint differentials and minimum on/off times to prevent equipment short cycling.

D. Equipment Status Delay

1. Provide an adjustable delay from when equipment is commanded on or off and when the control program looks to the status input for confirmation.

E. Run Time Accumulation

1. Use the Elapsed Time Property to provide re-settable run time accumulation for each Binary Output Object connected to mechanical loads greater than 1 HP, electrical loads greater than 10 KW, or wherever else specified.

F. Timed Local Override

1. Provide an adjustable override time for each push of a timed local override button.

G. Time Synchronization

1. Provide time synchronization, including adjustments for leap years, daylight saving time, and operator time adjustments.

H. Scheduling

1. Provide operating schedules as indicated, with equipment assigned to groups. Changing the schedule of a group shall change the operating schedule of all equipment in the group. Groups shall be capable of operator creation, modification, and deletion.
2. Provide capability to view and modify schedules in a seven-day week format.
3. Provide capability to enter holiday and override schedules one full year at a time.

I. Object Property Override

1. Allow writeable object property values to accept overrides to any valid value. Where specified or required for the sequence of control, the Out-Of-Service property of Objects shall be modifiable using BACnet's write property service.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. When documented, exceptions to these requirements are allowed for life, machine, and process safeties.

J. Alarms and Events

1. Alarms and events shall be capable of having programmed time delays and high-low limits.
2. When a computer workstation or web server is connected to the BACnet internetwork, alarms/events shall report to the computer, printer, e-mail, cell phone, as defined by an authorized operator. Otherwise alarms/events shall be stored within a device on the BACnet network until connected to a user interface device and retrieved. Provide alarms/events in agreement with the point schedule, sequence of operation, and the DDC SYSTEM Owner.
3. At a minimum, provide programming to initiate alarms/events any time a piece of equipment fails to operate, a control point is outside normal range or condition shown on schedules, communication to a device is lost, a device has failed, or a controller has lost its memory.

K. Trending

1. Provide BACnet trend services capable of trending all object present values set points, and other parameters indicated for trending on project schedules.
 - a. Trends may be associated into groups, and a trend report may be set up for each group.
 - b. Trends are stored within a device on the BACnet network, with operator selectable trend intervals from 10 seconds up to 60 minutes. The minimum number of consecutive trend values stored at one time shall be 100 per variable.
 - c. When trend memory is full, the most recent data shall overwrite the oldest data.
 - d. The operator workstation shall upload trends automatically upon reaching 3/4 of the device buffer limit (via Notification Threshold property), by operator request, or by time schedule for archiving.
 - e. Archived and real-time trend data shall be available for viewing numerically and graphically for at the workstation and connected notebook computers.

L. Device Diagnostics

1. Each controller shall have diagnostic LEDs for power, communication, and device fault condition.
2. The DDC system shall recognize and report a non-responsive controller.

M. Power Loss

1. Upon restoration of power, the DDC system shall perform an orderly restart and restoration of control.

2.7 BACnet Operator Workstation

- A. The workstation shall be furnished by the controls contractor.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- B. The workstation shall be capable of accessing all DDC system devices and communicate using the BACnet protocol.
 - 1. The workstation shall be capable of displaying, modifying, creating, archiving, and deleting (as applicable): all points, objects, object properties, programming, alarms, trends, messages, schedules, and reports.

- C. Password Protection
 - 1. Provide at least five levels of password protection for operator interfaces.
 - a. The lowest level only allow viewing graphics
 - b. The second level allows viewing graphics and changing space temperature setpoints.
 - c. The third level allows the previous level's capability, plus changing operating schedules.
 - d. The fourth level allows access to all functions except passwords.
 - e. The highest level provides all administrator rights and allows full access to all programming, including setting new passwords and access levels.
 - 2. Provide the Owner with the highest level password access.
 - 3. Provide automatic log out if no keyboard or mouse activity is detected after a user-defined time delay.

- D. BACnet Operator Workstation DDC Software
 - 1. Provide the workstation software with the manufacturer's installation CDs and licenses. Configure the software according to the DDC system manufacturer's specifications and in agreement with BACnet Operator Workstation (B-OWS) device standards found in ASHRAE 135, Annex L.
 - 2. The workstation software shall permit complete monitoring, modification, and troubleshooting interface with the DDC system.
 - a. The operator interface with the software shall be menu-driven with appropriate displays and menu commands to manipulate the DDC system's objects, point data, operating schedules, control routines, system configuration, trends, alarms, messages, graphics, and reports.
 - b. Trends shall be capable of graphic display in real time, with variables plotted as functions of time. Each alarmed point shall be capable of displaying its alarm history, showing when it went into alarm, if and when it was acknowledged, and when it went out of alarm. The modification of DDC system parameters and object properties shall be accomplished with "fill in the blank" and/or "point and drag" methods. Modifications shall download to the appropriate controllers at the operator's request.

- E. Graphics Software
 - 1. Provide web-based system graphics viewable on browsers compatible with MS Internet Explorer 8.X or greater using an industry-standard file format such as HTML, BMP, JPEG, or GIF.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Graphic displays shall have full-screen resolution when viewed on the workstation and notebook computers.
 - a. Dynamic data on graphics pages shall refresh within 10 seconds using an Internet connection,
 - b. Graphics viewing shall not require additional "plug-in" software like Java, Shockwave and Flash applications unless the software is readily available for free over the Internet.
3. The graphics shall show the present value and object name for each of the project's I/O points on at least one graphic page.
 - a. Arrange point values and names on the graphic displays in their appropriate physical locations with respect to the floor plan or equipment graphic displayed. Graphics shall allow the operator to monitor current status, view zone and equipment summaries, use point-and-click navigation between graphic pages, and edit setpoints and parameters directly from the screens. Items in alarm shall be displayed using a different color or other obvious visual indicator.
 - b. Provide graphics with the following:
4. Graphic Types:
 - a. Provide at least one graphic display for each piece of HVAC equipment, building floor, and controlled zone.
 - b. Indicate dynamic point values, operating statuses, alarm conditions, and control setpoints on each display. Provide summary pages where appropriate.
5. Building Floor Plans:
 - a. Provide a floor plan graphic for each of the building's floors with dynamic display of space temperature and other important data.
 - b. If used, indicate and provide links to sub-plan areas.
 - c. If possible, use the project's electronic drawing files for the graphic backgrounds.
 - d. Provide clear names for important areas, such as "Main Conference Room." Include room names and numbers where applicable.
 - e. Include features such as stairwells, elevators, and main entrances.
 - f. Where applicable, include the mechanical room, HVAC equipment, and control component locations, with corresponding links to the equipment graphics.
6. Sub-plan Areas:
 - a. Where a building's floor plan is too large to adequately display on the screen, subdivide the plan into distinct areas, and provide a separate graphic display for each area. Provide same level of detail requested in building floor plan section above.
7. HVAC Equipment:
 - a. Provide a graphic display for each piece of HVAC equipment, such as a fan coil unit, VAV terminal, or air handling unit. Equipment shall be represented by a two or three-dimensional drawing.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- b. Where multiple pieces of equipment combine to form a system, such as a central chiller plant or central heating plant, provide one graphic to depict the entire plant.
 - c. Indicate the equipment, piping, ductwork, dampers, and control valves in the installed location. Include labels for equipment, piping, ductwork, dampers, and control valves.
 - d. Show the direction of air and water flow. Include dynamic display of applicable object data with clear names in appropriate locations.
8. Sequence of Operation:
- a. Provide a graphic screen displaying the written out full sequence of operation for each piece of HVAC equipment. Provide a link to the sequence of operation displays on their respective equipment graphics.
 - b. Include dynamic real-time data within the text for setpoints and variables.
9. Graphic Title:
- a. Provide a prominent, descriptive title on each graphic page.
10. Dynamic Update:
- a. When the workstation is on-line, all graphic I/O object values shall update with change-of-value services, or by operator selected discrete intervals.
11. Graphic Linking:
- a. Provide forward and backward linking between floor plans, sub-plans, and equipment.
12. Graphic Editing: Provide installed software to create, modify, and delete the DDC graphics.
- a. Include the ability to store graphic symbols in a symbol directory and import these symbols into the graphics.
13. Dynamic Point Editing:
- a. Provide full editing capability for deleting, adding, and modifying dynamic points on the graphics.
- F. BACnet Protocol Analyzer
- 1. Provide a BACnet protocol analyzer and required cables and fittings for connection to the BACnet network.
 - 2. The analyzer shall include the following minimum capabilities:
 - a. Capture and store to a file data traffic on all network levels.
 - b. Measure bandwidth usage.
 - c. Filtering options with ability to ignore select traffic.

WAYNE STATE UNIVERSITY
 MATTHAEI PHYSICAL EDUCATION CENTER
 ADDITION OF AIR CONDITIONING

2.8 SENSORS AND INPUT HARDWARE

- A. Coordinate sensor types with the DDC SYSTEM Owner to keep them consistent with existing installations.
- B. Reporting Accuracy: Listed below are minimum acceptable reporting end-to-end accuracies for all values reported by the specified system:

Measured Variable	Reported Accuracy
Space temperature	±1F
Ducted air temperature	±1F
Outdoor air temperature	±2F
Dew Point	±3F
Water temperature	±1F
Relative humidity	±3% RH
Water flow	±1% of reading
Air flow (terminal)	±10% of reading
Air flow (measuring stations)	±5% of reading
Carbon Monoxide (CO)	±5% of reading
Carbon Dioxide (CO ₂)	±50 ppm
Air pressure (ducts)	±0.1"w.c.
Air pressure (space)	±0.001"w.c.
Water pressure	±2% of full scale *Note 1
Electrical Power	±0.5% of reading

Note 1: for both absolute and differential pressure

- C. Control stability and accuracy: Control sequences shall maintain measured variable at setpoint within the following tolerances:

Controlled Variable	Control Accuracy	Range of Medium
Air Pressure	±0.2 in. w.g.	0–6 in. w.g.
Air Pressure	±0.01 in. w.g.	-0.1 to 0.1 in. w.g.
Airflow	±10% of full scale	
Space Temperature	±1.5°F	
Duct Temperature	±2°F	
Humidity	±5% RH	
Fluid Pressure	±1.5 psi	1–150 psi
Fluid Pressure	±1.0 in. w.g.	0–50 in. w.g. differential

- D. Extent of direct digital control: control design shall allow for at least the points indicated on the points lists on the drawings.
- E. Field-Installed Temperature Sensors

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Where feasible, provide the same sensor type throughout the project. Avoid using transmitters unless absolutely necessary.

F. Thermistors

1. Precision thermistors may be used in applications below 200 degrees F. Sensor accuracy over the application range shall be 0.36 degree F or less between 32 to 150 degrees F. Stability error of the thermistor over five years shall not exceed 0.25 degrees F cumulative. A/D conversion resolution error shall be kept to 0.1 degrees F. Total error for a thermistor circuit shall not exceed 0.5 degrees F.

G. Resistance Temperature Detectors (RTDs)

1. Provide RTD sensors with platinum elements compatible with the digital controllers.
2. Encapsulate sensors in epoxy, series 300 stainless steel, anodized aluminum, or copper. Temperature sensor accuracy shall be 0.1 percent (1 ohm) of expected ohms (1000 ohms) at 32 degrees F.
3. Temperature sensor stability error over five years shall not exceed 0.25 degrees F cumulative.
4. Direct connection of RTDs to digital controllers without transmitters is preferred
5. When RTDs are connected directly, lead resistance error shall be less than 0.25 degrees F.
6. The total error for a RTD circuit shall not exceed 0.5 degrees F.

H. Temperature Sensor Details

1. Room Type:
 - a. Provide the sensing element components within a decorative protective cover suitable for surrounding decor. Provide room temperature sensors with, setpoint adjustment lever, digital temperature display.
2. Duct Probe Type:
 - a. Ensure the probe is long enough to properly sense the air stream temperature.
3. Duct Averaging Type:
 - a. Continuous averaging sensors shall be one foot in length for each 4 square feet of duct cross-sectional area, and a minimum length of 6 feet.
4. Pipe Immersion Type:
 - a. Provide minimum three-inch immersion. Provide each sensor with a corresponding pipe-mounted sensor well, unless indicated otherwise.
 - b. Sensor wells shall be stainless steel when used in steel piping, and brass when used in copper piping. Provide the sensor well with a heat-sensitive transfer agent between the sensor and the well interior.
5. Outside Air Type:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Provide the sensing element on the building's north side with a protective weather shade that positions the sensor approximately 3 inches off the wall surface, does not inhibit free air flow across the sensing element, and protects the sensor from snow, ice, and rain.

I. Transmitters

1. Provide transmitters with 4 to 20 mA or 0 to 10 VDC linear output scaled to the sensed input. Transmitters shall be matched to the respective sensor, factory calibrated, and sealed. Size transmitters for an output near 50 percent of its full-scale range at normal operating conditions. The total transmitter error shall not exceed 0.1 percent at any point across the measured span. Supply voltage shall be 12 to 24 volts AC or DC. Transmitters shall have non-interactive offset and span adjustments. For temperature sensing, transmitter drift shall not exceed 0.03 degrees F a year.
2. Relative Humidity Transmitters
 - a. Provide transmitters with an accuracy equal to plus or minus 3 percent from 0 to 90 percent scale, and less than one percent drift per year.
 - b. Sensing elements shall be the polymer type.
 - c. Sensor shall remain in calibration for 5 years.
3. Pressure Transmitters
 - a. Provide transmitters integral with the pressure transducer.
4. Current Transducers
 - a. Provide current transducers to monitor motor amperage, unless current switches are shown on design drawings or point tables.

J. CO2 Sensors

1. Provide photo-acoustic type CO2 sensors with integral transducers and linear output. The devices shall read CO2 concentrations between 0 and 2000 ppm with full scale accuracy of at least plus or minus 100 ppm. Sensor shall remain in calibration for 10 years.

2.9 Input Switches

A. Timed Local Overrides

1. Provide buttons or switches to override the DDC occupancy schedule programming during unoccupied periods, and to return HVAC equipment to the occupied mode, for AHU-6 per the Sequence of Operation
 - a. This requirement is waived for zones clearly intended for 24 hour continuous operation.

- B. Line-Voltage, On-Off Thermostats: Bimetal-actuated, open contact or bellows-actuated, enclosed, snap-switch or equivalent solid-state type, with heat anticipator; listed for electrical

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

rating; with concealed set-point adjustment, 55 to 85 deg F set-point range, and 2 deg F maximum differential.

1. Electric Heating Thermostats: Equip with off position on dial wired to break ungrounded conductors.
2. Selector Switch: Integral, manual on-off-auto.

C. High Duct Static Pressure Switch

D. Static Pressure Sensors: Non-directional, temperature compensated.

1. 4-20 ma output signal.
2. 0 to 5 inches wg for duct static pressure range.
3. 0 to 0.25 inch wg for Building static pressure range.

E. Freeze Protection Thermostats

1. Provide special purpose thermostats with flexible capillary elements 20 feet minimum length for coil face areas up to 20 square feet.
2. Provide longer elements for larger coils at 1-foot of element for every 1 square feet of coil face area, or provide additional thermostats. Provide switch contacts rated for the respective motor starter's control circuit voltage. Include auxiliary contacts for the switch's status condition.
 - a. A freezing condition at any 12-inch increment along the sensing element's length shall activate the switch.
 - b. The thermostat shall be equipped with a manual push-button reset switch so that when tripped, the thermostat requires manual resetting before the HVAC equipment can restart.

F. Air Flow Measurement Stations

1. Air flow measurement stations shall have an array of velocity sensing elements and straightening vanes inside a flanged sheet metal casing. The velocity sensing elements shall be the RTD or thermistor type, traversing the ducted air in at least two directions. The air flow pressure drop across the station shall not exceed 0.08 inch water gage at a velocity of 2,000 fpm. The station shall be suitable for air flows up to 5,000 fpm, and a temperature range of minus 20 to 120 degrees F. The station's measurement accuracy over the range of 125 to 2,500 fpm shall be plus or minus 3 percent of the measured velocity. Station transmitters shall provide a linear, temperature-compensated 4 to 20 mA or 0 to 10 VDC output. The output shall be capable of being accurately converted to a corresponding air flow rate in cubic feet per minute. The output error of the transmitter shall not exceed 0.5 percent of the measurement.
2. Air Flow Measurement Stations shall be manufactured by Ebtron or equal meeting the above specification. Model and accessories appropriate for the application.

G. Power Monitor: 3-phase type with disconnect/shorting switch assembly, listed voltage and current transformers, with pulse kilowatt hour output and 4- to 20-mA kW output, with maximum 2 percent error at 1.0 power factor and 2.5 percent error at 0.5 power factor.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

H. Water flow sensors:

1. Type: Vortex or Electromagnetic Insertion Type Meter shall be required for Cooling Tower water and Domestic Water.
 - a. Pipe size: 3 to 24 inches.
2. Retractor:
 - a. ASME threaded, non-rising stem type with hand wheel. c.
 - b. Mounting connection 2 inch 150 PSI flange.
3. Sensor assembly:
 - a. Design for expected water flow and pipe size.
4. Seal: Teflon (PTFE).
5. Controller:
 - a. Integral to unit.
 - b. Locally display flow rate and total.
 - c. Output flow signal to DDC System:
 - d. Digital pulse type.
6. Performance:
 - a. Turndown: 20:1
 - b. Response time: Adjustable from 1 to 100 seconds.
 - c. Power: 24 volt DC
7. Install flow meters according to manufacturer's recommendations.
 - a. Where recommended by manufacturer because of mounting conditions, provide flow rectifier.
8. Turbine or Paddle Sensor is approved for chilled water, heating hot water. Sensor shall be non-magnetic, with forward curved impeller blades designed for water containing debris. Sensor accuracy shall be +/- 2% of rate of flow, minimum operating flow velocity shall be 1 foot per second. Sensor repeatability and linearity shall be +/- 1%. A certificate of calibration shall be provided with each flow meter. Materials which will be wetted shall be made from non-corrosive materials and shall not contaminate water. The transmitter housing shall be a NEMA 250 Type 4 enclosure. Sensor shall have output to DDC system.
9. Turbine or Paddle Sensor is approved for makeup water applications. Sensor shall be non-magnetic, with forward curved impeller blades designed for water containing debris. Sensor accuracy shall be +/- 5% of rate of flow, minimum operating flow velocity shall be 1 foot per second. Materials which will be wetted shall be made from non-corrosive materials and shall not contaminate water. The transmitter housing shall be a NEMA 250 Type 4 enclosure. Sensor shall have output to DDC system.

I. Flow switches:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Shall be either paddle or differential pressure type.
 - a. Paddle-type switches (liquid service only) shall be UL Listed, SPDT snap-acting, adjustable sensitivity with NEMA 4 enclosure.
 - b. Differential pressure type switches (air or water service) shall be UL listed, SPDT snap acting, NEMA 4 enclosure, with scale range and differential suitable for specified application.

J. Current Switches:

1. Current operated switches shall be self powered, solid state with adjustable trip current as well as status, power, and relay command status LED indication.
2. The switches shall be selected to match the current of the application and output requirements of the DDC systems.

K. Natural Gas Flow Meter :

1. The meter shall have a minimum requirement for accuracy of $\pm 2.0\%$ of reading accuracy from 100 to 500 SFPM and $\pm 1.0\%$ of reading from 500 to 7000 SFPM of natural gas. The Meter shall have analog output to the BACnet control system. A certificate of calibration shall be provided with each flow meter.

2.10 OUTPUT HARDWARE

A. Control Dampers

1. Provide factory manufactured [galvanized][stainless] steel dampers where indicated. Control dampers shall comply with SMACNA 1966 except as modified or supplemented by this specification. Published damper leakage rates and respective pressure drops shall have been verified by tests in compliance with AMCA 500-D requirements.
2. Provide damper assembly frames constructed of 0.064 inch minimum thickness galvanized steel channels with mitered and welded corners. Damper axles shall be 0.5 inches minimum diameter plated steel rods supported in the damper frame by stainless steel or bronze bearings. Blades mounted vertically shall be supported by thrust bearings.
3. Dampers shall be rated for not less than 2000 fpm air velocity. The pressure drop through each damper when full-open shall not exceed 0.04 inches water gage at 1000 fpm face velocity. Damper assemblies in ductwork subject to above 3-inch water gauge static air pressure shall be constructed to meet SMACNA Seal Class "A" construction requirements.
4. Provide the damper operating linkages outside of the air stream, including crank arms, connecting rods, and other hardware that transmits motion from the damper actuators to the dampers, shall be adjustable. Additionally, operating linkages shall be designed and constructed to have a 2 to 1 safety factor when loaded with the maximum required damper operating force. Linkages shall be brass, bronze, galvanized steel, or stainless steel.
5. Provide access doors or panels in hard ceilings and walls for access to all concealed damper operators and damper locking setscrews.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

6. For field-installed control dampers, a single damper section shall have blades no longer than 48 inches and no higher than 72 inches. The maximum damper blade width shall be 12 inches. Larger sized dampers shall be built using a combination of sections.
7. Frames shall be at least 2 inches wide. Flat blades shall have edges folded for rigidity. Blades shall be provided with compressible gasket seals along the full length of the blades to prevent air leakage when closed.
8. The damper frames shall be provided with jamb seals to minimize air leakage. Seals shall be suitable for an operating temperature range of minus 40 degrees F to 200 degrees F.
9. The leakage rate of each damper when full-closed shall be no more than 4 cfm per sq. foot of damper face area at 1.0 inches water gage static pressure.

B. Actuators

1. Provide direct-drive electric actuators for all control applications, except where indicated otherwise.

2.11 OUTPUT SWITCHES

A. Control Relays

1. Field installed and DDC panel relays shall be double pole, double throw, UL listed, with contacts rated for the intended application, indicator light, and dust proof enclosure.
 - a. The indicator light shall be lit when the coil is energized and off when coil is not energized.
2. Relays shall be the socket type, plug into a fixed base, and replaceable without tools or removing wiring.
3. Encapsulated "PAM" type relays may be used for terminal control applications.

2.12 ELECTRICAL POWER AND DISTRIBUTION

A. Transformers

1. Transformers shall conform to UL 506.
 - a. For control power other than terminal level equipment, provide a fuse or circuit breaker on the secondary side of each transformer.

B. Surge and Transient Protection

1. Provide each digital controller with surge and transient power protection. Surge and transient protection shall consist of the following devices, installed externally to the controllers.

C. Power Line Surge Protection

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Provide surge suppressors on the incoming power at each controller or grouped terminal controllers.
2. Surge suppressors shall be rated in accordance with UL 1449, have a fault indicating light, and conform to the following:
 - a. The device shall be a transient voltage surge suppressor, hard-wire type individual equipment protector for 120 VAC/1 phase/2 wire plus ground.
 - b. The device shall react within 5 nanoseconds and automatically reset.
 - c. The type and level of protection shall be selected by the Controls Contractor, unless noted otherwise.
 - d. The device shall have an indication light to indicate the protection components are functioning.
 - e. All system functions of the transient suppression system shall be individually fused and not short circuit the AC power line at any time.
 - f. Surge protection for Direct Digital Control panels serving the boiler and chiller plants shall be a combination surge protector and noise filter such as Leviton 51020-0WM or approved equal, and located within the Direct Digital Control panel enclosure.

D. Telephone and Communication Line Surge Protection

1. Provide surge and transient protection for DDC controllers and DDC network related devices connected to phone and network communication lines, in accordance with the following:
 - a. The device shall provide continuous, non-interrupting protection, and shall automatically reset after safely eliminating transient surges.
 - b. The protection shall react within 5 nanoseconds using only solid-state silicon avalanche technology.
 - c. The device shall be installed at the distance recommended by its manufacturer.

E. Controller Input/Output Protection

1. Provide controller inputs and outputs with surge protection via optical isolation, metal oxide varistors (MOV), or silicon avalanche devices. Fuses are not permitted for surge protection.

F. Wiring

1. Provide complete less than 100 volts electrical wiring for the DDC System.

G. Power Wiring

1. All electrical wiring 100 volts and greater is furnished and installed by the Electrical Contractor. DDC System Contractor to coordinate with Electrical Contractor.
2. The following requirements are for field-installed wiring:
 - a. Wiring for 24 V circuits shall be insulated copper 18 AWG minimum and rated for 300 VAC service.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

H. Analog Signal Wiring

1. Field-installed analog signal wiring shall be 18 AWG single or multiple twisted pair.
 - a. Each cable shall be 100 percent shielded and have a 20 AWG drain wire.
 - b. Each wire shall have insulation rated for 300 VAC service. Cables shall have an overall aluminum-polyester or tinned-copper cable-shield tape.

2.13 Pneumatic Tubing

A. Copper Tubing

1. Provide ASTM B75 or ASTM B88M ASTM B88 rated tubing.
2. Tubing 0.64 mm 0.375 inch outside diameter and larger shall have minimum wall thickness equal to ASTM B88M ASTM B88, Type M. Tubing less than 10 mm 0.375 inch outside diameter shall have minimum wall thickness of 0.64 mm 0.025 inch. Exposed tubing and tubing for working pressures greater than 30 psig shall be hard copper. Fittings shall be ASME B16.18 or ASME B16.22 solder type using ASTM B32 95-5 tin-antimony solder, or ASME B16.26 compression type.

B. Polyethylene Tubing

1. Polyethylene tubing may only be used in systems with working pressure of 30 psig or less.
2. Provide flame-resistant, multiple polyethylene tubing in flame-resistant protective sheath with mylar barrier, or unsheathed polyethylene tubing in rigid metal, intermediate metal, or electrical metallic tubing conduit for areas where tubing is exposed.
3. Single, unsheathed, flame-resistant polyethylene tubing may be used where concealed in walls or above ceilings and within control panels.
4. Do not provide polyethylene tubing for smoke removal systems.
 - a. Provide compression or brass barbed push-on type fittings.
5. Extruded seamless polyethylene tubing shall conform to the following:
 - a. Minimum Burst Pressure Requirements: 100 psig at 75 degrees F to 25 psig at 150 degrees F.
 - b. Stress Crack Resistance: ASTM D1693, 200 hours minimum.
 - c. Tensile Strength (Minimum): ASTM D638, 1100 psi.
 - d. Flow Rate (Average): ASTM D1238, 0.30 decigram per minute.
 - e. Density (Average): ASTM D792, 57.5 pounds per cubic feet.
 - f. Burn rate: ASTM D635

PART 3 - EXECUTION

3.1 INSTALLATION

A. BACnet Naming and Addressing

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Coordinate with the DDC SYSTEM Owner and provide unique naming and addressing for BACnet networks and devices.
 - a. MAC Address
2. Every BACnet device shall have an assigned and documented MAC Address unique to its network.
 - a. For Ethernet networks, document the MAC Address assigned at its creation.
 - b. For ARCNET or MS/TP, assign from 00 to 64.
3. Network Numbering
 - a. Assign unique numbers to each new network installed on the BACnet internetwork.
 - b. Provide ability for changing the network number; either by device switches, network computer, or field operator interface. The BACnet internetwork (all possible connected networks) can contain up to 65,534 possible unique networks.
4. Device Object Identifier Property Number
 - a. Assign unique Device "Object_Identifier" property numbers or device instances for each device on the BACnet internetwork.
 - b. Provide for future modification of the device instance number; either by device switches, network computer, or field interface. BACnet allows up to 4,194,302 possible unique devices per internetwork.
5. Device Object Name Property Text
 - a. The Device Object Name property field shall support 32 minimum printable characters.
 - b. Assign unique Device "Object_Name" property names with plain-English descriptive names for each device For example, the Device Object Name that for the device controlling the chiller plant at Building 3408 would be:
 - 1) Device Object_Name = CW System B3408
 - 2) A Device Object Name for a VAV box controller might be: Device Object_Name = VAV BOX25
6. Object Name Property Text (Other than Device Objects)
 - a. The Object Name property field shall support 32 minimum printable characters.
 - b. Assign Object Name properties with plain-English names descriptive of the application.
 - 1) Examples include "Zone 1 Temperature" and "Fan Start/Stop".
7. Object Identifier Property Number (Other than Device Objects)

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Assign Object Identifier property numbers according to design drawings or tables if provided.
- b. If not provided, Object Identifier property numbers may be assigned at the Contractor's discretion but must be approved by the Engineer. In this case they must be documented and unique for like object types within the device.

B. Minimum BACnet Object Requirements

1. Use of Standard BACnet Objects

- a. For the following points and parameters, use standard BACnet objects, where all relevant object properties can be read using BACnet's Read Property Service, and all relevant object properties can be modified using BACnet's Write Property Service:
 - 1) all device physical inputs and outputs, all set points, all PID tuning parameters, all calculated pressures, flow rates, and consumption values, all alarms, all trends, all schedules, and all equipment and lighting circuit operating status.

2. BACnet Object Description Property

- a. The Object Description property shall support 32 minimum printable characters.
- b. For each object, complete the description property field using a brief, narrative, plain English description specific to the object and project application.
 - 1) For example: "HW Pump 1 Proof." Document compliance, length restrictions, and whether the description is writeable in the device PICS.

3. Analog Input, Output, and Value Objects

- a. Support and provide Description and/or Device_Type text strings matching signal type and engineering units shown on the points list.

4. Binary Input, Output, and Value Objects

- a. Support and provide Inactive_Text and Active_Text property descriptions matching conditions shown on the points list.

5. Calendar Object

- a. For devices with scheduling capability, provide at least one Calendar Object with ten-entry capacity.
- b. All operators may view Calendar Objects; authorized operators may make modifications from a workstation. Enable the writeable Date List property and support all calendar entry data types.

6. Schedule Object

- a. Use Schedule Objects for all building system scheduling.

WAYNE STATE UNIVERSITY
 MATTHAEI PHYSICAL EDUCATION CENTER
 ADDITION OF AIR CONDITIONING

- b. All operators may view schedule entries; authorized operators may modify schedules from a workstation.

7. Loop Object or Equal

- a. Use Loop Objects or equivalent BACnet objects in each applicable field device for PID control.
- b. Regardless of program method or object used, allow authorized operators to adjust the Update Interval, Setpoint, Proportional Constant, Integral Constant, and Derivative Constant using BACnet read/write services.

C. Minimum BACnet Service Requirements

1. Command Priorities

- a. Use commandable BACnet objects to control machinery and systems, providing the priority levels listed below. If the sequence of operation requires a different priority, obtain approval from the Engineer.

<u>Priority Level</u>	<u>Application</u>
1	Manual-Life Safety
2	Automatic-Life Safety
3	(User Defined)
4	(User Defined)
5	Critical Equipment Control
6	Minimum On/Off
7	(User Defined)
8	Manual Operator
9	(User Defined)
10	(User Defined)
11	Load Shedding
12	(User Defined)
13	(User Defined)
14	(User Defined)
15	(User Defined)
16	(User Defined)

2. Alarming

- a. Alarm Priorities - Coordinate alarm and event notification with the DDC SYSTEM Owner.
- b. Notification Class – Enable writeable Priority, Ack Required, and Recipient List properties of Notification Class objects.
- c. Event Notification Message Texts - Use condition specific narrative text and numerical references for alarm and event notification.

3. Updating Displayed Property Values

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Allow workstations to display property values at discrete polled intervals, or based on receipt of confirmed and unconfirmed Change of Value notifications. The COV increment shall be adjustable by an operator using BACnet services, and polled intervals shall be adjustable at the operator workstation.

D. Local Area Networks

1. Obtain Owner approval before connecting new networks with existing networks. Network numbers and device instance numbers shall remain unique when joining networks. Do not change existing network addressing without Owner approval. See also "BACnet Naming and Addressing".

E. BACnet Routers, Bridges, and Switches

1. Provide the quantity of BACnet routers, bridges, and switches necessary for communications shown on the BACnet Communication Architecture schematic. Provide BACnet routers with BACnet Broadcast Message Device (BBMD) capability on each BACnet internetwork communicating across an IP network. Configure each BACnet device and bridge, router, or switch to communicate on its network segment.

F. Wiring Criteria

1. Run circuits operating at more than 100 volts in rigid or flexible conduit, metallic tubing, covered metal raceways, or armored cable.
2. Do not run binary control circuit wiring in the same conduit as power wiring over 100 volts.
 - a. Where analog signal wiring requires conduit, do not run in the same conduit with AC power circuits or control circuits operating at more than 100 volts.
3. Provide circuit and wiring protection required by NFPA 70.
4. Run all wiring located inside mechanical rooms in conduit.
5. Do not bury aluminum-sheathed cable or aluminum conduit in concrete.
6. Input/output identification:
 - a. Permanently label each field-installed wire, cable, and pneumatic tube at each end with descriptive text using a commercial wire marking system that fully encircles the wire, cable, or tube. Locate the markers within 2 inches of each termination. Match the names and I/O number to the project's point list. Similarly label all power wiring serving control devices, including the word "power" in the label.
7. Number each pneumatic tube every six feet. Label all terminal blocks with alpha/numeric labels. All wiring and the wiring methods shall be in accordance with UL 508A.
8. For controller power, provide new 120 VAC circuits, with ground.
9. Provide each circuit with a dedicated breaker, and run wiring in its own conduit, separate from any control wiring.
 - a. Connect the controller's ground wire to the electrical panel ground; conduit grounds are not acceptable.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

10. Surge Protection:
 - a. Install surge protection according to manufacturer's instructions. Multiple controllers fed from a common power supply may be protected by a common surge protector, properly sized for the total connected devices.
11. Grounding:
 - a. Ground controllers and cabinets to a good earth ground as specified in Section 26. Conduit grounding is not acceptable; all grounding shall have a direct path to the building earth ground. Ground sensor drain wire shields at the controller end.
12. The Contractor shall be responsible for correcting all associated ground loop problems.
13. Run wiring in panel enclosures in covered wire track.

G. Accessibility

1. Install all equipment so that parts requiring periodic inspection, operation, maintenance, and repair are readily accessible.
2. Install digital controllers, data ports, and concealed actuators, valves, dampers, and like equipment in locations freely accessible through access doors.

H. Digital Controllers

1. Install as standalone control devices (see definitions).
2. Locate control cabinets at the locations shown on the drawings.
3. If not shown on the drawings, install in the most accessible space, close to the controlled equipment.

I. Hand-Off-Auto Switches

1. Wire safety controls such as smoke detectors and freeze protection thermostats to protect the equipment during both hand and auto operation.

J. Temperature Sensors

1. Install temperature sensors in locations that are accessible and provide a good representation of sensed media. Installations in dead spaces are not acceptable. Calibrate sensors according to manufacturer's instructions. Do not use sensors designed for one application in a different application.

K. Room Temperature Sensors

1. Mount the sensors on interior walls to sense the average room temperature at the locations indicated.
2. Avoid locations near heat sources such as copy machines or locations by supply air outlet drafts.
3. Mount the center of the sensor 4 feet above the finished floor to meet ADA requirements.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

L. Duct Temperature Sensors

1. Probe Type:
 - a. Provide a gasket between the sensor housing and the duct wall.
 - b. Seal the duct penetration air tight. Seal the duct insulation penetration vapor tight.
2. Averaging Type (and coil freeze protection thermostats):
 - a. Weave the capillary tube sensing element in a serpentine fashion perpendicular to the flow, across the duct or air handler cross-section, using durable non-metal supports. Prevent contact between the capillary and the duct or air handler internals. Provide a duct access door at the sensor location. The access door shall be hinged on the side, factory insulated, have cam type locks, and be as large as the duct will permit, maximum 18 by 18 inches.
 - b. For sensors inside air handlers, the sensors shall be fully accessible through the air handler's access doors without removing any of the air handler's internals.

M. Immersion Temperature Sensors

1. Provide thermowells for sensors measuring piping, tank, or pressure vessel temperatures. Locate wells to sense continuous flow conditions. Do not install wells using extension couplings. Where piping diameters are smaller than the length of the wells, provide wells in piping at elbows to sense flow across entire area of well. Wells shall not restrict flow area to less than 70 percent of pipe area. Increase piping size as required to avoid restriction.
2. Provide thermal conductivity material within the well to fully coat the inserted sensor.

N. Outside Air Temperature Sensors

1. Provide outside air temperature sensors in weatherproof enclosures on the north side of the building, away from exhaust hoods and other areas that may affect the reading. Provide a shield to shade the sensor from direct sunlight.

O. Energy Meters

1. Locate energy meters as indicated.
2. Connect each meter output to the DDC system, to measure both instantaneous and accumulated energy usage, and as described in the sequence of operations.

P. Damper Actuators

1. Where possible, mount actuators outside the air stream in accessible areas.

Q. Thermometers and Gages

1. Mount devices to allow reading while standing on the floor or ground, as applicable.

R. Pressure Sensors

1. Locate pressure sensors as indicated.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

S. Pneumatic Tubing

1. Run tubing concealed in finished areas, run tubing exposed in unfinished areas like mechanical rooms.
2. For tubing enclosed in concrete, provide rigid metal conduit.
3. Run tubing parallel and perpendicular to building walls.
 - a. Use 5 foot maximum spacing between tubing supports.
 - b. With the compressor turned off, test each tubing system pneumatically at 1.5 times the working pressure and prove it air tight, locating and correcting leaks as applicable. Caulking joints is not permitted. Do not run tubing and electrical power conductors in the same conduit.

T. Component Identification Labeling

1. Using an electronic hand-held label maker with white tape and bold black block lettering, provide an identification label on the exterior of each new control panel, control device, actuator, and sensor.
 - a. Also provide labels on the exterior of each new control actuator indicating the (full) open and (full) closed positions. For labels located outdoors, use exterior grade label tape, and provide labels on both the inside and outside of the panel door or device cover.
2. Acceptable alternatives are white plastic labels with engraved bold black block lettering permanently attached to the control panel, control device, actuator, and sensor. Have the labels and wording approved by the DDC SYSTEM Owner prior to installation.

U. Network Communication Lines

1. When network connections by the Owner are required, provide the Owner at least 60 days advance notice of need.

3.2 TEST AND BALANCE SUPPORT

A. The controls contractor shall coordinate with and provide on-site support to the test and balance (TAB) personnel [specified under Section 23 TESTING, ADJUSTING AND BALANCING.

1. This support shall include:
 - a. On-site operation and manipulation of control systems during the testing and balancing.
 - b. Control setpoint adjustments for balancing all relevant mechanical systems, including VAV boxes.
 - c. Tuning control loops with setpoints and adjustments determined by TAB personnel.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.3 POST WARRANTY END DATE SUPPORT

- A. See CONTROLS SYSTEM OPERATORS MANUALS below.
- B. See RE-CALIBRATION Requirements below

3.4 CONTROLS SYSTEM OPERATORS MANUALS

- A. Provide four electronic and printed copies of a Controls System Operators Manual. The manual shall be specific to the project, written to actual project conditions, and provide a complete and concise depiction of the installed work.
 - 1. Provide information in detail to clearly explain all operation requirements for the control system.
- B. Provide with each manual: CDs of the project's control system drawings, control programs, data bases, graphics, and all items listed below. Include gateway back-up data and configuration tools where applicable.
- C. Provide CDs in jewel case with printed and dated project-specific labels on both the CD and the case.
 - 1. For text and drawings, use Adobe Acrobat or MS Office file types.
 - 2. When approved by the Engineer, AutoCAD and Visio files are allowed.
 - 3. Give files descriptive English names and organize in folders.
- D. Provide printed manuals in sturdy 3-ring binders with a title sheet on the outside of each binder indicating the project title, project location, contract number, and the controls contractor name, address, and telephone number.
 - 1. Each binder shall include a table of contents and tabbed dividers, with all material neatly organized.
 - 2. Manuals shall include the following:
 - a. A copy of the as-built control system (shop) drawings set, with all items specified under the paragraph "Submittals." Indicate all field changes and modifications.
 - b. A copy of the project's mechanical design drawings, including any official modifications and revisions.
 - c. A copy of the project's approved Product Data submittals provided under the paragraph "Submittals."
 - d. A copy of the project's approved Performance Verification Testing Plan and Report.
 - e. A copy of the project's approved final TAB Report.
 - f. Printouts of all control system programs, including controller setup pages if used. Include plain-English narratives of application programs, flowcharts, and source code.
 - g. Printouts of all physical input and output object properties, including tuning values, alarm limits, calibration factors, and set points.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- h. A table entitled "AC Power Table" listing the electrical power source for each controller.
 - 1) Include the building electrical panel number, panel location, and circuit breaker number.
- i. The DDC manufacturer's hardware and software manuals in both print and CD format with printed project-specific labels. Include installation and technical manuals for all controller hardware, operator manuals for all controllers, programming manuals for all controllers, operator manuals for all workstation software, installation and technical manuals for the workstation and notebook, and programming manuals for the workstation and notebook software.
- j. A list of qualified control system service organizations for the work provided under this contract.
 - 1) Include their addresses and telephone numbers.
- k. A written statement entitled "Technical Support" stating the control system manufacturer or authorized representative will provide toll-free telephone technical support at no additional cost to the Owner for a minimum of two years from warranty start date, shall be furnished by experienced service technicians, and will be available during normal weekday working hours.
 - 1) Include the toll-free technical support telephone number.
- l. A written statement entitled "Software Upgrades" stating software and firmware patches and updates shall be provided at no additional cost to the Owner for a minimum of two years from warranty start date. Include a table of all DDC system software and firmware provided under this contract, listing the original release dates, version numbers, part numbers, and serial numbers.

3.5 PERFORMANCE VERIFICATION TESTING (PVT)

A. General

- 1. The PVT shall demonstrate compliance of the control system work with the contract requirements. The PVT shall be performed by the Contractor and witnessed and approved by the Engineer.
- 2. If the project is phased, provide separate testing for each phase. A Pre-PVT meeting to review the Pre-PVT Checklist is required to coordinate all aspects of the PVT and shall include the Contractor's QA representative, the Contractor's PVT administrator, and the Owner.

B. Performance Verification Testing Plan

- C. Submit a detailed PVT Plan of the proposed testing for Engineer approval. Develop the PVT Plan specifically for the control system in this contract. The PVT Plan shall be a clear list of test items arranged in a logical sequence.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Include the intended test procedure, the expected response, and the pass/fail criteria for every component tested.
2. The plan shall clearly describe how each item is tested, indicate where assisting personnel are required (like the mechanical contractor), and include what procedures are used to simulate conditions.
3. Include a separate column for each checked item and extra space for comments.

D. PVT Sample Size

1. Test all central plant equipment and primary air handling unit controllers unless otherwise directed.
2. Twenty percent sample testing is allowed for identical controllers typical of terminal control like VAV boxes and fan coil units.
3. The Engineer may require testing of like controllers beyond a statistical sample if sample controllers require retesting or do not have consistent results.
4. The Engineer may witness all testing, or random samples of PVT items. When only random samples are witnessed, the Engineer may choose which ones.

E. Pre-Performance Verification Testing Checklist

1. Submit the following as a list with items checked off once verified. Provide a detailed explanation for any items that are not completed or verified.
 - a. Verify all required mechanical installation work is successfully completed, and all HVAC equipment is working correctly (or will be by the time the PVT is conducted).
 - b. Verify all required control system components, wiring, and accessories are installed.
 - c. Verify the installed control system architecture matches approved drawings.
 - d. Verify all control circuits operate at the proper voltage and are free from grounds or faults.
 - e. Verify all required surge protection is installed.
 - f. Verify the A/C Power Table specified in "CONTROLS SYSTEM OPERATORS MANUALS" is accurate.
 - g. Verify all DDC network communications function properly, including uploading and downloading programming changes.
 - h. Using the BACnet protocol analyzer, verify communications are error free.
 - i. Verify each digital controller's programming is backed up.
 - j. Verify all wiring, components, and panels are properly labeled.
 - k. Verify all required points are programmed into devices.
 - l. Verify all TAB work affecting controls is complete.
 - m. Verify all valve and actuator zero and span adjustments are set properly.
 - n. Verify all sensor readings are accurate and calibrated.
 - o. Verify each control valve and actuator goes to normal position upon loss of power.
 - p. Verify all control loops are tuned for smooth and stable operation. View trend data where applicable.
 - q. Verify each controller works properly in stand-alone mode.
 - r. Verify all safety controls and devices function properly, including freeze protection and interfaces with building fire alarm systems.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- s. Verify all electrical interlocks work properly.
 - t. Verify all workstations, notebooks and maintenance personnel interface tools are delivered, all system and database software is installed, and graphic pages are created for each workstation and notebook.
 - u. Verify the as-built (shop) control drawings are completed.
2. Conducting Performance Verification Testing
- a. Conduct Engineer-witnessed PVT after approval of the PVT Plan and the completed Pre-PVT Checklist.
 - b. Notify the engineer of the planned PVT at least 15 days prior to testing. Provide an estimated time table required to perform the testing. Furnish personnel, equipment, instrumentation, and supplies necessary to perform all aspects of the PVT. Ensure that testing personnel are regularly employed in the testing and calibration of DDC systems. Using the project's as-built control system drawings, the project's mechanical design drawings, the approved Pre-PVT Checklist, and the approved PVT Plan, conduct the PVT.
 - c. During testing, identify any items that do not meet the contract requirements and if time permits, conduct immediate repairs and re-test. Otherwise, deficiencies shall be investigated, corrected, and re-tested later.
 - d. Document each deficiency and corrective action taken.
 - e. If re-testing is required, follow the procedures for the initial PVT.
 - f. The Engineer may require re-testing of any control system components affected by the original failed test.

F. Controller Capability and Labeling

1. Test the following for each controller:
- a. Memory:
 - 1) Demonstrate that programmed data, parameters, and trend/ alarm history collected during normal operation is not lost during power failure.
 - b. Direct Connect Interface:
 - 1) Demonstrate the ability to connect directly to each type of digital controller with a portable electronic device like a notebook computer.
 - 2) Show that maintenance personnel interface tools perform as specified in the manufacturer's technical literature.
 - c. Stand Alone Ability:
 - 1) Demonstrate controllers provide stable and reliable stand-alone operation using default values or other method for values normally read over the network.
 - d. Wiring and AC Power:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- 1) Demonstrate the ability to disconnect any controller safely from its power source using the AC Power Table. Demonstrate the ability to match wiring labels easily with the control drawings. Demonstrate the ability to locate a controller's location using the BACnet Communication Architecture Schematic and floor plans.

e. Nameplates and Tags:

- 1) Show the nameplates and tags are accurate and permanently attached to control panel doors, devices, sensors, and actuators.

G. Workstation and Software Operation

1. For every user workstation or notebook provided:
 - a. Show points lists agree with naming conventions.
 - b. Show that graphics are complete.

H. BACnet Communications and Interoperability Areas

1. Demonstrate proper interoperability of data sharing, alarm and event management, trending, scheduling, and device and network management.
2. If available or required in this specification, use a BACnet protocol analyzer to assist with identifying devices, viewing network traffic, and verifying interoperability. These requirements must be met even if there is only one manufacturer of equipment installed. Testing includes the following:
 - a. Data Presentation: On each BACnet Operator Workstation, demonstrate graphic display capabilities.
 - b. Reading of Any Property: Demonstrate the ability to read and display any used readable object property of any device on the network.
 - c. Setpoint and Parameter Modifications: Show the ability to modify all setpoints and tuning parameters in the sequence of control or listed on project schedules. Modifications are made with BACnet messages and write services initiated by an operator using workstation graphics, or by completing a field in a menu with instructional text.
 - d. Peer-to-Peer Data Exchange: Show all BACnet devices are installed and configured to perform BACnet read/write services directly (without the need for operator or workstation intervention), to implement the project sequence of operation, and to share global data.
 - e. Alarm and Event Management: Show that alarms/events are installed and prioritized according to the DDC SYSTEM Owner.
 - f. Demonstrate time delays and other logic is set up to avoid nuisance tripping, e.g., no status alarms during unoccupied times or high supply air during cold morning start-up. Show that operators with sufficient privilege can read and write alarm/event parameters for all standard BACnet event types. Show that operators with sufficient privilege can change routing (BACnet notification classes) for each alarm/event including the destination, priority, day of week, time of day, and the type of transition involved (TO-OFF NORMAL, TO-NORMAL, etc.).

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- g. Schedule Lists: Show that schedules are configured for start/stop, mode change, occupant overrides, and night setback as defined in the sequence of operations.
- h. Schedule Display and Modification: Show the ability to display any schedule with start and stop times for the calendar year. Show that all calendar entries and schedules are modifiable from any connected workstation by an operator with sufficient privilege.
- i. Archival Storage of Data: Show that data archiving is handled by the operator workstation/server, and local trend archiving and display is accomplished with BACnet Trend Log objects.
- j. Modification of Trend Log Object Parameters: Show that an operator with sufficient privilege can change the logged data points, sampling rate, and trend duration.
- k. Device and Network Management: Show the following capabilities:
 - 1) Display of Device Status Information
 - 2) Display of BACnet Object Information
 - 3) Silencing Devices that are Transmitting Erroneous Data
 - 4) Time Synchronization
 - 5) Remote Device Re-initialization
 - 6) Backup and Restore Device Programming and Master Database(s)
 - 7) Configuration Management of Half-Routers, Routers and BBMDs

- I. Execution of Sequence of Operation: Demonstrate that the HVAC system operates properly through the complete sequence of operation. Use read/write property services to globally read and modify parameters over the internetwork.

- J. Control Loop Stability and Accuracy
 - 1. For all control loops tested, give the Engineer trend graphs of the control variable over time, demonstrating that the control loop responds to a 20 percent sudden change of the control variable set point without excessive overshoot and undershoot.
 - a. If the process does not allow a 20 percent set point change, use the largest change possible. Show that once the new set point is reached, it is stable and maintained.
 - b. Control loop trend data shall be in real-time with the time between data points 30 seconds or less.

- K. Performance Verification Testing Report
 - 1. Upon successful completion of the PVT, submit a PVT Report to the Engineer and prior to the Engineer taking use and possession of the facility. Do not submit the report until all problems are corrected and successfully re-tested.
 - a. The report shall include the annotated PVT Plan used during the PVT.
 - b. Where problems were identified, explain each problem and the corrective action taken. Include a written certification that the installation and testing of the control system is complete and meets all of the contract's requirements.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.6 TRAINING REQUIREMENTS

- A. Provide a qualified instructor (or instructors) with two years minimum field experience with the installation and programming of similar BACnet DDC systems.
 - 1. Orient training to the specific systems installed. Coordinate training times with the Owner after receiving approval of the training course documentation. Training shall take place at the job site. A training day shall occur during normal working hours, last no longer than 8 hours and include a one-hour break for lunch and two additional 15-minute breaks.
 - 2. The project's approved Controls System Operators Manual shall be used as the training text.
 - 3. The Contractor shall ensure the manuals are submitted, approved, and available to hand out to the trainees before the start of training.

- B. Training Documentation
 - 1. Submit training documentation for review 30 days minimum before training. Documentation shall include an agenda for each training day, objectives, a synopsis of each lesson, and the instructor's background and qualifications.
 - 2. The training documentation can be submitted at the same time as the project's Controls System Operators Manual.

- C. Phase I Training - Fundamentals
 - 1. The Phase I training session shall last one day and be conducted in a classroom environment with complete audio-visual aids provided by the contractor.
 - a. Provide each trainee a printed 8.5 by 11 inch hard-copy of all visual aids used.
 - 2. Upon completion of the Phase I Training, each trainee should fully understand the project's DDC system fundamentals.
 - 3. The training session shall include the following:
 - a. BACnet fundamentals (objects, services, addressing) and how/where they are used on this project
 - b. This project's list of control system components
 - c. This project's list of points and objects
 - d. This project's device and network communication architecture
 - e. This project's sequences of control, and:
 - f. Alarm capabilities
 - g. Trending capabilities
 - h. Troubleshooting communication errors
 - i. Troubleshooting hardware errors

- D. Phase II Training - Operation
 - 1. Provide Phase II Training shortly after completing Phase I Training.
 - 2. The Phase II training session shall last one day and be conducted at the DDC system workstation, at a notebook computer connected to the DDC system in the field, and at

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

other site locations as necessary. Upon completion of the Phase II Training, each trainee should fully understand the project's DDC system operation.

3. The training session shall include the following:
 - a. A walk-through tour of the mechanical system and the installed DDC components (controllers, valves, dampers, surge protection, switches, thermostats, sensors, etc.)
 - b. A discussion of the components and functions at each DDC panel
 - c. Logging-in and navigating at each operator interface type
 - d. Using each operator interface to find, read, and write to specific controllers and objects
 - e. Modifying and downloading control program changes
 - f. Modifying setpoints
 - g. Creating, editing, and viewing trends
 - h. Creating, editing, and viewing alarms
 - i. Creating, editing, and viewing operating schedules and schedule objects
 - j. Backing-up and restoring programming and data bases
 - k. Modifying graphic text, backgrounds, dynamic data displays, and links to other graphics
 - l. Creating new graphics and adding new dynamic data displays and links
 - m. Alarm and Event management
 - n. Adding and removing network devices

- E. All training shall be video-taped by the HVAC contractor. Two copies shall be turned over to the Owner's maintenance staff.

3.7 TREND LOG REQUIREMENTS

- A. The DDC System Contractor shall perform data trend logging and reporting for monitoring the performance of the systems and facility through a one-year period commencing on the warranty start date. Trend points shall as be established by the Commissioning Agent and A/E. Trend reports shall be provided to the Commissioning Agent and A/E monthly.

END OF SECTION 230923

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 23 0993

SEQUENCE OF OPERATIONS FOR HVAC CONTROLS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes control sequences for HVAC systems, subsystems, and equipment.
- B. See Division 23 Section "23 09 23 "DDC Control Systems for HVAC" for control equipment and devices and for submittal requirements.

1.2 GENERAL

- A. The contractor shall furnish, install and place in operating condition an HVAC control system to sequence the equipment as described below.

1.3 VAV ROOFTOP UNITS RTU-103

A. General Operation

- 1. The RTU operates as a variable air volume system and consists of:
 - a. supply fan(s) with variable frequency drive(s);
 - b. power exhaust fan(s) with variable frequency drive(s),
 - c. evaporator and compressor/condenser sections,
 - d. economizer,
 - e. air filters,
 - f. modulating gas fired heat exchanger.
- 2. The RTU is scheduled for automatic operation through the Building Automation System for occupied and unoccupied modes.

B. Occupied Mode:

- 1. The supply fan shall start, the outside air and return air dampers shall be positioned as required to maintain minimum outdoor air (CFM) setpoint, and the exhaust fan shall start. Modulating gas heating and direct expansion cooling operate in sequence and without overlap to maintain discharge air temperature set point of 55°F (adj.). The supply air fan speed shall modulate to maintain supply air duct static pressure set point.
- 2. Supply Fan Control -
 - a. A duct mounted sensor shall determine the supply air duct static pressure control point and shall operate the supply fan variable frequency drive.
 - b. The Building Automation System (BAS) shall monitor the damper position of each terminal unit associated with the RTU
 - c. Supply fan motor speed shall not fall below 25% rated speed, and shall not exceed 100% rated speed.
- 3. Exhaust Fan Control - Building Pressurization.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. The exhaust fan speed shall modulate to maintain building pressurization set point. When the indoor pressure falls below set point, the exhaust fan speed shall reduce to minimum speed.
4. Supply Air Temperature Reset:

When the outdoor air temperature is above 55F (adj), the supply air temperature will be maintained at 55F (adj). When the outdoor air temperature is below 55F (adj), the supply air temperature shall be linearly reset between 55F (adj) and 60F (adj) as follows; when the outside air temperature is above 55F (adj) RTU supply air temperature is 55F and when the outside air temperature is below 10F (adj) the supply air temperature is 60F (adj).
 5. Economizer operation:
 - a. When the outside air dry bulb temperature is below the return air dry bulb temperature, economizer operation “free cooling” shall be allowed. The outdoor air and relief air dampers, gas fired heat exchanger and DX cooling coil shall operate in sequence and without overlap to maintain discharge air temperature. The unit shall maximize economizer operation by allowing the cooling coil to operate during economizer. When the outdoor air dry bulb temperature is above the return air dry bulb temperature, economizer operation is disabled. During economizer operation, the outdoor air airflow rate shall not fall below minimum outdoor air airflow setpoint.
 - b. Economizer Relief:
 - 1) When operating in economizer mode, the exhaust fan speed will modulate speed as required to maintain building pressure setpoint.
 - 2) If the exhaust fan is in failure, the exhaust fan will be commanded Off.
- C. Unoccupied Mode
1. The supply fan is off, DX cooling is de-energized, the gas heat exchanger is off, the outdoor air dampers are closed, the exhaust fan is off, and all terminal units associated with the RTU enter unoccupied mode.
 2. Unoccupied heating –When the space temperature of a connected VAV terminal falls below the unoccupied heating setpoint of 60F (adj), the rooftop unit shall be enabled. The outside air dampers remain closed, the exhaust fan is off. The supply fan recirculates air throughout the system, and the terminal unit electric heating coils provide heat to the space. When activated, the RTU shall maintain 60F (adj) minimum discharge air temperature and the BAS shall open the air damper in sufficient terminal units to allow the RTU to exceed minimum supply CFM operation.
 3. Unoccupied cooling –When the space temperature of a connected VAV terminal rises above the unoccupied cooling setpoint of 85F (adj), the rooftop unit shall start and supply 55F (adj.) air. The outdoor air dampers remain closed, the exhaust fan is off, and the energy recovery wheel is off. The terminal unit serving that particular space shall go to full cooling mode. The BAS shall open the air damper in sufficient terminal units to allow the RTU to exceed minimum supply CFM operation. When the critical zone space temperature falls below 80F, the RTU shall stop.
 - a. Economizer operation shall be utilized if the outdoor air dry bulb temperature is less than the return air temperature; see “Economizer Operation” in Occupied Mode above.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

4. Unoccupied override - Each terminal unit room temperature sensor has an override pushbutton which when depressed during unoccupied mode causes the associated RTU to enter occupied mode for 2 hours to allow the space to be ventilated, cooled or heated. Other terminal units shall go to occupied mode as required to allow the RTU to exceed minimum supply CFM operation.
5. Morning warm-up – The BAS shall monitor each zone temperature and outdoor air temperature and automatically start the RTU prior to the occupancy schedule start time based on “optimal start time” to bring all the spaces up to occupied setpoint temperature by occupied start time. During this period of operation, the outdoor air dampers remain closed, the return air dampers are open, the exhaust fan is off, and the enthalpy wheel is off. During morning warm-up, the RTU shall discharge 75F (adj.) supply air, all terminal units shall operate at maximum cooling CFM setpoint, and all terminal units electric heating coils shall cycle as required to maintain room temperature setpoint. This is to allow the RTU to provide additional gas-fired heat for morning warm-up, minimizing the amount of electric heat required. When a room temperature rises above the occupied heating setpoint, the VAV boxes shall enter occupied mode, and all VAV’s shall enter occupied mode at occupied period start time.
6. Morning cool-down - The BAS shall monitor each zone temperature and outdoor air temperature and automatically start the RTU prior to the occupancy schedule start time based on “optimal start time” to bring all the spaces down to occupied setpoint temperature by occupied start time. During this period of operation the outdoor air dampers remain closed, the return air dampers are open, the exhaust fan is off, and the enthalpy wheel is off. During morning cool-down, the RTU shall discharge 55F (adj.) supply air and each terminal unit shall operate in occupied mode.
 - a. Economizer operation shall be utilized if the outside air enthalpy is less than the return air enthalpy; see “Economizer Operation” in Occupied Mode above.

D. External Safeties

1. Fire alarm manufacturer provided smoke detectors, installed in the return air duct shall automatically shut-down the RTU when activated. The RTU shall automatically restart after the fire alarm system has been reset.
2. Activation of any fire alarm pull station or fire sprinkler system water flow switch shall automatically shut-down the RTU when activated. The RTU shall automatically restart after the fire alarm system has been reset.
3. A differential pressure switch will measure the pressure drop across the air filters. When the pressure drop exceeds the setpoint and alarm will be generated by the BAS to alert operating staff to replace the filters.
4. A supply duct high limit static pressure switch mounted in the supply air ductwork shall shut down supply fan operation when its setpoint is exceeded.
5. Outside air: If the outside airflow rate is 10% less than the minimum outside air setpoint, an alarm shall be generated.

1.4 SINGLE-ZONE COOLING ONLY ROOFTOP UNITS (RTU-105)

A. General Operation

1. The RTU is scheduled for automatic operation through the Building Automation System for occupied and unoccupied modes upon a call for **cooling** only. Upon cooling operation, the existing 6 HV units (HV- 3,4,5,6,9,10) will deactivated via an EP switch. All HV have pneumatic controls for mixed, relief, and outside air. The return and supply runs run continuously in the building.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. RTU-105 shall be deactivated when the space stat is in a call for heating. The EP switches shall allow the 6 HV units to operate in heating mode.

B. Occupied Mode

1. The supply fan shall start or continue to run, the outside air damper is modulated to maintain ventilation set point while and DX cooling operate in sequence and without overlap to maintain discharge air temperature set point. The supply air fan speed shall modulate as required to maintain space temperature set point.
2. Integrated economizer control – comparative dry bulb: When the outdoor air dry bulb temperature is below the return air dry bulb temperature, the mixed air dampers modulate and mechanical cooling operates in sequence as required to maintain the supply air temperature set point of 55°F, with a low limit of 42°F at the mixed air sensor. If, when the outdoor damper is fully open, the economizer cannot meet the discharge air temperature setpoint, mechanical cooling shall operate as required to meet the discharge air temperature setpoint. The mixing dampers shall ramp open slowly to avoid overshooting. When the outside enthalpy is above the economizer changeover value, the mixing dampers are placed in minimum outdoor air position as determined by the ventilation set point and mechanical cooling operates to maintain the supply air temperature set point.
3. Supply air temperature reset. The supply air temperature set point shall be reset based on outside air temperature. The supply air temperature set point shall be 60°F at 45°F and lower outside air temperature and reset proportionally to 55°F at 55°F and higher outside air temperature.

C. Unoccupied mode

1. The supply fan is off and the mixed air dampers close to the outdoor air.

D. Safety:

1. Smoke detectors. Fire alarm manufacturer provided smoke detectors installed in the return air streams shall de-energize the supply fan upon activation. All dampers and valves shall return to their normal positions after the fan is completely de-energized.
2. End switches. End switches installed on dampers shall ensure the dampers are fully opened before the fans are allowed to start.
3. Current switches. Current switches are installed at the supply fans. The control system uses the switch to confirm the fan is in the desired state and generates an alarm signal if status deviates from the start/stop control

E. Trend logs

1. Trend log 1: Trend outside air temperature, supply air temperature set point, actual supply air temperature, and space temperature every 15 minutes.

1.5 SINGLE-ZONE ROOFTOP UNITS (RTU-108)

A. General Operation

1. The RTU is scheduled for automatic operation through the Building Automation System for occupied and unoccupied modes.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- B. Within the unoccupied mode, the system can enter the warm-up mode when the space temperature is below set point or the cool-down mode when the space temperature is above set point. The system stays in warm-up or cool-down mode until the mode set point is satisfied. Within the unoccupied mode, night heating is available when the space temperature drops below 60°F (adj.).
- C. Occupied Mode
1. The supply fan shall start or continue to run, the outside air damper is modulated to maintain ventilation set point while gas heating and DX cooling operate in sequence and without overlap to maintain discharge air temperature set point. The supply air fan speed shall modulate as required to maintain space temperature set point.
 2. Integrated economizer control – comparative dry bulb: When the outdoor air dry bulb temperature is below the return air dry bulb temperature, the mixed air dampers modulate and mechanical cooling operates in sequence as required to maintain the supply air temperature set point of 55°F, with a low limit of 42°F at the mixed air sensor. If, when the outdoor damper is fully open, the economizer cannot meet the discharge air temperature setpoint, mechanical cooling shall operate as required to meet the discharge air temperature setpoint. The mixing dampers shall ramp open slowly to avoid overshooting. When the outside enthalpy is above the economizer changeover value, the mixing dampers are placed in minimum outdoor air position as determined by the ventilation set point and mechanical cooling operates to maintain the supply air temperature set point.
- D. Unoccupied mode
1. The supply fan is off and the mixed air dampers close to the outdoor air.
- E. Safety:
1. Smoke detectors. Fire alarm manufacturer provided smoke detectors installed in the return air streams shall de-energize the supply fan upon activation. All dampers and valves shall return to their normal positions after the fan is completely de-energized.
- F. Trend logs
1. Trend log 1: Trend outside air temperature, supply air temperature set point, actual supply air temperature, and space temperature every 15 minutes.

1.6 SINGLE-ZONE VAV ROOFTOP UNITS (RTU-101,102,104)

- A. General Operation
1. The RTU is scheduled for automatic operation through the Building Automation System for occupied and unoccupied modes upon a call for **cooling** only. Upon cooling operation, the existing HV units
 - a. RTU-101 serves HV -1
 - b. RTU-102 serves HV-2
 - c. RTU-104 serves HV-108

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. The associated HV unit will be deactivated via an EP switch. All HV have pneumatic controls for mixed, relief, and outside air. The return and supply runs run continuously in the building.
3. The RTU is scheduled for automatic operation through the Building Automation System for occupied and unoccupied modes.

B. Occupied Mode

1. The supply fan shall start or continue to run, the outside air damper is modulated to maintain ventilation set point while heating from existing HV units and DX cooling operate in sequence and without overlap to maintain discharge air temperature set point. The supply air fan speed shall modulate as required to maintain space temperature set point.
2. Integrated economizer control – comparative dry bulb: When the outdoor air dry bulb temperature is below the return air dry bulb temperature, the mixed air dampers modulate and mechanical cooling operates in sequence as required to maintain the supply air temperature set point of 55°F, with a low limit of 42°F at the mixed air sensor. If, when the outdoor damper is fully open, the economizer cannot meet the discharge air temperature setpoint, mechanical cooling shall operate as required to meet the discharge air temperature setpoint. The mixing dampers shall ramp open slowly to avoid overshooting. When the outside enthalpy is above the economizer changeover value, the mixing dampers are placed in minimum outdoor air position as determined by the ventilation set point and mechanical cooling operates to maintain the supply air temperature set point.

C. Heating mode: The RTU unit shall be off and the HV units shall be allowed to operate as normal.

D. Unoccupied mode

1. The supply fan is off and the mixed air dampers close to the outdoor air.

E. Safety:

1. Smoke detectors. Fire alarm manufacturer provided smoke detectors installed in the return air streams shall de-energize the supply fan upon activation. All dampers and valves shall return to their normal positions after the fan is completely de-energized.
2. End switches. End switches installed on dampers shall ensure the dampers are fully opened before the fans are allowed to start.

F. Trend logs

1. Trend log 1: Trend outside air temperature, supply air temperature set point, actual supply air temperature, and space temperature every 15 minutes.

G.

1.7 100% OUTSIDE AIR CONSTANT VOLUME ROOFTOP UNITS (RTU-106 AND 107)

A. General Operation

1. The RTU operates as a constant volume, 100% outside air ventilation system, and consists of:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Constant speed supply fan;
 - b. evaporator and compressor/condenser sections,
 - c. hot gas reheat coil
 - d. air filters,
 - e. 100% outside air intake section,
2. The RTU is scheduled for automatic operation through the Building Automation System for occupied and unoccupied modes.
 3. The humidity sensor in the space shall control the factory installed hot gas reheat coil for operation.
- B. Occupied Mode
1. The supply fan shall start or continue to run at constant speed, the outside air damper is modulated 100% open while gas heating and DX cooling operate in sequence and without overlap to maintain discharge air temperature set point.
 - a. Special note concerning RTU-106,107 The purpose of these units are to supply dehumidified air to the locker rooms.
 2. Heating mode: The RTU unit shall be off and the HV units shall be allowed to operate as normal. All HV have pneumatic controls for mixed, relief, and outside air. The existing return and supply runs run continuously in the building.
- C. The RTU is scheduled for automatic operation through the Building Automation System for occupied and unoccupied modes
- D. Unoccupied mode
1. The supply fan is off and the outdoor air damper is closed.
- E. Safety:
1. Smoke detectors. Fire alarm manufacturer provided smoke detectors installed in the supply air streams shall de-energize the supply fan upon activation. All dampers and valves shall return to their normal positions after the fan is completely de-energized.
 2. End switches. End switches installed on dampers shall ensure the dampers are fully opened before the fans are allowed to start.
- F. Trend logs
1. Trend log 1: Trend outside air temperature, supply air temperature set point, actual supply air temperature, and space temperature every 15 minutes.
- 1.8 SINGLE DUCT SHUTOFF VAV BOX SEQUENCE OF OPERATION
- A. Each VAV box has an SCR modulating electric reheat coil. VAV terminal unit operation is controlled by a controller mounted on the VAV box.
 - B. Heating coil operation – The electric heating coil output is controlled through a single point connection. VAV box heating coil has a discharge air sensor that prevents the supply air temperature from exceeding 90F (adj) during occupied and unoccupied mode. During morning warm-up mode, supply air temperature shall not exceed 100F (adj).

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Each space temperature sensor (unless noted otherwise) has an adjustable lever that will allow the temperature setpoint to be increased or decreased by 2F.
- D. Each space temperature sensor (unless noted otherwise) has an override pushbutton which when depressed during unoccupied periods causes the associated Rooftop Unit to enter occupied mode for 2 hours to allow the space to be ventilated, cooled or heated.
- E. The space served by the VAV terminal unit is controlled in occupied and unoccupied modes as follows;
 - 1. Occupied mode
 - a. The VAV terminal unit is controlled within user defined maximum cooling and minimum cooling primary airflow settings. The VAV terminal unit controller monitors the space temperature sensor and airflow station, and modulates the air damper between minimum and maximum cfm settings to maintain space temperature setpoint. As the space temperature decreases, the VAV terminal unit controller closes the air damper until it reaches minimum cooling cfm and upon a further decrease in space temperature the heating electric reheat coil modulates to maintain space temperature setpoint, and if the space temperature continuous to fall below setpoint, the air damper modulates open up to maximum cooling airflow setting. Space temperature setpoints are 75F during cooling and 70F during heating.
 - 2. Unoccupied mode
 - a. When the Rooftop Unit is in unoccupied mode, the VAV terminal unit is in unoccupied mode. During the unoccupied mode the air damper is fully closed. When a space temperature falls below 60F (adj), the associated Rooftop Unit shall start and the terminal unit shall go to full heating mode and electric reheat coil shall modulate and heat the space. When the critical zone space temperature rises above 65F, the Rooftop Unit shall stop, or, the Rooftop Unit shall operate for a minimum of 30 minutes. When a space temperature rises above 85F (adj), the associated Rooftop Unit shall start and the terminal unit shall go to full cooling mode. When the critical zone space temperature falls below 80F, the Rooftop Unit shall stop, or, the Rooftop Unit shall operate for a minimum of 30 minutes. Whenever the rooftop unit is started, sufficient VAV boxes air dampers shall open to allow Rooftop Unit to operate at minimum supply air cfm.
- F. See Rooftop Unit sequence of operation for unoccupied heating and unoccupied cooling.

1.9 DUCTLESS SPLIT SYSTEM AIR CONDITIONERS

- A. The standalone split system controller controls the system.
- B. Each indoor evaporator fan shall run continuously, varying speed in response to space sensible load, and the compressor shall cycle to maintain a space temperature set point of 72 degrees (adj.) year-round.

During cooling operation of the Ductless splits, the associated HV-1a,1b units shall be deactivated.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

PART 2 - PRODUCTS (Not Applicable)

PART 3 - EXECUTION (Not Applicable)

END OF SECTION

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 232300 - REFRIGERANT PIPING

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes refrigerant piping used for air-conditioning applications.

1.2 SUBMITTALS

- A. Product Data: For each type of valve and refrigerant piping specialty required. Include pressure drop based on manufacturer's test data.
- B. Shop Drawings (For information only, not a reviewed submittal): Show layout of refrigerant piping and specialties, including pipe, tube, and fitting sizes, flow capacities, valve arrangements and locations, slopes of horizontal runs, oil traps, double risers, wall and floor penetrations, and equipment connection details. Show interface and spatial relationships between piping and equipment.
 - 1. Refrigerant piping indicated on Drawings is schematic only. Size piping and design actual piping layout, including oil traps, double risers, specialties, and pipe and tube sizes to accommodate, as a minimum, equipment provided, elevation difference between compressor and evaporator, and length of piping to ensure proper operation and compliance with warranties of connected equipment.
- C. Field quality-control test reports.
- D. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Comply with ASHRAE 15, "Safety Code for Refrigeration Systems."
- B. Comply with ASME B31.5, "Refrigeration Piping and Heat Transfer Components."
- C. If Zoomlock fittings are utilized, qualified installers shall be trained on the safe installation of flame free refrigerant fittings. They should also be licensed within the jurisdiction.
- D. If Zoomlock fittings are utilized, fittings shall be installed using the proper tools and pressing jaws defined by the manufacturer.
- E. Installation of HVAC/R copper tubing shall conform to the requirements of the International Mechanical and Residential Codes and Uniform Mechanical Code.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.4 PRODUCT STORAGE AND HANDLING

- A. Store piping in a clean and protected area with end caps in place to ensure that piping interior and exterior are clean when installed.
- B. Fittings and copper tubing shall be shipped to the job site in such a manner to protect the tubing and fittings. Fittings and tubing shall not be roughly handled during shipment. Tubing and fittings shall be unloaded with reasonable care.
- C. When using a knife for unpacking, take special care not to scratch copper tubing or fittings since this can lead to leaks.

PART 2 - PRODUCTS

2.1 COPPER TUBE AND FITTINGS

- A. Copper Tube: ASTM B 280, Type ACR.
- B. Wrought-Copper Fittings: ASME B16.22.
- C. Wrought-Copper Unions: ASME B16.22.
- D. Brazing Filler Metals: AWS A5.8.

2.2 All valves and specialties to be per manufacturers instructions including but not limited to the following:

- A. Moisture/Liquid Indicators:
- B. Replaceable-Core Filter Dryers: Comply with ARI 730.
- C. Permanent Filter Dryers: Comply with ARI 730.
- D. Liquid Accumulators: Comply with ARI 495.

2.3 ZOOMLOCK flame free fittings are allowed as a contractor option, however confirm compliance with local building codes and authority having jurisdiction.

- A. Klauke 15 kN Compatible Jaws: Hard Drawn Copper: 1/4" to 7/8" Type ACR, M, L, Type K up to 7/8". Soft (Annealed) Copper: 1/4" to 1-1/8" Type ACR, L, Type K up to 7/8".
- B. Klauke 19 kN Jaws and RIDGID Compatible Jaws: Hard Drawn Copper: 1/4" to 1-3/8" Type ACR, M, L, K. Soft (Annealed) Copper: 1/4" to 1-3/8" Type ACR, L, K.
- C. Tubing: The installer shall confirm the copper tubing conforms to ASTM B280, ASTM B88, or EN 12735-1.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Zoomlock Fitting Body: Conform to ASTM-B75 or ASTM-B743.
- E. Zoomlock Fitting Sealing O-Rings: HNBR. These shall be factory installed only.
- F. Zoomlock Compatible ODM Fittings: Material conform to C12200 copper per ASTM B280 or Cu-DHP CW024A per BS EN 12735-1.
- G. Zoomlock Threaded Schraeder Valve Access Fittings: Schraeder style valve material and threads conform to SAE J513.
- H. Zoomlock SAE Threaded Fittings: Flare nuts conform to SAE J513 & SAE J533.

PART 3 - EXECUTION

3.1 PIPING APPLICATIONS

- A. Suction Lines, Hot Gas and Liquid Lines All Sizes to be Copper, Type ACR, annealed-temper tubing and wrought-copper fittings with brazed joints.
- B. Safety-Relief-Valve Discharge Piping: Copper, Type ACR, drawn-temper tubing and wrought-copper fittings with brazed joints.

3.2 VALVE AND SPECIALTY APPLICATIONS

- A. Install all valves and specialties per manufacturer's instructions.

3.3 PIPING INSTALLATION

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems; indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on Shop Drawings.
- B. Install refrigerant piping according to ASHRAE 15.
- C. Install piping in concealed locations unless otherwise indicated and except in equipment rooms and service areas.
- D. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- E. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- F. Install piping adjacent to machines to allow service and maintenance.
- G. Install piping free of sags and bends.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- H. Install fittings for changes in direction and branch connections.
 - I. Select system components with pressure rating equal to or greater than system operating pressure.
 - J. Refer to Division 23 Sections "Instrumentation and Control for HVAC" and "Sequence of Operations for HVAC Controls" for solenoid valve controllers, control wiring, and sequence of operation.
 - K. Install piping as short and direct as possible, with a minimum number of joints, elbows, and fittings.
 - L. Arrange piping to allow inspection and service of refrigeration equipment. Install valves and specialties in accessible locations to allow for service and inspection. Install access doors or panels as specified in Division 08 Section "Access Doors and Frames" if valves or equipment requiring maintenance is concealed behind finished surfaces.
 - M. Install refrigerant piping in rigid or flexible conduit in locations where exposed to mechanical injury.
 - N. Slope refrigerant piping as follows:
 - 1. Install horizontal hot-gas discharge piping with a uniform slope downward away from compressor.
 - 2. Install horizontal suction lines with a uniform slope downward to compressor.
 - 3. Install traps and double risers to entrain oil in vertical runs.
 - 4. Liquid lines may be installed level.
 - O. When brazing, remove solenoid-valve coils and sight glasses; also remove valve stems, seats, and packing, and accessible internal parts of refrigerant specialties. Do not apply heat near expansion-valve bulb.
 - P. Install piping with adequate clearance between pipe and adjacent walls and hangers or between pipes for insulation installation.
 - Q. Install sleeves for piping penetrations of walls, ceilings, and floors. Comply with requirements for sleeves specified in Division 23 Section "Common Work Results for HVAC."
 - R. Install sleeve seals for piping penetrations of concrete walls and slabs. Comply with requirements for sleeve seals specified in Division 23 Section "Common Work Results for HVAC."
 - S. Install escutcheons for piping penetrations of walls, ceilings, and floors. Comply with requirements for escutcheons specified in Division 23 Section "Common Work Results for HVAC."
- 3.4 PIPE JOINT CONSTRUCTION
- A. Brazed Joints: Construct joints according to AWS's "Braze Handbook," Chapter "Pipe and Tube."

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.5 HANGERS AND SUPPORTS

- A. Hanger, support, and anchor products are specified in Division 23 Section "Hangers and Supports for HVAC Piping and Equipment."
- B. Install the following pipe attachments:
 - 1. Adjustable steel clevis hangers for individual horizontal runs less than 20 feet long.
 - 2. Roller hangers and spring hangers for individual horizontal runs 20 feet or longer.
 - 3. Pipe Roller: MSS SP-58, Type 44 for multiple horizontal piping 20 feet or longer, supported on a trapeze.
 - 4. Spring hangers to support vertical runs.
 - 5. Copper-clad hangers and supports for hangers and supports in direct contact with copper pipe.
- C. Install hangers for copper tubing with the following maximum spacing and minimum rod sizes:
 - 1. NPS 1/2: Maximum span, 60 inches; minimum rod size, 1/4 inch.
 - 2. NPS 5/8: Maximum span, 60 inches; minimum rod size, 1/4 inch.
 - 3. NPS 1: Maximum span, 72 inches; minimum rod size, 1/4 inch.
 - 4. NPS 1-1/4: Maximum span, 96 inches; minimum rod size, 3/8 inch.
 - 5. NPS 1-1/2: Maximum span, 96 inches; minimum rod size, 3/8 inch.
 - 6. NPS 2: Maximum span, 96 inches; minimum rod size, 3/8 inch.
- D. Support multi-floor vertical runs at least at each floor.

3.6 ZOOMLOCK PIPING INSTALLATION (Contractor Option)

- A. Installers shall follow all 16 installation steps per the Zoomlock installation instructions. This covers examination, preparation and installation.
- B. Upon delivery to the jobsite, the installing contractor shall examine the copper tubing and fittings for debris, defects, incise marks (manufacturer's engraving on tube), holes or cracks.
- C. If any brazing is required, the installer shall follow the Zoomlock manufacturer guidelines.
- D. Wrapping electrical tape over the end of a flare fitting can be used when placing foam insulation of a pipe to prevent tearing.
- E. The installer shall not crimp Zoomlock fittings over flared style tubing (ODF). The installer can cut off the flare and crimp the Zoomlock fitting to the tube as long as there is a minimum of 2 inches of tube remaining.
- F. Installer shall ensure piping is spaced such that the crimp gauge can be fit around the pipes to check for proper crimp.
- G. The installer shall place Zoomlock fittings no closer than 1/4" apart.
- H. The installer shall locate the copper tubing such that the crimp tool and jaws can fit around the Zoomlock fittings.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3.7 FIELD QUALITY CONTROL

- A. Perform tests and inspections and prepare test reports.
- B. Piping shall be evacuated, tested, adjusted, and charged in strict accordance with the equipment manufacturer's instructions.

END OF SECTION 232300

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 233113 - METAL DUCTS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Rectangular ducts and fittings.
2. Round ducts and fittings.
3. Sheet metal materials.
4. Sealants and gaskets.
5. Hangers and supports.

B. Related Sections:

1. Division 23 Section "Testing, Adjusting, and Balancing for HVAC" for testing, adjusting, and balancing requirements for metal ducts.
2. Division 23 Section "Air Duct Accessories" for dampers, sound-control devices, duct-mounting access doors and panels, turning vanes, and flexible ducts.

1.2 PERFORMANCE REQUIREMENTS

- A. Duct construction, including sheet metal thicknesses, seam and joint construction, reinforcements, and hangers and supports, shall comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" and performance requirements and design criteria indicated in "Duct Schedule" Article.
- B. Structural Performance: Duct hangers and supports shall withstand the effects of gravity loads and stresses within limits and under conditions described in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible"
- C. Airstream Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1-2016.

1.3 SUBMITTALS

A. Product Data: For each type of product indicated.

B. Shop Drawings:

1. Factory- and shop-fabricated ducts and fittings.
2. Fittings.
3. Seam and joint construction.
4. Equipment installation based on equipment being used on Project.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

5. Hangers and supports, including methods for duct and building attachment and vibration isolation.
- C. Coordination Drawings (For information only, not a reviewed submittal): Plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
1. Duct installation in congested spaces, indicating coordination with general construction, building components, and other building services. Indicate proposed changes to duct layout.

1.4 QUALITY ASSURANCE

- A. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1-2016, Section 5 - "Systems and Equipment" and Section 7 - "Construction and System Start-Up."
- B. ASHRAE/IESNA Compliance: Applicable requirements in ASHRAE 90.1-2010, Section 6.4.4 - "HVAC System Construction and Insulation."

PART 2 - PRODUCTS

2.1 RECTANGULAR DUCTS AND FITTINGS

- A. General Fabrication Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" based on indicated static-pressure class unless otherwise indicated.
- B. Transverse Joints: Select joint types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 1-4, "Transverse (Girth) Joints," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
- C. Longitudinal Seams: Select seam types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 1-5, "Longitudinal Seams - Rectangular Ducts," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
- D. Elbows, Transitions, Offsets, Branch Connections, and Other Duct Construction: Select types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Chapter 2, "Fittings and Other Construction," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.2 ROUND DUCTS AND FITTINGS

- A. General Fabrication Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Chapter 3, "Round, Oval, and Flexible Duct," based on indicated static-pressure class unless otherwise indicated.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Linx Industries Inc.
 - b. EHG Air Distribution Systems
 - c. McGill AirFlow LLC.
 - d. SEMCO Incorporated.
 - e. Sheet Metal Connectors, Inc.
 - f. Spiral Manufacturing Co., Inc.
 - g. SET Duct
 - h. Lapine Metal Products
- B. Transverse Joints: Select joint types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-2, "Transverse Joints - Round Duct," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
1. Transverse Joints in Ducts Larger Than 60 Inches in Diameter: Flanged.
- C. Longitudinal Seams: Select seam types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-1, "Seams - Round Duct and Fittings," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
1. Fabricate round ducts larger Than 90 inches in diameter with butt-welded longitudinal seams.
- D. Tees and Laterals: Select types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-4, "90 Degree Tees and Laterals," and Figure 3-5, "Conical Tees," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."

2.3 SHEET METAL MATERIALS

- A. General Material Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for acceptable materials, material thicknesses, and duct construction methods unless otherwise indicated. Sheet metal materials shall be free of pitting, seam marks, roller marks, stains, discolorations, and other imperfections.
- B. Galvanized Sheet Steel: Comply with ASTM A 653/A 653M G90.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Finishes for Surfaces Exposed to View: Mill phosphatized.
- C. Carbon-Steel Sheets: Comply with ASTM A 1008/A 1008M, with oiled, matte finish for exposed ducts.
- D. Stainless-Steel Sheets: Comply with ASTM A 480/A 480M, Type 304 or 316, as indicated in the "Duct Schedule" Article; cold rolled, annealed, sheet. Exposed surface finish shall be No. 2B, No. 2D, No. 3, or No. 4 as indicated in the "Duct Schedule" Article.
- E. Aluminum Sheets: Comply with ASTM B 209 Alloy 3003, H14 temper; with mill finish for concealed ducts, and standard, one-side bright finish for duct surfaces exposed to view.
- F. Reinforcement Shapes and Plates: ASTM A 36/A 36M, steel plates, shapes, and bars; black and galvanized.
 1. Where black- and galvanized-steel shapes and plates are used to reinforce aluminum ducts, isolate the different metals with butyl rubber, neoprene, or EPDM gasket materials.
- G. Tie Rods: Galvanized steel, 1/4-inch minimum diameter for lengths 36 inches or less; 3/8-inch minimum diameter for lengths longer than 36 inches.

2.4 SEALANT AND GASKETS

- A. General Sealant and Gasket Requirements: Surface-burning characteristics for sealants and gaskets shall be a maximum flame-spread index of 25 and a maximum smoke-developed index of 50 when tested according to UL 723; certified by an NRTL. The entire perimeter of all joints shall be sealed.
 1. For indoor applications, use sealant that has a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- B. Flange Gaskets: Butyl rubber, neoprene, or EPDM polymer with polyisobutylene plasticizer.
- C. Round Duct Joint O-Ring Seals:
 1. Seal shall provide maximum leakage class of 3 cfm/100 sq. ft. at 1-inch wg and shall be rated for 10-inch wg static-pressure class, positive or negative.
 2. EPDM O-ring to seal in concave bead in coupling or fitting spigot.
 3. Double-lipped, EPDM O-ring seal, mechanically fastened to factory-fabricated couplings and fitting spigots.

2.5 HANGERS AND SUPPORTS

- A. Hanger Rods for Noncorrosive Environments: Steel rods and nuts.
- B. Hanger Rods for Corrosive Environments: Electrogalvanized, all-thread rods or galvanized rods with threads painted with zinc-chromate primer after installation.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Strap and Rod Sizes: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 4-1, "Rectangular Duct Hangers Minimum Size," and Table 4-2, "Minimum Hanger Sizes for Round Duct."
- D. Steel Cables for Galvanized-Steel Ducts: Galvanized steel complying with ASTM A 603.
- E. Steel Cables for Stainless-Steel Ducts: Stainless steel complying with ASTM A 492.
- F. Steel Cable End Connections: Steel assemblies with brackets, swivel, and bolts designed for duct hanger service; with an automatic-locking and clamping device.
- G. Duct Attachments: Sheet metal screws, blind rivets, or self-tapping metal screws; compatible with duct materials.
- H. Trapeze and Riser Supports:
 - 1. Supports for Galvanized-Steel Ducts: Galvanized-steel shapes and plates.
 - 2. Supports for Stainless-Steel Ducts: Stainless-steel shapes and plates.
 - 3. Supports for Aluminum Ducts: Aluminum.

PART 3 - EXECUTION

3.1 DUCT INSTALLATION

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of duct system. Indicated duct locations, configurations, and arrangements were used to size ducts and calculate friction loss for air-handling equipment sizing and for other design considerations. Install duct systems as indicated unless deviations to layout are approved on Shop Drawings and Coordination Drawings.
- B. Install ducts according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" unless otherwise indicated.
- C. Install round ducts in maximum practical lengths.
- D. Install ducts with fewest possible joints.
- E. Install factory- or shop-fabricated fittings for changes in direction, size, and shape and for branch connections.
- F. Unless otherwise indicated, install ducts vertically and horizontally, and parallel and perpendicular to building lines.
- G. Install ducts close to walls, overhead construction, columns, and other structural and permanent enclosure elements of building.
- H. Install ducts with a clearance of 1 inch, plus allowance for insulation thickness.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- I. Route ducts to avoid passing through transformer vaults and electrical equipment rooms and enclosures.
- J. Where ducts pass through non-fire-rated interior partitions and exterior walls and are exposed to view, cover the opening between the partition and duct or duct insulation with sheet metal flanges of same metal thickness as the duct. Overlap openings on four sides by at least 1-1/2 inches.
- K. Where ducts pass through fire-rated interior partitions and exterior walls, install fire dampers. Comply with requirements in Division 23 Section "Air Duct Accessories" for fire and smoke dampers.
- L. Protect duct interiors from moisture, construction debris and dust, and other foreign materials.

3.2 INSTALLATION OF EXPOSED DUCTWORK

- A. Protect ducts exposed in finished spaces from being dented, scratched, or damaged.
- B. Trim duct sealants flush with metal. Create a smooth and uniform exposed bead. Do not use two-part tape sealing system.
- C. Grind welds to provide smooth surface free of burrs, sharp edges, and weld splatter. When welding stainless steel with a No. 3 or 4 finish, grind the welds flush, polish the exposed welds, and treat the welds to remove discoloration caused by welding.
- D. Maintain consistency, symmetry, and uniformity in the arrangement and fabrication of fittings, hangers and supports, duct accessories, and air outlets.
- E. Repair or replace damaged sections and finished work that does not comply with these requirements.

3.3 DUCT SEALING

- A. Seal ducts to the following seal classes according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible":
 - 1. Outdoor, Supply-Air Ducts: Seal Class A.
 - 2. Outdoor, Exhaust Ducts: Seal Class C.
 - 3. Outdoor, Return-Air Ducts: Seal Class C.
 - 4. Unconditioned Space, Supply-Air Ducts in Pressure Classes 2-Inch wg and Lower: Seal Class B.
 - 5. Unconditioned Space, Supply-Air Ducts in Pressure Classes Higher Than 2-Inch wg: Seal Class A.
 - 6. Unconditioned Space, Exhaust Ducts: Seal Class C.
 - 7. Unconditioned Space, Return-Air Ducts: Seal Class B.
 - 8. Conditioned Space, Supply-Air Ducts in Pressure Classes 2-Inch wg and Lower: Seal Class C.
 - 9. Conditioned Space, Supply-Air Ducts in Pressure Classes Higher Than 2-Inch wg: Seal Class B.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- 10. Conditioned Space, Exhaust Ducts: Seal Class B.
- 11. Conditioned Space, Return-Air Ducts: Seal Class C.

3.4 HANGER AND SUPPORT INSTALLATION

- A. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Chapter 4, "Hangers and Supports."
- B. Building Attachments: Concrete inserts, powder-actuated fasteners, or structural-steel fasteners appropriate for construction materials to which hangers are being attached.
 - 1. Where practical, install concrete inserts before placing concrete.
 - 2. Install powder-actuated concrete fasteners after concrete is placed and completely cured.
 - 3. Use powder-actuated concrete fasteners for standard-weight aggregate concretes or for slabs more than 4 inches thick.
 - 4. Do not use powder-actuated concrete fasteners for lightweight-aggregate concretes or for slabs less than 4 inches thick.
- C. Hanger Spacing: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 4-1, "Rectangular Duct Hangers Minimum Size," and Table 4-2, "Minimum Hanger Sizes for Round Duct," for maximum hanger spacing; install hangers and supports within 24 inches of each elbow and within 48 inches of each branch intersection.
- D. Hangers Exposed to View: Threaded rod and angle or channel supports.
- E. Support vertical ducts with steel angles or channel secured to the sides of the duct with welds, bolts, sheet metal screws, or blind rivets; support at each floor and at a maximum intervals of 16 feet.
- F. Install upper attachments to structures. Select and size upper attachments with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

3.5 CONNECTIONS

- A. Make connections to equipment with flexible connectors complying with Division 23 Section "Air Duct Accessories."
- B. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for branch, outlet and inlet, and terminal unit connections.

3.6 START UP

- A. Air Balance: Comply with requirements in Division 23 Section "Testing, Adjusting, and Balancing for HVAC."
- B. Duct dimensions shown are free inside dimensions and shall be followed unless job conditions require alterations. Duct size revisions shall be based on the equal friction method.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Fabricate ducts with galvanized sheet steel except as otherwise indicated and as follows:
- D. Supply Ducts:
 - 1. Ducts Connected to Terminal Units and Constant Volume Air Handling Units:
 - a. Pressure Class: Positive 2-inch wg.
 - b. Minimum SMACNA Seal Class: B.
 - c. SMACNA Leakage Class for Rectangular: 12
- E. Return, Outdoor Air, and Exhaust Ducts:
 - 1. Ducts Connected to Terminal Units, Air Handling Units, or Fans:
 - a. Pressure Class: Positive or negative 2-inch wg.
 - b. Minimum SMACNA Seal Class: B.
 - c. SMACNA Leakage Class for Rectangular: 12.
- F. Intermediate Reinforcement shall match duct material
- G. Elbow Configuration:
 - 1. Rectangular Duct: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 2-2, "Rectangular Elbows."
 - a. Radius Type RE 1 with minimum 1.5 radius-to-diameter ratio.
 - b. Radius Type RE 3 with minimum 1.0 radius-to-diameter ratio and two vanes.
 - c. Mitered Type RE 2 with vanes complying with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 2-3, "Vanes and Vane Runners," and Figure 2-4, "Vane Support in Elbows."
 - 2. Round Duct: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-3, "Round Duct Elbows."
 - a. Minimum Radius-to-Diameter Ratio and Elbow Segments: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 3-1, "Mitered Elbows." Elbows with less than 90-degree change of direction have proportionately fewer segments.
 - 1) Radius-to Diameter Ratio: 1.5.
 - b. Round Elbows, 12 Inches and Smaller in Diameter: Stamped or pleated.
 - c. Round Elbows, 14 Inches and Larger in Diameter: Standing seam.
- H. Branch Configuration:
 - 1. Rectangular Duct: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 2-6, "Branch Connections."
 - a. Rectangular Main to Rectangular Branch: 45-degree entry.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Round: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-4, "90 Degree Tees and Laterals," and Figure 3-5, "Conical Tees." Saddle taps are permitted in existing duct.
 - a. Velocity 1000 fpm or Lower: 90-degree tap.
 - b. Velocity 1000 to 1500 fpm: Conical tap.
 - c. Velocity 1500 fpm or Higher: 45-degree lateral.

END OF SECTION 233113

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 233300 - AIR DUCT ACCESSORIES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Backdraft and pressure relief dampers.
 2. Manual volume dampers.
 3. Control dampers.
 4. Fire dampers.
 5. Flange connectors.
 6. Turning vanes.
 7. Duct-mounted access doors.
 8. Flexible connectors.
 9. Flexible ducts.
 10. Duct accessory hardware.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Comply with NFPA 90A, "Installation of Air Conditioning and Ventilating Systems," and with NFPA 90B, "Installation of Warm Air Heating and Air Conditioning Systems."
- B. Comply with AMCA 500-D testing for damper rating.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for acceptable materials, material thicknesses, and duct construction methods unless otherwise indicated. Sheet metal materials shall be free of pitting, seam marks, roller marks, stains, discolorations, and other imperfections.
- B. Galvanized Sheet Steel: Comply with ASTM A 653/A 653M.
1. Exposed-Surface Finish: Mill phosphatized.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Stainless-Steel Sheets: Comply with ASTM A 480/A 480M, Type 304.
- D. Aluminum Sheets: Comply with ASTM B 209, Alloy 3003, Temper H14; with mill finish for concealed ducts and standard, 1-side bright finish for exposed ducts.
- E. Extruded Aluminum: Comply with ASTM B 221, Alloy 6063, Temper T6.
- F. Reinforcement Shapes and Plates: Galvanized-steel reinforcement where installed on galvanized sheet metal ducts; compatible materials for aluminum and stainless-steel ducts.
- G. Tie Rods: Galvanized steel, 1/4-inch minimum diameter for lengths 36 inches or less; 3/8-inch minimum diameter for lengths longer than 36 inches.

2.2 DAMPERS – BACKDRAFT, VOLUME, CONTROL, FIRE, SMOKE

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Mestek, Inc.
 - 2. Greenheck Fan Corporation.
 - 3. Nailor Industries Inc.
 - 4. Pottorff
 - 5. Ruskin Company.

2.3 BACKDRAFT AND PRESSURE RELIEF DAMPERS

- A. Description: Gravity balanced.
- B. Maximum Air Velocity: 3000 fpm.
- C. Maximum System Pressure: 2-inch wg.
- D. Frame: 0.052-inch-thick, galvanized sheet steel, with welded corners.
- E. Blades: Multiple single-piece blades, maximum 6-inch width with sealed edges.
- F. Blade Action: Parallel.
- G. Return Spring: Adjustable tension.
- H. Bearings: Provide end bearings on all dampers. On multiple blade dampers bearing shall be oil-impregnated nylon or sintered bronze.
- I. Accessories:
 - 1. Adjustment device to permit setting for varying differential static pressure.
 - 2. Counterweights and spring-assist kits for vertical airflow installations.
 - 3. Electric actuators.
 - 4. Chain pulls.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

5. Screen Material: Galvanized steel.
6. Screen Type: Bird.
7. 90-degree stops.

2.4 MANUAL VOLUME DAMPERS

1. Damper and blade material to match ductwork material
2. Standard leakage rating.
3. Suitable for horizontal or vertical applications.
4. Frames:
 - a. Hat-shaped, galvanized-steel channels, 0.064-inch minimum thickness.
 - b. Mitered and welded corners.
 - c. Flanges for attaching to walls and flangeless frames for installing in ducts.
5. Blades:
 - a. Rectangular dampers shall be single blade type in ducts up to 11" high and shall be opposed blade type in ducts 12" high and above.
 - b. Round dampers shall be single blade type.
 - c. Stiffen damper blades for stability.
6. Provide end bearings on all dampers. On multiple blade dampers bearing shall be oil-impregnated nylon or sintered bronze.
7. Provide locking indicating quadrant regulators on all dampers. Where rod lengths exceed 30-inches, provide a regulator at both ends.
8. On insulated ducts mount quadrant regulators on stand-off mounting brackets, bases, or adapters.
9. Jackshaft:
 - a. Size: 1-inch diameter.
 - b. Material: Galvanized-steel pipe rotating within pipe-bearing assembly mounted on supports at each mullion and at each end of multiple-damper assemblies.
 - c. Length and Number of Mountings: As required to connect linkage of each damper in multiple-damper assembly.
10. Damper Hardware:
 - a. Zinc-plated, die-cast core with dial and handle made of 3/32-inch- thick zinc-plated steel, and a 3/4-inch hexagon locking nut.
 - b. Include center hole to suit damper operating-rod size.
 - c. Include elevated platform for insulated duct mounting.

2.5 CONTROL DAMPERS

- A. Frames:
 1. Galvanized-steel channels, 0.064 inch thick.
 2. Mitered and welded corners.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

B. Blades:

1. Multiple blade with maximum blade width of 8 inches.
2. Opposed-blade design.
3. Galvanized steel.
4. 0.064 inch thick.
5. Blade Edging: Closed-cell neoprene edging.
6. Blade Edging: Inflatable seal blade edging, or replaceable rubber seals.

C. Blade Axles: 1/2-inch-diameter; galvanized steel; blade-linkage hardware of zinc-plated steel and brass; ends sealed against blade bearings.

1. Operating Temperature Range: From minus 40 to plus 200 deg F.

D. Bearings:

1. Dampers in ducts with pressure classes of 3-inch wg or less shall have axles full length of damper blades and bearings at both ends of operating shaft.
2. Thrust bearings at each end of every blade.

2.6 FIRE DAMPERS

- A. Fire dampers shall be dynamic interlocking blade type with integral wall sleeve and blades out of air stream and shall be constructed in accordance with UL Standard 555.
- B. Closing rating in ducts up to 4-inch wg static pressure class and minimum 4000-fpm velocity.
- C. Dampers shall be for horizontal or vertical mounting and shall be of sizes shown on the drawings.
- D. Horizontal Dampers: Include blade lock and stainless-steel closure spring.
- E. Dampers shall have 1-1/2 or 3 hour rating as shown on drawings and replaceable 165 degree F fusible link.
- F. Rated pressure and velocity to exceed design airflow conditions.
- G. Mounting Sleeve: Factory-installed, 0.052-inch-thick, galvanized sheet steel; length to suit wall or floor application with factory-furnished silicone caulking.
- H. Damper Motors: two-position action.
- I. Comply with NEMA designation, temperature rating, service factor, enclosure type, and efficiency requirements for motors specified in Division 23 Section "Common Motor Requirements for HVAC Equipment."
 1. Motor Sizes: Minimum size as indicated. If not indicated, large enough so driven load will not require motor to operate in service factor range above 1.0.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Controllers, Electrical Devices, and Wiring: Comply with requirements for electrical devices and connections specified in Division 23 Section "Instrumentation and Control for HVAC.]
3. Permanent-Split-Capacitor or Shaded-Pole Motors: With oil-immersed and sealed gear trains.
4. Spring-Return Motors: Equip with an integral spiral-spring mechanism where indicated. Enclose entire spring mechanism in a removable housing designed for service or adjustments. Size for running torque rating of 150 in. x lbf and breakaway torque rating of 150 in. x lbf.
5. Outdoor Motors and Motors in Outdoor-Air Intakes: Equip with O-ring gaskets designed to make motors weatherproof. Equip motors with internal heaters to permit normal operation at minus 40 deg F.
6. Nonspring-Return Motors: For dampers larger than 25 sq. ft., size motor for running torque rating of 150 in. x lbf and breakaway torque rating of 300 in. x lbf.
7. Electrical Connection: 115 V, single phase, 60 Hz.

J. Accessories:

1. Auxiliary switches for position indication remote mounted.

2.7 FLANGE CONNECTORS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 1. Ductmate Industries, Inc.
 2. Nexus PDQ; Division of Shilco Holdings Inc.
 3. Ward Industries, Inc.; a division of Hart & Cooley, Inc.
- B. Description: Factory-fabricated, slide-on transverse flange connectors, gaskets, and components.
- C. Material: Galvanized steel.
- D. Gage and Shape: Match connecting ductwork.

2.8 TURNING VANES

- A. General Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible"; Figures 2-3, "Vanes and Vane Runners," and 2-4, "Vane Support in Elbows."
- B. Vane Construction: Single wall for ducts up to 48 inches wide and double wall for larger dimensions.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.9 DUCT-MOUNTED ACCESS DOORS

- A. Duct-Mounted Access Doors: Fabricate access panels according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible"; Figures 2-10, "Duct Access Doors and Panels," and 2-11, "Access Panels - Round Duct."
 - 1. Door:
 - a. Double wall, rectangular.
 - b. Galvanized sheet metal with insulation fill and thickness as indicated for duct pressure class.
 - c. Hinges and Latches: 1-by-1-inch butt or piano hinge and cam latches.
 - d. Fabricate doors airtight and suitable for duct pressure class.
 - 2. Frame: Galvanized sheet steel, with bend-over tabs and foam gaskets.
 - 3. Number of Hinges and Locks:
 - a. Access Doors Less Than 12 Inches Square: No hinges and two sash locks.
 - b. Access Doors up to 18 Inches Square: Two hinges and two sash locks.
 - c. Access Doors up to 24 by 48 Inches: Three hinges and two compression latches

2.10 DUCT ACCESS PANEL ASSEMBLIES

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 1. Ductmate Industries, Inc.
 - 2. Flame Gard, Inc.
 - 3. 3M.
- B. Labeled according to UL 1978 by an NRTL.
- C. Panel and Frame: Minimum thickness 0.0428-inch stainless steel.
- D. Fasteners: Stainless steel. Panel fasteners shall not penetrate duct wall.
- E. Gasket: Comply with NFPA 96; grease-tight, high-temperature ceramic fiber, rated for minimum 2000 deg F.
- F. Minimum Pressure Rating: 10-inch wg, positive or negative.

2.11 FLEXIBLE CONNECTORS

- A. Materials: Flame-retardant or noncombustible fabrics.
- B. Coatings and Adhesives: Comply with UL 181, Class 1.
- C. Material shall be crimped into a metal edging strip and shall be approximately 3 inches wide.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Indoor System, Flexible Connector Fabric: Glass fabric double coated with neoprene.
 - 1. Minimum Weight: 26 oz./sq. yd..
 - 2. Tensile Strength: 480 lbf/inch in the warp and 360 lbf/inch in the filling.
 - 3. Service Temperature: Minus 40 to plus 200 deg F.

- E. Outdoor System, Flexible Connector Fabric: Glass fabric double coated with weatherproof, synthetic rubber resistant to UV rays and ozone.
 - 1. Minimum Weight: 24 oz./sq. yd..
 - 2. Minimum Tensile Strength: 500 lbf/inch in the warp and 440 lbf/inch in the filling.
 - 3. Service Temperature: Minus 50 to plus 250 deg F.

2.12 FLEXIBLE DUCTS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 1. Flexmaster U.S.A., Inc.
 - 2. McGill AirFlow LLC.
 - 3. Ward Industries, Inc.

- B. Noninsulated, Flexible Duct: UL 181, Class 1, 2-ply vinyl film supported by helically wound, spring-steel wire.
 - 1. Pressure Rating: 10-inch wg positive and 1.0-inch wg negative.
 - 2. Maximum Air Velocity: 4000 fpm.
 - 3. Temperature Range: Minus 10 to plus 160 deg F.

- C. Insulated, Flexible Duct: UL 181, Class 1, black polymer film supported by helically wound, spring-steel wire; fibrous-glass insulation; fire resistive vapor-barrier film.
 - 1. Pressure Rating: 4-inch wg positive and 0.5-inch wg negative.
 - 2. Maximum Air Velocity: 4000 fpm.
 - 3. Temperature Range: Minus 20 to plus 175 deg F.
 - 4. Insulation R-Value: Comply with ASHRAE 90.1-2010.

- D. Insulated, Flexible Duct: UL 181, Class 1, multiple layers of aluminum laminate supported by helically wound, spring-steel wire; fibrous-glass insulation; fire resistive vapor-barrier film.
 - 1. Pressure Rating: 10-inch wg positive and 1.0-inch wg negative.
 - 2. Maximum Air Velocity: 4000 fpm.
 - 3. Temperature Range: Minus 20 to plus 210 deg F.
 - 4. Insulation R-value: Comply with ASHRAE 90.1-2010.

- E. Flexible Duct Connectors:
 - 1. Clamps: Stainless-steel band with hex screw to tighten band with a worm-gear action or Nylon strap in sizes 3 through 18 inches, to suit duct size.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.13 DUCT ACCESSORY HARDWARE

- A. Instrument Test Holes: Cast iron or cast aluminum to suit duct material, including screw cap and gasket. Size to allow insertion of pitot tube and other testing instruments and of length to suit duct-insulation thickness.
- B. Adhesives: High strength, quick setting, neoprene based, waterproof, and resistant to gasoline and grease.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install duct accessories according to applicable details in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for metal ducts and in NAIMA AH116, "Fibrous Glass Duct Construction Standards," for fibrous-glass ducts.
- B. Install duct accessories of materials suited to duct materials; use galvanized-steel accessories in galvanized-steel and fibrous-glass ducts, stainless-steel accessories in stainless-steel ducts, and aluminum accessories in aluminum ducts.
- C. Install backdraft dampers at inlet of exhaust fans or exhaust ducts as close as possible to exhaust fan unless otherwise indicated.
- D. Install volume dampers at points on supply, return, and exhaust systems where branches extend from larger ducts. Where dampers are installed in ducts having duct liner, install dampers with hat channels of same depth as liner, and terminate liner with nosing at hat channel.
 - 1. Install steel volume dampers in steel ducts.
 - 2. Install aluminum volume dampers in aluminum ducts.
- E. Set dampers to fully open position before testing, adjusting, and balancing.
- F. Install test holes at fan inlets and outlets and elsewhere as indicated.
- G. Install fire dampers according to UL listing.
- H. Install duct access doors on sides of ducts to allow for inspecting, adjusting, and maintaining accessories and equipment at the following locations:
 - 1. On both sides of duct coils.
 - 2. Upstream from duct filters.
 - 3. At outdoor-air intakes and mixed-air plenums.
 - 4. At drain pans and seals.
 - 5. Downstream from manual volume dampers, control dampers, backdraft dampers, and equipment.
 - 6. Adjacent to and close enough to fire or smoke dampers, to reset or reinstall fusible links. Access doors for access to fire or smoke dampers having fusible links shall be pressure

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

relief access doors; and shall be outward operation for access doors installed upstream from dampers and inward operation for access doors installed downstream from dampers.

7. Control devices requiring inspection.
8. Elsewhere as indicated.

I. Install access doors with swing against duct static pressure.

J. Access Door Sizes:

1. One-Hand or Inspection Access: 8 by 5 inches.
2. Two-Hand Access: 12 by 6 inches.
3. Head and Hand Access: 18 by 10 inches.
4. Head and Shoulders Access: 21 by 14 inches.
5. Body Access: 25 by 14 inches.
6. Body plus Ladder Access: 25 by 17 inches.

K. Label access doors according to Division 23 Section "Identification for HVAC Piping and Equipment" to indicate the purpose of access door.

L. Install flexible connectors to connect ducts to equipment.

M. For fans developing static pressures of 5-inch wg and more, cover flexible connectors with loaded vinyl sheet held in place with metal straps.

N. Connect terminal units to supply ducts directly or with maximum 12-inch lengths of flexible duct. Do not use flexible ducts to change directions.

O. Connect diffusers or light troffer boots to ducts directly or with maximum 60-inch lengths of flexible duct clamped or strapped in place.

P. Connect flexible ducts to metal ducts with draw bands plus tape.

3.2 FIELD QUALITY CONTROL

A. Tests and Inspections:

1. Operate dampers to verify full range of movement.
2. Inspect locations of access doors and verify that purpose of access door can be performed.
3. Operate fire and smoke dampers to verify full range of movement and verify that proper heat-response device is installed.
4. Inspect turning vanes for proper and secure installation.

END OF SECTION 233300

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 233423 - HVAC POWER VENTILATORS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 Inline ventilators.

1.2 SUBMITTALS

- A. Product Data: Include rated capacities, furnished specialties, and accessories for each type of product indicated and include the following:
- B. Shop Drawings: Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
- C. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. NEMA Compliance: Motors and electrical accessories shall comply with NEMA standards.
- C. UL Standard: Power ventilators shall comply with UL 705.
- D. Sound Power Level Rating: AMCA 301.
- E. Performance Requirements: AMCA 210.

PART 2 - PRODUCTS

2.1 IN LINE CENTRIFUGAL FANS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide the model(s) as scheduled on the drawings or a comparable product by one of the following:
 - 1. Greenheck.
 - 2. Loren Cook Company.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- B. Description: In-line, centrifugal fans consisting of housing, wheel, outlet guide vanes, fan shaft, bearings, motor and disconnect switch, drive assembly, mounting brackets, and accessories.
- C. Housing: Split, spun aluminum with aluminum straightening vanes, inlet and outlet flanges, and support bracket adaptable to floor, side wall, or ceiling mounting.
- D. Direct-Driven Units: EC Motor mounted in airstream, factory wired to disconnect switch located on outside of fan housing.
- E. Belt-Driven Units: Motor mounted on adjustable base, with adjustable sheaves, enclosure around belts within fan housing, and lubricating tubes from fan bearings extended to outside of fan housing.
- F. Fan Wheels: Aluminum, airfoil blades welded to aluminum hub.
- G. Accessories:
 - 1. Volume-Control Damper: Manually operated with quadrant lock, located in fan outlet.
 - 2. Companion Flanges: For inlet and outlet duct connections.
 - 3. Fan Guards: 1/2- by 1-inch mesh of galvanized steel in removable frame. Provide guard for inlet or outlet for units not connected to ductwork.
 - 4. Motor and Drive Cover (Belt Guard): Epoxy-coated steel.

2.2 MOTORS

- A. Comply with requirements in Division 23 Section "Common Motor Requirements for HVAC Equipment."
- A. Enclosure Type:
 - 1. Outdoor: Totally enclosed, fan cooled.
 - 2. Indoor: Totally enclosed, fan cooled or Open Drip Proof

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install power ventilators level and plumb.
- B. Support suspended units from structure per manufacturer's installation instructions. Use threaded steel rods and elastomeric hangers. Install units with clearances for service and maintenance.
- C. Install floor-mounting units on concrete bases. Concrete, reinforcement, and formwork requirements are specified in Division 03 Section "Cast-in-Place Concrete."
- D. Ceiling Units: Suspend units from structure; use steel wire or metal straps.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- E. Install units with clearances for service and maintenance.
- F. Label units according to requirements specified in Division 23 Section "Identification for HVAC Piping and Equipment."
- G. Duct installation and connection requirements are specified in other Division 23 Sections. Drawings indicate general arrangement of ducts and duct accessories. Make final duct connections with flexible connectors. Flexible connectors are specified in Division 23 Section "Air Duct Accessories."
- H. Install ducts adjacent to power ventilators to allow service and maintenance.
- I. Ground equipment and Connect wiring according to Division 26 Specifications.

3.2 FIELD QUALITY CONTROL

- A. Perform the following field tests and inspections and prepare test reports:
 - 1. Verify that shipping, blocking, and bracing are removed.
 - 2. Verify that unit is secure on mountings and supporting devices and that connections to ducts and electrical components are complete. Verify that proper thermal-overload protection is installed in motors, starters, and disconnect switches.
 - 3. Verify that cleaning and adjusting are complete.
 - 4. Disconnect fan drive from motor, verify proper motor rotation direction, and verify fan wheel free rotation and smooth bearing operation. Reconnect fan drive system, align and adjust belts, and install belt guards.
 - 5. Adjust belt tension.
 - 6. Adjust damper linkages for proper damper operation.
 - 7. Verify lubrication for bearings and other moving parts.
 - 8. Verify that manual and automatic volume control and fire and smoke dampers in connected ductwork systems are in fully open position.
 - 9. Disable automatic temperature-control operators, energize motor and adjust fan to indicated rpm, and measure and record motor voltage and amperage.
 - 10. Shut unit down and reconnect automatic temperature-control operators.
 - 11. Remove and replace malfunctioning units and retest as specified above.
- B. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.

END OF SECTION 233423

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 23 3600

AIR TERMINAL UNITS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Single duct air terminal units

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For air terminal units. Include plans, elevations, sections, details, and attachments to other work.
- C. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1-2016, Section 5 - "Systems and Equipment" and Section 7 - "Construction and System Start-Up."

PART 2 - PRODUCTS

2.1 SHUTOFF, SINGLE-DUCT AIR TERMINAL UNITS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Titus
 - 2. Price
 - 3. Daikin
 - 4. Trane
 - 5. ETI
- B. Configuration: Volume-damper assembly inside unit casing with control components inside a protective metal shroud.
- C. Casing: minimum 22 gauge steel, single wall.
 - 1. Casing Lining:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Adhesive attached, 3/4" foil faced fibrous-glass insulation complying with ASTM C 1071, with a reinforced foil facing on the airstream side, and having a maximum flame/smoke index of 25/50, for both insulation and adhesive, when tested according to ASTM E 84.
 - b. Elastomeric Closed Cell Foam Insulation is an acceptable alternate. Insulation must meet 25/50 flame/smoke index, and comply with antimicrobial performance of no observed growth per ASTM G-21
2. Air Inlet: Round stub connection or S-slip and drive connections for duct attachment.
 3. Air Outlet: S-slip and drive connections.
 4. Access: Removable panels for access to parts requiring service, adjustment, or maintenance; with airtight gasket.
 5. Airstream Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1-2016.
- A. Velocity Sensors: Single axis sensor shall not be acceptable for duct diameters 6" or larger. Multiple pressure sensing points shall be utilized. The total pressure inputs shall be averaged using a pressure chamber located at the center of the sensor. Sensor shall have an error of plus or minus 5% or better.
- B. Volume Damper: Minimum 22 gauge steel with shaft rotating in self-lubricating bearings. Shaft shall be clearly marked on the end to indicate damper position.
1. Mechanical stop to prevent overstroking of damper.
 2. The air valve leakage shall not exceed 1% of maximum inlet rated airflow at 3" W.G. inlet pressure.
- C. Electric-Resistance Heating Coils: Nickel-chromium heating wire, free of expansion noise and hum, mounted in ceramic inserts in a galvanized-steel housing; with primary automatic, and secondary manual, reset thermal cutouts. Terminate elements in stainless-steel, machine-staked terminals secured with stainless-steel hardware.
1. Access door interlocked disconnect switch.
 2. Downstream air temperature sensor with local connection to override discharge-air temperature to not exceed a maximum temperature set point (adjustable.)
 3. Nickel chrome 80/20 heating elements.
 4. Airflow switch for proof of airflow.
 5. Fan interlock contacts.
 6. Fuses in terminal box for overcurrent protection (for coils more than 48 A).
 7. Mercury contactors.
 8. Magnetic contactor for each step of control (for three-phase coils).
- D. Electronic Controls:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. See Section 23 0923 "Direct Digital Control Systems for HVAC" for VAV box controller requirements.
 - a. Manufacturer's VAV box controller may be furnished and factory mounted and wired provided it meets all requirement of the specification.
2. Bidirectional damper operator and microprocessor-based thermostat with integral airflow transducer and room sensor. Control devices shall be compatible with temperature controls specified in Division 23 Section "Instrumentation and Control for HVAC" and shall have the following features:
 3. Damper Actuator: 24 V, powered closed,
 4. Velocity Controller: Factory calibrated and field adjustable to minimum and maximum air volumes; shall maintain constant airflow dictated by thermostat within 5 percent of set point while compensating for inlet static-pressure variations up to 4-inch wg; and shall have a multipoint velocity sensor at air inlet.
 5. Thermostat: Wall-mounted electronic type with temperature set-point display in Fahrenheit and Celsius.

2.2 HANGERS AND SUPPORTS

- A. Hanger Rods for Noncorrosive Environments: Steel rods and nuts.
- B. Steel Cables: Galvanized steel complying with ASTM A 603.
- C. Steel Cable End Connections: Steel assemblies with brackets, swivel, and bolts designed for duct hanger service; with an automatic-locking and clamping device.
- D. Air Terminal Unit Attachments: Sheet metal screws, blind rivets, or self-tapping metal screws; compatible with duct materials.
- E. Trapeze and Riser Supports: Steel shapes and plates for units with steel casings; aluminum for units with aluminum casings.

2.3 SOURCE QUALITY CONTROL

- A. Factory Tests: Test assembled air terminal units according to ARI 880.
 1. Label each air terminal unit with plan number, nominal airflow, maximum and minimum factory-set airflows, and ARI certification seal.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install air terminal units according to NFPA 90A, "Standard for the Installation of Air Conditioning and Ventilating Systems."
- B. Install air terminal units level and plumb. Maintain sufficient clearance for normal service and maintenance.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- C. Install fan powered boxes per the installation detail on drawing M-001.

3.2 HANGER AND SUPPORT INSTALLATION

- A. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Chapter 4, "Hangers and Supports."
- B. Building Attachments: Concrete inserts, or structural-steel fasteners appropriate for construction materials to which hangers are being attached.
 - 1. Where practical, install concrete inserts before placing concrete.
 - 2. Install powder-actuated concrete fasteners after concrete is placed and completely cured.
 - 3. Use powder-actuated concrete fasteners for standard-weight aggregate concretes and for slabs more than 4 inches (100 mm) thick.
 - 4. Do not use powder-actuated concrete fasteners for lightweight-aggregate concretes and for slabs less than 4 inches (100 mm) thick.
- C. Hangers Exposed to View: Threaded rod and angle or channel supports.
- D. Install upper attachments to structures. Select and size upper attachments with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

3.3 CONNECTIONS

- A. Install piping adjacent to air terminal unit to allow service and maintenance.
- B. Connect ducts to air terminal units according to Division 23 Section "Metal Ducts."
- C. Make connections to inlets of air terminal units with flexible connectors complying with requirements in Division 23 Section "Air Duct Accessories."

3.4 IDENTIFICATION

- A. Label each air terminal unit with plan number, nominal airflow, and maximum and minimum factory-set airflows. Comply with requirements in Division 23 Section "Identification for HVAC Piping and Equipment" for equipment labels and warning signs and labels.

3.5 FIELD QUALITY CONTROL

- A. Perform Tests and Inspections:
 - 1. After installing air terminal units and after electrical circuitry has been energized, test for compliance with requirements.
 - 2. Leak Test: After installation, fill water coils and test for leaks. Repair leaks and retest until no leaks exist.
 - 3. Operational Test: After electrical circuitry has been energized, start units to confirm proper motor rotation and unit operation.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Air terminal unit will be considered defective if it does not pass tests and inspections.
 - C. Prepare test and inspection reports.

3.6 STARTUP SERVICE

- A. Engage a factory-authorized service representative to perform startup service.
 1. Complete installation and startup checks according to manufacturer's written instructions.
 2. Verify that inlet duct connections are as recommended by air terminal unit manufacturer to achieve proper performance.
 3. Verify that controls and control enclosure are accessible.
 4. Verify that control connections are complete.
 5. Verify that nameplate and identification tag are visible.
 6. Verify that controls respond to inputs as specified.

3.7 DEMONSTRATION

- A. Train Owner's maintenance personnel to adjust, operate, and maintain air terminal units.

END OF SECTION

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

THIS PAGE IS INTENTIONALLY

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 233713 - DIFFUSERS, REGISTERS, AND GRILLES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Fixed face registers and grilles.

B. Related Sections:

1. Division 23 Section "Air Duct Accessories" for fire and smoke dampers and volume-control dampers not integral to diffusers, registers, and grilles.

1.2 SUBMITTALS

A. Product Data: For each type of product indicated, include the following:

1. Data Sheet: Indicate materials of construction, finish, and mounting details; and performance data including throw and drop, static-pressure drop, and noise ratings.
2. Diffuser, Register, and Grille Schedule: Indicate drawing designation, room location, quantity, model number, size, and accessories furnished.

PART 2 - PRODUCTS

2.1 ACCEPTABLE MANUFACTURERS:

A. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated or comparable product by one of the following:

1. Titus.
2. Price Industries.

B. Verification of Performance: Rate diffusers, registers, and grilles according to ASHRAE 70, "Method of Testing for Rating the Performance of Air Outlets and Inlets."

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install diffusers, registers, and grilles level and plumb.
- B. Install diffusers, registers, and grilles with airtight connections to ducts and to allow service and maintenance of dampers, air extractors, and fire dampers.

3.2 ADJUSTING

- A. After installation, adjust diffusers, registers, and grilles to air patterns indicated, or as directed, before starting air balancing.

END OF SECTION 233713

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 23 7413

PACKAGED ROOFTOP UNITS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes packaged, outdoor, central-station air-handling units (rooftop units) with the following components and accessories:
 - 1. Direct-expansion cooling with:
 - a. Modulating capacity control; or,
 - b. Multi-stage capacity control.
 - 2. Heating section, with:
 - a. Modulating gas burner;
 - b. Modulating SCR electric heater.
 - 3. Modulating hot gas reheat dehumidification, where scheduled.
 - 4. Economizer outdoor- and return-air damper section, where scheduled.
 - 5. Integral, space temperature controls.
 - a. Single-zone variable air volume
 - b. Multi-zone variable air volume
 - c. 100% outside air constant volume
 - 6. Roof curbs.

1.2 DEFINITIONS

- A. Outdoor-Air Refrigerant Coil: Refrigerant coil in the outdoor-air stream to reject heat during cooling operations and to absorb heat during heating operations. "Outdoor air" is defined as the air outside the building or taken from outdoors and not previously circulated through the system.
- B. Outdoor-Air Refrigerant-Coil Fan: The outdoor-air refrigerant-coil fan in RTUs. "Outdoor air" is defined as the air outside the building or taken from outdoors and not previously circulated through the system.
- C. RTU: Rooftop unit. As used in this Section, this abbreviation means packaged, outdoor, central-station air-handling units. This abbreviation is used regardless of whether the unit is mounted on the roof or on a concrete base on ground.
- D. Supply-Air Fan: The fan providing supply-air to conditioned space. "Supply air" is defined as the air entering a space from air-conditioning, heating, or ventilating apparatus.
- E. Supply-Air Refrigerant Coil: Refrigerant coil in the supply-air stream to absorb heat (provide cooling) during cooling operations and to reject heat (provide heating) during heating operations. "Supply air" is defined as the air entering a space from air-conditioning, heating, or ventilating apparatus.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1.3 SUBMITTALS

- A. Product Data: Include manufacturer's technical data for each unit, including rated capacities, dimensions, required clearances, characteristics, furnished specialties, and accessories.
- B. Shop Drawings: Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
 - 1. Wiring Diagrams: Power, signal, and control wiring.
- C. Field quality-control test reports.
- D. Operation and maintenance data.
- E. Warranty.

1.4 QUALITY ASSURANCE

- A. ARI Compliance:
 - 1. Comply with ARI 210/240 and ARI 340/360 for testing and rating energy efficiencies for RTUs.
 - 2. Comply with ARI 270 for testing and rating sound performance for RTUs.
- B. ASHRAE Compliance:
 - 1. Comply with ASHRAE 15 for refrigerant system safety.
 - 2. Comply with ASHRAE 33 for methods of testing cooling and heating coils.
 - 3. Comply with applicable requirements in ASHRAE 62.1-2016, Section 5 - "Systems and Equipment" and Section 7 - "Construction and Startup."
- C. ASHRAE 90.1-2010 Compliance: Applicable requirements in ASHRAE 90.1-2010, Section 6 - "Heating, Ventilating, and Air-Conditioning."
- D. NFPA Compliance: Comply with NFPA 90A and NFPA 90B.
- E. UL Compliance: Comply with UL 1995.
- F. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

1.5 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to replace components of RTUs that fail in materials or workmanship within specified warranty period.
 - 1. Warranty Period for Compressors: Manufacturer's standard, but not less than **five** years from date of Substantial Completion.
 - 2. Warranty Period for Gas Furnace Heat Exchangers: Manufacturer's standard, but not less than five years from date of Substantial Completion.
 - 3. Warranty Period for Solid-State Ignition Modules: Manufacturer's standard, but not less than three years from date of Substantial Completion.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

4. Warranty Period for Control Boards: Manufacturer's standard, but not less than three years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide the **Daikin** 'Rebel' units or comparable products by one of the following with an **inverter compressor**:
 1. AAO, Inc.
 2. Engineered Air.
 3. Trane;

2.2 GENERAL DESCRIPTION

- A. Furnish units as schedule and as shown on plans:
 1. Single Zone VAV Cooling Units.
 2. Multizone VAV Heating and Cooling Units.
 3. Constant Volume Cooling Units.
- B. Unit performance and electrical characteristics shall be per the job schedule.
- C. Configuration: Fabricate as detailed on prints and drawings:
 1. Supply fan section
 2. Cooling coil section
 3. Condensing unit section
 4. Filter section
 5. The following sections may not pertain to all units:
 - a. Return plenum/economizer section
 - b. Exhaust/relief fan
 - c. Modulating hot gas reheat
 - d. Natural gas heating section
 - e. Electric heat section
 - f. Energy recovery section
- D. The complete unit shall be cETLus listed.
- E. The unit shall be ASHRAE 90.1-2016 compliant and labeled.
- F. Each unit shall be specifically designed for outdoor rooftop application and include a weatherproof cabinet. Each unit shall be completely factory assembled and shipped in one piece. Packaged units shall be shipped fully charged with R-410 Refrigerant and oil.
- G. The unit shall undergo a complete factory run test prior to shipment. The factory test shall include a refrigeration circuit run test, a unit control system operations checkout, a unit refrigerant leak test and a final unit inspection.
- H. All units shall have decals and tags to indicate caution areas and aid unit service. Unit nameplates shall be fixed to the main control panel door.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- I. Electrical wiring diagrams shall be attached to the control panels. Installation, operating and maintenance bulletins and start-up forms shall be supplied with each unit.

2.3 CABINET, CASING, AND FRAME

- A. Panel construction shall be double-wall construction for all panels. All floor panels shall have a solid galvanized steel inner liner on the air stream side of the unit to protect insulation during service and maintenance. Insulation shall be a minimum of 1" thick with an R-value not less than 4.0. Panel design shall include no exposed insulation edges. Unit cabinet shall be designed to operate at total static pressures up to 5.0 inches w.g.
- B. *Double wall* construction shall be the minimum design in all sections downstream of the cooling coil section. This shall include the fan, gas heat, and discharge plenum sections as a minimum.
- C. Exterior surfaces shall be constructed of painted galvanized steel, for aesthetics and long-term durability. Paint finish will include a base primer with a high-quality polyester resin topcoat. Finished, unabraded panel surfaces shall be exposed to an ASTM B117 salt spray environment and exhibit no visible red rust at a minimum of 3,000 hours exposure.
- D. Service doors shall be provided on the fan section, filter section, control panel section, and heating vestibule in order to provide user access to unit components. All service access doors shall be mounted on multiple, stainless steel hinges and shall be secured by a latch system. Removable service panels secured by multiple mechanical fasteners are not acceptable.
- E. The unit base shall overhang the roof curb for positive water runoff and shall seat on the roof curb gasket to provide a positive, weathertight seal. Lifting brackets shall be provided on the unit base to accept cable or chain hooks for rigging the equipment.

2.4 OUTDOOR/RETURN AIR SECTION

- A. Unit shall be provided with a 0 to 100% outside air economizer section including outdoor, return, and exhaust air dampers. The outdoor air hood shall be factory installed and constructed from galvanized steel finished with the same durable paint finish as the main unit. The hood shall include moisture eliminator filters to drain water away from the entering air stream.
- B. The opposed blade outside and return air dampers shall be sized to handle 100% of the supply air volume. All dampers shall be low-leak with blade and side seals, and have leakage rates of 1.5 cfm per sq. ft. of the damper area at 1-inch w.c. differential pressure, as tested in accordance with AMCA Standard 500.
- C. Damper blades shall be operated from multiple sets of linkages mounted on the leaving face of the dampers.
- D. Control of the OA/RA dampers shall be by a factory installed direct coupled actuator. Damper actuator shall be of the modulating, spring return type. A comparative dry bulb control shall be provided to sense and compare dry bulb temperatures of both the outdoor and return air streams to determine if outdoor air is suitable for "free" cooling. If outdoor air is suitable for "free" cooling, the outdoor air dampers shall modulate in response to the unit's temperature control system.
- E. Provide factory installed and tested, outdoor air monitor that controls outdoor air +/- 15% accuracy down to 40 cfm per ton.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.5 FILTERS

- A. Unit shall be provided with a draw-through filter section. The filter rack shall be designed to accept a 2" prefilter and a 4" post filter. The unit design shall have a hinged access door for the filter section.
- B. The manufacturer shall ship the rooftop unit with 2" MERV 8 construction filters. The contractor shall furnish and install, at building occupancy, the final set of 4" MERV 13 filters.

2.6 COOLING COIL

- A. The indoor coil section shall be installed in a draw through configuration, upstream of the supply air fan. The coil section shall be complete with a factory piped cooling coil and an ASHRAE 62.1 compliant double sloped drain pan.
- B. The direct expansion (DX) cooling coils shall be fabricated of seamless high efficiency copper tubing that is mechanically expanded into high efficiency aluminum plate fins. Coils shall be a multi-row, staggered tube design with a minimum of 3 rows. All cooling coils shall have an interlaced coil circuiting that keeps the full coil face active at all load conditions. All coils shall be factory leak tested with high pressure air under water.
- C. The cooling coil shall have an electronic controlled expansion valve. The unit controller shall control the expansion valve to maintain liquid subcooling and the superheat of the refrigerant system.
- D. The refrigerant suction lines shall be fully insulated from the expansion valve to the compressors.
- E. The drain pan shall be stainless steel and positively sloped. The slope of the drain pan shall be in two directions and comply with ASHRAE Standard 62.1. The drain pan shall have a minimum slope of 1/8" per foot to provide positive draining. The drain pan shall extend beyond the leaving side of the coil. The drain pan shall have a threaded drain connection extending through the unit base.

2.7 HOT GAS REHEAT RTU-106,107

- A. Unit shall be equipped with a fully modulating hot gas reheat coil with hot gas coming from the unit condenser.
- B. Hot gas reheat coil shall be a microchannel design. The aluminum tube shall be a microchannel design with high efficiency aluminum fins. Fins shall be brazed to the tubing for a direct bond. The capacity of the reheat coil shall allow for a 20°F temperature rise at all operating conditions.
- C. The modulating hot gas reheat systems shall allow for independent control of the cooling coil leaving air temperature and the reheat coil leaving air temperature. The cooling coil and reheat coil leaving air temperature setpoints shall be adjustable through the unit controller. During the dehumidification cycle the unit shall be capable of 100% of the cooling capacity. The hot gas reheat coil shall provide discharge temperature control within +/- 2°F.
- D. Each coil shall be factory leak tested with high- pressure air under water.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.8 SUPPLY FAN

1. Supply fan shall be a SWSI airfoil centrifugal fan, of Class II construction with steel fan blades welded to the back plate and end rim. The supply fan shall be mounted using solid-steel shafts and wheel hubs with mating keyways.
 2. The fan assembly shall have fixed pitched drives with a minimum of two belts. The drives shall be selected with a minimum diameter of 4 inches and a 1.2 service factor. The belts shall be of the grip- notch design.
 3. All fan assemblies shall be statically and dynamically balanced at the factory, including a final trim balance, prior to shipment. All fan assemblies shall employ solid steel fan shafts. Heavy-duty concentric locking pillow block type, self-aligning, grease lubricated ball bearings shall be used. Bearings shall be sized to provide a L-50 life at 200,000 hours. The entire fan assembly shall be isolated from the fan bulkhead and mounted on 1" spring isolators.
 4. Fan motors shall be heavy-duty 1800 rpm open drip-proof (ODP) type with grease lubricated ball bearings. Motors shall be premium efficiency. Motors shall be mounted on an adjustable base that provides for proper alignment and belt tension adjustment. Motors shall be suitable for use with a variable frequency drive.
 5. The supply fan shall be capable of airflow modulation from 30% to 100% of the scheduled designed airflow. The fan shall not operate in a state of surge at any point within the modulation range.
 6. Supply fan shall be a single width, single inlet (SWSI) airfoil centrifugal fan. The fan wheel shall be Class II construction with fan blades that are continuously welded to the hub plate and end rim. The supply fan shall be a direct drive fan mounted to the motor shaft.
 7. The fan motor shall be a totally enclosed EC motor that is speed controlled by the rooftop unit controller. The motor shall include thermal overload protection and protect the motor in the case of excessive motor temperatures. The motor shall have phase failure protection and prevent the motor from operation in the event of a loss of phase. Motors shall be premium efficiency.
 8. The supply fan shall be capable of airflow modulation from 30% to 100% of the scheduled designed airflow. The fan shall not operate in a state of surge at any point within the modulation range.
- B. All fans connected to variable frequency drives (VFDs) shall be furnished with grounding rings.

2.9 GAS HEATING SECTION

- A. RTU-103 and 108
1. The unit shall include a natural gas heating section. The gas furnace design shall have a natural gas fired heating module factory installed downstream of the supply air fan in the heat section. The module shall be complete with furnace controller and control valve capable of modulating operation from 100% down to 28% of full fire capacity. The heating module shall be a tubular design with in-shot gas burners. The heat exchanger tubes shall be constructed of stainless steel. The module shall have an induced draft fan that will maintain a negative pressure in the heat exchanger tubes for the removal of the flue gases.
 2. The burner module shall have two flame roll-out safety protection switches and a high temperature limit switch that will shut the gas valve off upon detection of improper burner manifold operation. The induced draft fan shall have an airflow safety switch that will prevent the heating module from turning on in the event of no airflow in the flue chamber.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

3. The burner shall be specifically designed to burn natural gas and shall include a microprocessor based flame safeguard control, combustion air proving switch, pre-purge timer and spark ignition. The gas train shall include redundant gas valves, maximum 0.5psi pressure regulator, shutoff cock, pilot gas valve, pilot pressure regulator, and pilot cock.
4. The factory-installed DDC unit control system shall control the gas heat module. Field installed heating modules shall require a field ETL certification. The manufacturer's rooftop unit ETL certification shall cover the complete unit including the gas heating modules.

2.10 CONDENSING SECTION

1. Condenser coils shall be an all-aluminum design. The aluminum tube shall be a micro channel design with high efficiency aluminum fins. Fins shall be brazed to the tubing for a direct bond. Each condenser coil shall be factory leak tested with high-pressure air under water. Condenser coils shall be protected from incidental contact to coil fins by a coil guard. Coil guard shall be constructed of cross wire welded steel with PVC coating.
2. Condenser fans shall be direct drive, axial type designed for low tip speed and vertical air discharge. Condenser fan rpm shall be 1140 rpm maximum. Fan blades shall be constructed of steel and riveted to a steel center hub. Condenser fan motors shall be heavy-duty, inherently protected, three-phase, non-reversing type with permanently lubricated ball bearing and integral rain shield.
3. Each circuit shall have fan cycling of at least one condenser fan to maintain positive head pressure. An ambient thermostat shall prevent the refrigeration system from operating below 0°F.
4. Condenser coils shall be protected from hail damage as an integral part of the unit design. Hail guards shall be provided on all units with vertical mounted condenser coils.
5. Each unit shall have multiple, heavy-duty scroll compressors. Each compressor shall be complete with gauge ports, crankcase heater, sight-glass, anti-slug protection, motor overload protection and a time delay to prevent short cycling and simultaneous starting of compressors following a power failure. Compressors shall be isolated with resilient rubber isolators to decrease noise transmission.
6. Each unit shall have two independent refrigeration circuits. Each circuit shall be complete with a low pressure control, filter-drier, thermal expansion valve, and a manual reset high pressure safety switch. The thermal expansion valve shall be capable of modulation from 100% to 25% of its rated capacity. Sight-glasses shall be accessible for viewing without disrupting unit operation. Each circuit shall be dehydrated and factory charged with Refrigerant 410A and oil.

2.11 ELECTRICAL

- A. Unit wiring shall comply with NEC requirements and with all applicable UL standards. All electrical components shall be UL recognized where applicable. All wiring and electrical components provided with the unit shall be number and color-coded and labeled according to the electrical diagram provided for easy identification. The unit shall be provided with a factory wired weatherproof control panel. Unit shall have a single point power terminal block for main power connection. A terminal board shall be provided for low voltage control wiring. Branch short circuit protection, 120-volt control circuit transformer and fuse, system switches, and a high temperature sensor shall also be provided with the unit. Each compressor and condenser fan motor shall be furnished with contactors and inherent thermal overload protection. Supply fan motors shall have contactors and external overload protection. Knockouts shall be provided in the bottom of the main control panels for field wiring entrance.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- B. A single fused disconnect switch shall be provided for disconnecting electrical power at the unit. Disconnect switches shall be mounted internally to the control panel and operated by an externally mounted handle.
- C. A GFI receptacle shall be unit mounted. The receptacle will require a field power connection independent from the unit's main power block and/or disconnect.
- D. A factory-installed phase monitor shall protect the unit from low voltage, phase imbalance and phase reversal.

2.12 CONTROLS

- A. Provide a complete integrated microprocessor based Direct Digital Control (DDC) system to control all unit functions including temperature control, scheduling, monitoring, unit safety protection, including compressor minimum run and minimum off times, and diagnostics. This system shall consist of all required temperature sensors, pressure sensors, controller and keypad/display operator interface. All MCBs and sensors shall be factory mounted, wired and tested.
- B. The stand-alone DDC controllers shall not be dependent on communications with any on-site or remote PC or master control panel for proper unit operation. The microprocessor shall maintain existing set points and operate stand alone if the unit loses either direct connect or network communications. The microprocessor memory shall be protected from voltage fluctuations as well as any extended power failures. All factory and user set schedules and control points shall be maintained in nonvolatile memory. No settings shall be lost, even during extended power shutdowns.
- C. The DDC control system shall permit starting and stopping of the unit locally or remotely. The control system shall be capable of providing a remote alarm indication. The unit control system shall provide for outside air damper actuation, emergency shutdown, remote heat enable/disable, remote cool enable/ disable, heat indication, cool indication, and fan operation.
- D. The controller shall have BACnet communication to the central control system.
- E. All digital inputs and outputs shall be protected against damage from transients or incorrect voltages. All field wiring shall be terminated at a separate, clearly marked terminal strip.
- F. The DDC controller shall have a built-in time schedule. The schedule shall be programmable from the unit keypad interface. The schedule shall be maintained in nonvolatile memory to insure that it is not lost during a power failure. There shall be one start/stop per day and a separate holiday schedule. The controller shall accept up to sixteen holidays each with up to a 5-day duration. Each unit shall also have the ability to accept a time schedule via BAS network communications.
- G. The keypad interface shall allow convenient navigation and access to all control functions. The unit keypad/display character format shall be 4 lines × 20 characters. All control settings shall be password protected against unauthorized changes. For ease of service, the display format shall be English language readout.
- H. The user interaction with the display shall provide the following information as a minimum:
 - 1. If the unit is to be programmed with a night setback or setup function, an optional space sensor shall be provided. Space sensors shall be available to support field selectable features. Sensor options shall include:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- a. Zone sensor with tenant override switch.
- I. The display shall provide the following information as required by selected unit options:
- 1. Unit status showing stages or % capacity for cooling, heating, and economizer operation.
 - 2. Supply, return, outdoor, and space air temperature.
 - 3. Duct and building static pressure; the control contractor is responsible for providing and installing sensing tubes.
 - 4. Supply fan and return fan status and airflow verification.
 - 5. Supply and return VFD speed (if applicable)
 - 6. Outside air damper position and economizer mode.
 - 7. Cooling and heating changeover status.
 - 8. Occupied and unoccupied.
 - 9. Date and time schedules.
 - 10. Up to 10 current alarms and 25 previous alarms with time and date.
 - 11. Dirty filter status.
 - 12. Morning warm-up or night setback status.
 - 13. System operating hours of the SAF, EAF, compressors, economizer, and heat.
- J. The keypad shall provide the following set points as a minimum as required by selected unit options:
- 1. Six control modes including off manual, auto, heat/cool, cool only, heat only, and fan only.
 - 2. Four occupancy modes including auto, occupied, unoccupied and bypass (tenant override with adjustable duration).
 - 3. Control changeover based on return air temperature, outdoor air temperature, or space temperature.
 - 4. Primary cooling and heating set point temperature based on supply or space temperature.
 - 5. Night setback and setup space temperature.
 - 6. Cooling and heating control differential (or dead band).
 - 7. Cooling and heating supply temperature reset options based on one of the following: Return air temperature, outdoor air temperature, space temperature, airflow, or external (1—5 VDC) signal.
 - 8. Reset schedule temperature.
 - 9. High supply, low supply, and high return air temperature alarm limits.
 - 10. Ambient compressor and heat lockout temperatures.
 - 11. Compressor interstage timers duration.
 - 12. Duct and building static pressure.
 - 13. Minimum outdoor airflow reset based on external reset (1—5 VFD) percent of cfm capacity, and fixed outdoor damper position.
 - 14. Economizer changeover based on enthalpy, dry bulb or network signal.
 - 15. Current time and date.
 - 16. Occupied/unoccupied time schedules with allowances for holiday/event dates and duration.
 - 17. Two types of service modes including timers normal (all time delays) and timers fast (all time delays 20 seconds).
 - 18. Tenant override time.
- K. The BMS system shall be capable of interacting with the individual rooftop controllers in the following ways:
- 1. Monitor controller inputs, outputs, set points, parameters and alarms.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2. Set controller set points and parameters.
 3. Clear alarms.
 4. Reset the cooling discharge air temperature set point (VAV and CAV-DTC units).
 5. Reset the duct static pressure set point (VAV units).
 6. Set the heat/cool changeover temperature (VAV and CAV-DTC units).
 7. Set the representative zone temperature (CAV- ZTC units).
- L. It will be the responsibility of the Building Automation System Contractor to integrate the rooftop data into the BMS control logic and interface stations.
- M. The units shall be provided with the following factory-installed sensors:
1. Leaving coil/entering fan temperature sensor.
 2. Return air temperature sensor.
 3. Discharge air temperature sensor – wired in unit, field mounted in duct.
 4. Outside air temperature sensor.
 5. Return air temperature sensor.
 6. Return air enthalpy sensor.
 7. Outside air enthalpy sensor.
 8. Dirty filter switch.
 9. Supply fan air proving sensor.
 10. Outside air monitor station.

2.13 ROOF CURB

- A. A prefabricated heavy gauge galvanized steel, mounting curb shall be provided for field assembly on the roof decking prior to unit shipment. The roof curb shall be a full perimeter type with complete perimeter support of the air handling section and condensing section. The curb shall be a minimum of (14", 24") high and include a nominal 2"x4" wood nailing strip. Gasket shall be provided for field mounting between the unit base and roof curb.

2.14 CAPACITIES AND CHARACTERISTICS

1. Capacities and Characteristics as scheduled on drawings.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Roof Curb: Install on roof structure or concrete base, level and secure, according to NRCA or AHRI Guideline B. Install RTUs on curbs and coordinate roof penetrations and flashing with roof construction specified in Division 07 Section "Roof Accessories." Secure RTUs to upper curb rail, and secure curb base to roof framing or concrete base with anchor bolts.
- B. Install condensate drain, minimum connection size, with trap and indirect connection to nearest roof drain or area drain.
- C. Install piping adjacent to RTUs to allow service and maintenance.
1. Gas Piping: Comply with applicable requirements in Division 23 Section Natural-Gas Piping. Connect gas piping to burner, full size of gas train inlet, and connect with union and shutoff valve with sufficient clearance for burner removal and service.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- D. Duct installation requirements are specified in other Division 23 Sections. Drawings indicate the general arrangement of ducts. The following are specific connection requirements:
1. Install ducts to termination at top of roof curb.
 2. Remove roof decking only as required for passage of ducts. Do not cut out decking under entire roof curb.
 3. Connect supply ducts to RTUs with flexible duct connectors specified in Division 23 Section "Air Duct Accessories."
 4. Install return-air duct continuously through roof structure.

3.2 FIELD QUALITY CONTROL

- A. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect, test, and adjust components, assemblies, and equipment installations, including connections. Report results in writing.
- B. Perform tests and inspections and prepare test reports.
1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing. Report results in writing.
- C. Tests and Inspections:
1. After installing RTUs and after electrical circuitry has been energized, test units for compliance with requirements.
 2. Inspect for and remove shipping bolts, blocks, and tie-down straps.
 3. Operational Test: After electrical circuitry has been energized, start units to confirm proper motor rotation and unit operation.
 4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- D. Remove and replace malfunctioning units and retest as specified above.

3.3 CLEANING AND ADJUSTING

- A. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting system to suit actual occupied conditions. Provide an additional visit to the site during other-than-normal occupancy hours for this purpose.
- B. After completing system installation and testing, adjusting, and balancing RTU and air-distribution systems, clean filter housings and install new filters.

END OF SECTION

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

THIS PAGE IS INTENTIONALLY BLANK

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

SECTION 238126

SPLIT-SYSTEM AIR-CONDITIONERS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes split-system air-conditioning units consisting of separate evaporator-fan and compressor-condenser components.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Operation and maintenance data.
- C. Warranty

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ASHRAE Compliance:
 - 1. Fabricate and label refrigeration system to comply with ASHRAE 15, "Safety Standard for Refrigeration Systems."
 - 2. Applicable requirements in ASHRAE 62.1-2016, Section 4 - "Outdoor Air Quality," Section 5 - "Systems and Equipment," Section 6 - "Procedures," and Section 7 - "Construction and System Start-Up."
- C. ASHRAE/IESNA Compliance: Applicable requirements in ASHRAE 90.1-2010.

1.4 WARRANTY

- A. One (1) year manufacturer's warranty, provide an additional four (4) year warranty on all compressors (5 years total).

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
 - 1. Mitsubishi Electric
 - 2. Daikin
 - 3. SAMSUNG

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.2 GENERAL

A. Description:

1. Outdoor--mounted, air--cooled, split--system air conditioner unit suitable for ground or rooftop installation. Unit consists of a hermetic compressor, an air--cooled coil, propeller--type condenser fan, and a control box. Unit will discharge supply air horizontally as shown on contract drawings. Unit will be used in a refrigeration circuit to match up to a packaged fan coil or coil unit.
2. Indoor, direct--expansion, wall--mounted fan coil. Unit shall be complete with cooling coil, fan, fan motor, piping connectors, electrical controls, microprocessor control system, and integral temperature sensing. Unit shall be furnished with integral wall mounting bracket and mounting hardware.

B. Refrigeration Components:

1. Refrigeration circuit components will include liquid--line front--seating shutoff valve with sweat connections, vapor--line front--seating shutoff valve with sweat connections, system charge of R--410A refrigerant, and compressor oil. Unit will be equipped with high--pressure switch, low pressure switch and filter drier for R-410A refrigerant.

2.3 INDOOR WALL-MOUNTED DUCT FREE UNIT

A. Unit Cabinet

1. Cabinet discharge and inlet grilles shall be attractively styled, high--impact polystyrene. Cabinet shall be fully insulated for improved thermal and acoustic performance.

B. Fans

1. Fan shall be tangential direct--drive blower type with air intake at the top of the unit and discharge at the bottom front. Automatic, motor--driven vertical air sweep shall be provided standard.
2. Air sweep operation shall be user selectable. The vertical sweep may be adjusted (using the remote control) and the horizontal air direction may be set manually.

C. Coil

1. Coil shall be copper tube with aluminum fins and galvanized steel tube sheets. Fins shall be bonded to the tubes by mechanical expansion.
2. A drip pan under the coil shall have two drain connections for hose attachment, on either the left or right--hand side, to remove condensate. Condensate pan shall have internal trap.

D. Motors

1. Motors shall be open drip--proof, permanently lubricated ball bearing with inherent overload protection. Fan motors shall be 3--speed.

E. Filters

1. Unit shall have filter track with factory--supplied cleanable filters.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

- F. Operating Characteristics
 - 1. Indoor unit when matched with the appropriate outdoor section, shall have a minimum listed SEER (seasonal energy efficiency ratio) of 13 at ARI conditions.
 - 2. All other operating characteristics as scheduled on the drawings.

2.4 OUTDOOR CONDENSING UNIT

- A. Unit Cabinet
 - 1. Unit cabinet shall be will be constructed of galvanized steel, bonderized, and coated with a powder coat paint.
- B. Fans
 - 1. Fan shall be direct-drive propeller type discharging air horizontally.
 - 2. Condenser fan motors will be totally enclosed, 1—phase type with class B insulation and permanently lubricated bearings. Shafts will be corrosion resistant.
 - 3. Fan blades will be statically and dynamically balanced.
 - 4. Condenser fan openings will be equipped with coated steel wire safety guards.
- C. Compressor
 - 1. Compressor will be hermetically sealed.
 - 2. Compressor will be mounted on rubber vibration isolators.
 - 3. Condenser coil will be air cooled.
 - 4. Coil will be constructed of aluminum fins mechanically bonded to copper tubes which are then cleaned, dehydrated, and sealed.

2.5 CONTROLS

- A. Controls shall consist of a microprocessor-based control system which shall control space temperature, determine optimum speed, and run self diagnostics.
 - 1. User interface with the unit shall be accomplished through a **wired** controller.
- B. The unit shall have the following functions as a minimum:
 - 1. An automatic restart after power failure at the same operating conditions as at failure.
 - 2. A timer function to provide a minimum 24--hour timer cycle for system Auto Start/Stop.
 - 3. Temperature--sensing controls shall sense return air temperature.
 - 4. Indoor coil freeze protection.
 - 5. Automatic vertical air sweep control to provide on or off activation of air sweep louvers.
 - 6. Dehumidification mode shall provide increased latent removal capability by modulating system operation and set point temperature.
 - 7. Fan--only operation to provide room air circulation when no cooling is required.
 - 8. Diagnostics shall provide continuous checks of unit operation and warn of possible malfunctions. Error messages shall be displayed at the unit.
 - 9. Fan speed control shall be user--selectable: high, medium, low, or microprocessor controlled automatic operation during all operating modes.

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

2.6 OPTIONAL FEATURES:

- A. Provide Low Ambient Kit: Control shall regulate fan--motor cycles in response to saturated condensing temperature of the unit. The control shall be capable of maintaining a condensing temperature of 100 F \pm 10 F with outdoor temperatures to -20 F
- B. Provide crankcase heater
- C. Provide wind baffle

2.7 ELECTRICAL REQUIREMENTS:

- A. Unit shall operate on the voltage shown on drawings.
- B. Only control wiring shall run between the indoor and outdoor units.
- C. Indoor and Outdoor unit electrical power shall be single point connection.
- D. Voltage as scheduled on drawings.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Condenser shall be installed in strict accordance with the manufacturer's printed instructions.
- B. Install units level and plumb.
- C. Install evaporator-fan components using manufacturer's standard mounting devices securely fastened to building structure.
- D. Install compressor-condenser components on equipment supports specified in Division 07. Anchor units to supports with removable, fasteners.
- E. Test, dehydrate, and charge the refrigeration system in strict accordance with the manufacturer's instructions.
- F. Insulate both refrigerant lines.

3.2 CONNECTIONS

- A. For Refrigerant Piping Refer to Section 232300

3.3 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
 - 1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.
- B. Tests and Inspections:

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

1. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
2. Operational Test: After electrical circuitry has been energized, start units to confirm proper motor rotation and unit operation.
3. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.

C. Remove and replace malfunctioning units and retest as specified above.

D. Prepare test and inspection reports.

3.4 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain units.

END OF SECTION

WAYNE STATE UNIVERSITY
MATTHAEI PHYSICAL EDUCATION CENTER
ADDITION OF AIR CONDITIONING

THIS PAGE IS INTENTIONALLY BLANK