



Division of Finance and Business Operations

Procurement & Strategic Sourcing
5700 Cass Avenue, suite 4200
Detroit, Michigan 48202
(313) 577-3734

June 8, 2020

**Addendum #2 To
Request for Proposal
For Mott - 1st floor Office Renovation: Project 609-331367
Dated May 26, 2020**

The Addendum must be acknowledged on your lump sum bid.

NOTE: You must have attended a Pre-Bid conference in order to be eligible to bid on a particular project. Receipt of minutes or addenda without being at a Pre-Bid conference does not qualify your company to bid.

Please find the following questions and clarifications with regards to the above competitive bid opportunity.

Question 1: Will a visually impaired (VI) safety strip be required at the South vestibule stairs (vestibule #100.3)?

Answer: No, VI safety strips are not required.

Question 2: Will loading dock vestibule (room 004) be added to the scope of Lobby floor replacement?

Answer: No, Room 004 will not be added to the project scope.

Question 3: Will the replacement of additional wall base removal/install be added to the scope in Break Room 103?

Answer: No, additional wall base removal/install will be added to the current scope of work.

Question 4: Is there an overage requirement for flooring materials (LVT and Carpet)?

Answer: Yes, a 5% overage should be included for both LVT and Carpet as part of the base bid.

Question 5: What is the direction of the flooring material (LVT) in the Lobby?

Answer: The orientation of the lobby is generally North/South, therefore the flooring material will run East/West.

IMPORTANT- This is an addendum which MUST be acknowledged on your bid form

We will require your lump sum proposals, vendor qualification questionnaire and your bid bond documents as a single PDF in your electronic submission.

All questions concerning this project must be emailed to: **Robert Kuhn**, Procurement & Strategic Sourcing. Email: **ac6243@wayne.edu**, and copy **Kim Tomaszewski**, Senior Buyer, at **ac9934@wayne.edu**.

Bids are due **by electronic submission** on no later than 2:00 p.m., **June 11, 2020**. The link for bid submission will be posted with the bid details at **<http://go.wayne.edu/bids>** beginning **May 26, 2020**.

Do not contact either FP&M or the Design Firm directly as this may result in disqualification of your proposal.

Thank you for interest shown in working with Wayne State University.

Robert Kuhn
Senior Buyer

CC: Matthew Clor (Project Manager), Kim Tomaszewski, Senior Buyer, Attendee list.