



Division of Finance and Business Operations

Procurement & Strategic Sourcing  
5700 Cass Avenue, suite 4200  
Detroit, Michigan 48202  
(313) 577-3734  
FAX (313) 577-3747

October 17, 2018

**Addendum #2 To  
Request for Proposal  
For Mott ATS Replacement: Project 609-314591**

**Dated October 5, 2018**

As a result of the Mandatory Pre-proposal Meeting on October 12, 2018 questions have been submitted for clarification. The questions and the University's responses are as follows:

1. Drawing E-5.1 details the new work ATS as a standard single Service Entrance Rated ATS, not a Bypass Isolation type ATS, while note #1 calls out Closed Transition/Bypass Isolation Type 4 Pole ATS. I would like to make sure that we should be providing a 4 Pole, Closed Transition, Bypass Isolation Type ATS?  
Response: Per the revised drawings sheet E5.1 note # 1, it should be 4 pole, closed transition with bypass.
2. For Service Entrance Rated, Closed Transition, Bypass Isolation style ATS would it be acceptable to provide the UL1008 Listed Eaton Magnum Power Circuit Breakers 4 Pole ATS instead of the specified Contactor Style ATS?  
Response: You can quote it in voluntary proposal, but you need to submit a proposal based on specs and drawings.
3. The old ASCO ATS carried a Short Circuit Amps of 42kAIC, is this acceptable as a minimum requirement of the new ATS?  
Response: Yes, this is acceptable.
4. Would the customer like us to Add our Optional Communications Interface via Modbus 485 or Ethernet TCP/IP to the ATS Controller since it is more cost effective to include it now than to try and add this capability later in the field.  
Response: The ATS should be ready for future connection with the building management system through BACnet.

**The Addendum must be acknowledged on your lump sum bid.**

NOTE: You must have attended a pre-bid conference in order to be eligible to bid on a particular project. Receipt of minutes or addenda without being at a pre-bid conference does not qualify your company to bid.

A copy of this Addendum will be posted to the Purchasing web site at  
**<http://go.wayne.edu/bids>.**

All questions concerning this project must be emailed to: **Kimberly Tomaszewski**, Procurement & Strategic Sourcing. Email: **[ac9934@wayne.edu](mailto:ac9934@wayne.edu)**, and copy **Leiann Day**, Associate Director, at **[Leiann.day@wayne.edu](mailto:Leiann.day@wayne.edu)**.

Bids are due **by electronic submission** on no later than 2:00 p.m., **October 22, 2018**. The link for bid submission will be posted with the bid details at **<http://go.wayne.edu/bids>** beginning **October 5, 2018**.

Thank you,

**Kimberly Tomaszewski,**  
**Senior Buyer**