



Division of Finance and Business Operations

Procurement & Strategic Sourcing
5700 Cass Avenue, suite 4200
Detroit, Michigan 48202
(313) 577-3734
FAX (313) 577-3747

2/8/16

**Addendum #3 To
Request for Proposal
For University Towers Lobby Upgrades: Project 507-243838
Dated January 21, 2016**

The Addendum must be acknowledged on your lump sum bid.

NOTE: You must have attended a prebid conference in order to be eligible to bid on a particular project. Receipt of minutes or addenda without being at a prebid conference does not qualify your company to bid.

Do not contact either FP&M or the Design Firm directly as this may result in disqualification of your proposal.

Question 1: Is Ceiling MP1 for Bid Alternate #4 supposed to have an integral return edge at the perimeter where floating? If so please advise of height.

Answer: Integral return edge to be sufficient length to ensure full coverage of vertical edge, 4" minimum.

Thank you for interest shown in working with Wayne State University.

Robert Kuhn
Sr. Buyer

CC: Jason R. Davis (Project Manager), Deborah Brazen, Leiann Day, Procurement Analyst,
Attendee list.