



Division of Finance and Business Operations

Procurement & Strategic Sourcing
5700 Cass Avenue, suite 4200
Detroit, Michigan 48202
(313) 577-3734
FAX (313) 577-3747

August 8, 2019

Addendum 4
RFP Gateway Theatre Complex Project
dated July 19, 2019

Note: You must have attended the **mandatory** pre-bid meeting to participate in this bid opportunity.

Numerous simple questions have been submitted and the clarifications are as follows:

Question 1: Kalwall panels are Basis of Design on this project. Can you clarify the face sheet color or the U-Factor in the spec or the details? Where can they be found?

Answer: Please note the design is not final at 100% Design Development Phase, however initial conversations between the design team and Kalwall representatives have occurred. The following is the latest progress on this scope item for your use:

Exterior faces shall be (smooth or pebble) 0.070 "thick and Crystal in color. Interior face sheets shall be 0.045" thick and White in color. Faces shall not vary more than +/- 10% in thickness.

Approved Manufacturers for .23 Certified system Panel values per NFRC and .29 Certified System "U" values NFRC.

All questions concerning this project must be emailed to: Robert Kuhn, Procurement & Strategic Sourcing at 313-577-3712 Email: ac6243@wayne.edu (copy to Valerie Kreher, Email: ab4889@wayne.edu) by August 09, 2019, 12:00 pm/noon.

Do not contact the Facilities Planning & Management, or other University Units, directly as this may result in disqualification of your proposal.

Thank you

Robert Kuhn,
Senior Buyer, Purchasing
313-577-3712

CC: Ryan Miller, Kenneth Doherty, Attendees list.